



## **DIRECTOR SHIRE SERVICES REPORT**

10<sup>th</sup> May 2005

<b>DSS17</b>	<b>HAT HEAD SEWERAGE</b>
	<b>FILE: S8-24      DH</b>

### **SUMMARY:**

Reporting on the operating and maintenance of Hat Head sewerage system.



This report is provided following the resolution from the February Council meeting and updates the previous report regarding operation and maintenance of the Hat Head Sewerage Scheme.

### **Sewerage Treatment Plant**

United Kilpatrick Green to visit the STP on the 03/05/2005 in an attempt to finalise any outstanding modifications to the plant.

Outstanding STP problems to be repaired or replaced.

- Sludge storage tank Floats still inverted.

### **Sewerage Pumping Station**

Outstanding problems to be repaired or equipment replaced in the Reticulation system and SPS.

- Airvac have advised new Transfer Pumps and motors to be installed 03/05/2005.

### **Dune Disposal**

No current problems with effluent disposal to date.

### **EPA Licence compliance**

The plant has been operating within the guidelines of the EPA licence conditions for April.

Furthermore, no incidents of no compliance were reported to have occurred during the peak loading period of the Easter break. It should be noted that the tourist/holiday population influx over Easter was minimal.

**REPORT IMPLICATIONS:**

- **Environmental Implications**

*When completed and running efficiently the sewerage system will improve the environment of Hat Head.*

- **Social Implications**

*The moratorium on further development in Hat head under DCP37 will continue until the sewerage system is fully functional.*

- **Economic (Financial) Implications**

*There are no economic implications as all costs are borne by the contractors.*

- **Policy or Statutory Implications**

*There are no policy or statutory implications from the following recommendations.*

- **Director's Review**

*Improvements to the system have occurred and will continue to improve the sewerage system to a satisfactory level.*

**RECOMMENDATION:**

That the information be noted.

.....  
K J Finnie  
DIRECTOR SHIRE SERVICES