



KEMPSEY

Shire Council

Drinking Water Management System

Annual Report

July 2020-June 2021

Document control

Document	Drinking Water Management System Annual Report
File No	F19/2008
Date	4th May 2022
Prepared by	Bobbie Brenton, Water Quality Officer Kempsey Shire Council On behalf of Wes Trotter, Manager Water and Sewer Kempsey Shire Council
Approved by	Robert Fish, Director Operations and Planning Kempsey Shire Council

Report Revision History

Version	Date	Details	Review
0.1	04/03/2022	First Draft	Internal – Kempsey Shire Council Wes Trotter – Manager Water and Sewer John Nelson – Coordinator Water and Sewer Operations Scott Brown – Team Leader Water Treatment
0.2	11/03/2022	Second Draft	Internal - Kempsey Shire Council Robert Fish - Director Operations and Planning
0.3	18/03/2022	Final Draft	External - North Coast Public Health Unit Tennille Lawrence-Haskew – Senior Environmental Health Officer David Basso - Environmental Health Officer
0.4	21/03/2022	Final Draft review	North Coast Public Health Unit and Kempsey Shire Council Yearly DWMS Review meeting North Coast Public Health Unit David Basso - Environmental Health Officer Kempsey Shire Council Robert Fish - Director Operations and Planning Wes Trotter – Manager Water and Sewer John Nelson – Coordinator Process Water and Sewer Scott Brown – Team Leader Water Treatment Bobbie Brenton – Water Quality Officer
1.0	26/04/2022	Final	External - North Coast Public Health Unit David Basso - Environmental Health Officer

Executive Summary

Kempsey Shire Council (Council) manages eight (8) water supply systems, providing drinking water to Kempsey - Lower Macleay (KLM), Crescent Head, Hat Head, South West Rocks, Stuarts Point, Willawarrin, Bellbrook, and the Thunggutti Aboriginal Community.

Council has developed this report as part of its requirements to perform an annual evaluation and review of the performances of its water supply systems. The evaluation and review are based on the current regulatory framework, reporting requirements and guidelines of the Australian Drinking Water Guidelines (ADWG) (ADWG; 2011); along with reporting requirements of NSW Health that includes a yearly document submission to the local Public Health Unit (PHU), NSW Health.

This report covers the period of 1 of July 2020 to 30 of June 2021 and satisfies the reporting (Element 10), evaluation (Element 11) and review and continual improvement (Element 12) requirements of Councils Drinking Water Management System (DWMS).

DWMS document review

Internal workshops during February 2021 were held for the review of the DWMS Overall Manual, Sub plans (8 separate supply systems) and the Water Quality Incident Response and Reporting plan. Identified updates included adjustments to CCPs and monitoring frequencies, these were finalized before 30 June 2021 for commencement at the start of the 2021-2022 reporting period.

Review and updates to the Risk Register and Implementation Plan (IP) where completed post 2020-2021 report period (workshops held in October 2021). Summary is discussed in "Improvement plan implementation".

Supply summary and system upgrades

Planning was completed and the Stuarts Point Reservoir refurbishment had commenced in the Stuarts Point supply system; pH correction facilities were added to Willawarrin and Thunggutti supplies, and membrane cleaning system modifications continue in the South West Rocks supply.

Performance of critical control points

Council had fifty-six (56) fewer Critical Control Point (CCP) exceptions reported compared to 2019-2020 reporting year. The Kempsey - Lower Macleay and Crescent Head supplies showed the greatest improvement from the previous reporting year with only the Willawarrin supply having an increase in the number of captured CCP exceptions. No exceptions were recorded in the South West Rocks or Stuarts Point supplies. A summary of critical control point exceptions is listed in Table E.1.

Table E.1 - Critical Control Points Summary

Supply System	2019 -2020			2020-2021			Difference between report years
	Alert	Critical	Total	Alert	Critical	Total	
Kempsey - Lower Macleay	35	2	37	13	0	13	-24
Crescent Head	41	0	41	19	0	19	-22
Hat Head	7	0	7	1	0	1	-6
South West Rocks	0	0	0	0	0	0	0
Stuarts Point	0	0	0	0	0	0	0
Willawarrin	2	1	3	3	1	4	+1
Bellbrook	7	0	7	6	1	7	0
Thunggutti	12	3	15	9	0	9	-6
Total	104	5	109	51	2	53	-56

Reservoir inspection programs

No breaches of integrity were detected during in house monthly CCP reservoir inspections.

Three (3) reservoirs (Clybucca, Willawarrin, and Bellbrook) were cleaned and inspected by external contractors during this reporting period.

Water quality verification

Seventy-eight (78) ADWG and Water Quality Indicators (WQI) exceptions occurred from the combined NSW Health sponsored monitoring program and Council's in house operational monitoring program. This includes four (4) Total Coliform detections and three (3) Nickel detections above the ADWG and WQI.

Total ADWG and WQI water quality exceptions by supply system is summarised in Table E.2.

Table E.2 Total ADWG and WQI water quality exceptions by supply system

	Kempsey Lower Macleay	Crescent Head	Hat Head	South West Rocks	Stuarts Point	Willawarrin	Bellbrook	Thunggutti	Total
NSW Health Program	4	3	1	1	0	6	0	4	19
Council Program	0	0	0	0	0	37	0	22	59
Total	4	3	1	1	0	43	0	26	78

Consumer enquires

Thirty-six (36) customer enquiries were recorded across all supplies; a decrease 67.6 % from the one-hundred and eleven (111) enquires from 2019-2020. The majority of enquiries were in the Kempsey – Lower Macleay supply; no customer enquiries were recorded at either Stuarts Point or Thunggutti. Table E.3 provides a summary of customer enquires.

Table E.3 Customer Enquires for Councils Water Supply Systems

Supply System	Dirty	Air or Cloudy	Taste & Odour	Illness	Loss of Supply	Other	Total
Kempsey – Lower Macleay	7	1	0	0	12	0	20
Crescent Head	1	0	0	0	0	0	1
Hat Head	2	0	0	0	0	0	2
South West Rocks	4	1	3	0	1	0	9
Stuarts Point	0	0	0	0	0	0	0
Willawarrin	2	0	0	0	0	0	2
Bellbrook	2	0	0	0	0	0	2
Thunggutti	0	0	0	0	0	0	0
Total	18	2	3	0	13	0	36

Water quality incidents or emergency

Two (2) Critical Limit exceptions were reported in two (2) separate water quality incidents to the local North Coast Public Health Unit (NCPHU) at time of occurrence. Table E.4 provides a summary of the water quality incidents.

Table E.4 Water Quality Incidents

Supply	Date of Event	Location	CCP Number	CCP Parameter	CCP Critical Limit	CCP Result
Bellbrook	1/07/2020	Clear Water Tank	CCP3	Free Chlorine	4.0 mg/L	4.1 mg/L
Willawarrin	29/10/2020	Raw Water	CCP1	Turbidity	2 NTU	3.12 NTU

Monitoring programs

Pesticide monitoring from water supplies servicing discrete Aboriginal communities (5 identified within the drinking water supply areas of Council) are funded by the NSW Aboriginal Communities Water and Sewer Program (ACWSP) every five (5) years. No pesticide testing was conducted in 2020-2021, the next program cycle is due to commence in 2022.

The NSW Department of Primary Industries (DPI) inspects the water supply at the Aboriginal communities at least yearly and checks water quality against ADWG and NSW Health recommended indicators for the tested parameters. All supplies at time of inspections met water quality specifications except for the Greenhill community, though it has been identified that the testing location is not a representative location of water that is supplied to this community.

Staff training and development

Training and development programs completed by the Water Process Team during 2020-2021 is captured in Table E.5.

Table E.5 Summary of Completed Training during 2020-2021

Training Details	Trainees	Water Process Operators	Management Team
DWMS Water Quality Incident Response Yearly VOC	4	6	4
DWMS Documentation and Process updates from DWMS review	4	6	4
Pollution Incident Response Management Plan (PIRMP) Yearly VOC	4	6	4
NSW Health Fluoride Plant Operator Certificate		3	
Asbestos Awareness		5	2
Chemical Awareness	4	6	4
Apply Fist Aid and Perform CPR		1	
Working at Heights	1		
Governance and Risk Management 101			1

Continuous improvement - implementation plan (IP)

Since the establishment of the DWMS in 2014, the IP has been reviewed yearly by the Risk Management Team in conjunction with the Risk Register. Table E.6 provides the status of the IP at the end of 2020-2021 report year (review undertaken in October 2021).

Table E.6. Implementation Plan progress status based on risk value

Residual Risk	Removed	Completed	Standing Items	In progress	Ongoing (Long term actions)	Not Started	New	Tasks Remaining
Very High	2	3	0	4	4	1	0	9
High	5	3	4	25	8	3	0	40
Medium	7	8	0	13	9	3	0	25
Low	3	2	3	11	6	2	0	22
Total	17	20	9	53	27	9	0	96

Contents

1. Report Purpose	1
2. DWMS Document Review	1
3. Supply Summary and Upgrades	3
4. Critical Control Points	7
4.1. Data Collection and Monitoring	7
4.2. Non-Compliant Data	7
4.3. Reporting	8
4.3.1 Kempsey and Lower Macleay (KLM) Supply System.....	12
4.3.2 Crescent Head Supply System.....	13
4.3.3 Hat Head Supply System.....	15
4.3.4 South West Rocks Supply System.....	16
4.3.5 Stuarts Point Supply System.....	18
4.3.6 Willawarrin Supply System.....	19
4.3.7 Bellbrook Supply System	20
4.3.8 Thunggutti Supply System.....	21
5. Reservoir Inspections	23
5.1. Data Collection and Monitoring.....	23
5.2. Reporting	23
6. Water Quality Verification	26
6.1. Data Collection and Monitoring.....	26
6.2. Non-Compliant data.....	26
6.3. Reporting	26
6.3.1 Kempsey and Lower Macleay (KLM) Supply System.....	29
6.3.2 Crescent Head Supply System.....	30
6.3.3 Hat Head Supply System.....	30
6.3.4 South West Rocks Supply System.....	31
6.3.5 Stuarts Point Supply System.....	31
6.3.6 Willawarrin Supply System.....	31
6.3.7 Bellbrook Supply System	32
6.3.8 Thunggutti Supply System.....	32
7. Water Quality Incident or Emergency	32
8. Customer Enquires.....	34
9. Monitoring Programs	35
9.1. Stuart Macintyre Dam (SMD) Algae Monitoring Program.....	35
9.2. Aboriginal Communities Water & Sewage Program (ACWSP)	35
9.2.1 Pesticide Testing.....	36
9.2.2 Inspections and Water Quality Testing to ADWG and WQIs.....	36
10. Staff Training and Development.....	37

11. Continual Improvement – Implementation Plan.....	37
12. References	45

Appendix A - Summary of CCP for each Supply System	A-1
Table A.1a CCP Kempsey and Lower Macleay Water Supply – Lime Plant.....	A-1
Table A.1a.1 SOP for KLM CCP1 Turbidity - Lime Plant in use	A-2
Table A.1a.2 SOP for KLM CCP3 Free Chlorine & pH – Lime Plant in use	A-3
Table A.1b.3 SOP for KLM CCP5 Reservoir Integrity - Lime Plant in use.....	A-4
Table A.1b CCP Kempsey and Lower Macleay Water Supply – SMD in use.....	A-5
Table A.1b.1 SOP for KLM CCP1 Turbidity (inlet race) - SMD in use	A-6
Table A.1b.2 SOP for KLM CCP1 Turbidity (pump transfer) - SMD in use.....	A-7
Table A.1b.3 SOP for KLM CCP1 Algae, (in dam) – SMD in use.....	A-8
Table A.1b.4 SOP for KLM CCP3 Free Chlorine & pH – SMD	A-9
Table A.1b.5 SOP for KLM CCP5 Reservoir Integrity – SMD in use.....	A-10
Table A.2 CCP Crescent Head Water Supply.....	A-11
Table A.3.1 SOP for HH CCP1 Turbidity at Raw Water.....	A-12
Table A.3.2 SOP for HH CCP3 Free Chlorine and pH at outlet of Reservoir	A-13
Table A.3.3 SOP for HH CCP5 Reservoir Integrity at all Reservoirs	A-14
Table A.3 CCP Hat Head Water Supply.....	A-15
Table A.3.1 SOP for HH CCP1 Turbidity at Raw Water.....	A-16
Table A.3.2 SOP for HH CCP3 Free Chlorine and pH at outlet of Reservoir	A-17
Table A.3.3 SOP for HH CCP5 Reservoir Integrity at all Reservoirs	A-18
Table A.4 CCP South West Rocks Water Supply.....	A-19
Table A.4.1 SOP for SWR CCP1 Turbidity at inlet to WTP (Raw Water)	A-20
Table A.4.2 SOP for SWR CCP2 Turbidity at Outlet of filters (Treated Water).....	A-21
Table A.4.3 SOP for SWR CCP3 Free Chlorine and pH at Reservoir.....	A-22
Table A.4.4 SOP for SWR CCP4 Fluoridation at WTP and Reservoir.....	A-23
Table A.4.5 SOP for SWR CCP5 Reservoir Integrity at all Reservoirs	A-24
Table A.5 CCP Stuarts Point Water Supply	A-25
Table A.5.1 SOP for SP CCP1 Turbidity at WTP before disinfection (Raw Water).....	A-26
Table A.5.2 SOP for SP CCP2 Turbidity at WTP post filtration (Treated Water)	A-27
Table A.5.3 SOP for SP CCP3 Free Chlorine at Clear Water Tank	A-28
Table A.5.4 SOP for SP CCP5 Reservoir Integrity at all Reservoirs.....	A-29
Table A.6 CCP Bellbrook Water Supply.....	A-30
Table A.6.1 SOP for BB CCP1 Turbidity at Inlet to Plat (Raw Water)	A-31
Table A.6.2 SOP for BB CCP2 Turbidity at WTP post filtration (Treated Water)	A-32
Table A.6.3 SOP for BB CCP3 Free Chlorine at outlet of Clear Water Tank.....	A-33
Table A.6.4 SOP for BB CCP5 Reservoir Integrity at all Reservoirs.....	A-34
Table A.7 CCP Willawarrin Water Supply	A-35
Table A.7.1 SOP for WW CCP1 Turbidity at Raw Water	A-36
Table A.7.2 SOP for WW CCP3 Free Chlorine at Reservoir.....	A-37
Table A.7.3 SOP for WW CCP5 Reservoir Integrity at all Reservoirs.....	A-38
Table A.8 CCP Thungutti Water Supply.....	A-39

Table A.8.1 SOP for TH CCP1 Turbidity at Raw Water	A-40
Table A.8.2 SOP for TH CCP3 Free Chlorine at Reservoir	A-41
Table A.8.3 SOP for TH CCP5 Reservoir Integrity at all Reservoirs.....	A-42
Appendix B - Stuart McIntyre Dam Algae Monitoring.....	B-1
Figure B.1 Stuart McIntyre Dam Total Cyanobacteria Biovolume and Alert Levels	B-1
Figure B.2 Total Phytoplankton and Taste and Odour Results	B-2
Appendix C - Water Quality Verification Data	C-1
Table C.1 Kempsey and Lower Macleay Water Supply Water Quality Data	C-2
Table C.2 Crescent Head Supply System Water Quality Data	C-3
Table C.3 Hat Head Supply System Water Quality Data	C-4
Table C.4 South West Rocks Supply System Water Quality Data	C-5
Table C.5 Stuarts Pint Supply System Water Quality Data	C-6
Table C.6 Willawarrin Supply System Water Quality Data	C-7
Table C.7 Bellbrook Supply System Water Quality Data	C-8
Table C.8 Thunggutti Supply System Water Quality Data	C-9
Appendix D - Customer Enquiry Supply Area Description	D-1
Table D.1 Customer Enquiry Descriptors for KLM Supply System.....	D-1
Appendix E - Continuous Improvement – Implementation Plan.....	E-1

Tables

Table 2.1 DWMS Document Revision History.....	2
Table 3.1 Councils Drinking Water Supply Systems Summary.....	5
Table 4.1 Summary of Critical Control Point exceptions 2020-2021 comparison to 2019-2020.....	9
Table 5.1 Reservoir Schedule for external contractor inspections and cleaning	24
Table 5.2 Reservoir Inspection Report Summary	24
Table 6.1 ADWG and WQI non-compliances - NSW Health sponsored monitoring program	28
Table 6.2 ADWG and WQI non-compliances - Operational monitoring program.....	28
Table 7.1 Water Quality Incident or Emergency Summary.....	33
Table 8.1 Customer Enquires for the KLM Water Supply System.....	34
Table 8.2 Customer Enquires for Councils Water Supply Systems excluding KLM.....	34
Table 9.1 Pesticide Monitoring at Aboriginal communities.....	36
Table 9.2 DPIE inspection Water Quality results	36
Table 10.1 Completed Staff Training and Development Summary.....	37
Table 11.1 Implementation Plan Review History.....	38
Table 11.2. Progress on actions based on risk ranking by risk ranking.....	38
Table 11.3 Summary of Completed tasks in Implementation Plan	39
Table 11.4 Summary of removed tasks from Implementation Plan	41

Figures

Figure 3.1 Kempsey Shire Water Supply	4
Figure 4.3.1a CCP 1 Abstraction – Turbidity at combined raw water Lime Plant	12

Figure 4.3.1b CCP3 Disinfection – Free Chlorine at Greenhill Reservoir outlet.....	12
Figure 4.3.1c CCP3 Disinfection – pH at Greenhill Reservoir.....	12
Figure 4.3.2a CCP 1 Abstraction – Turbidity at Front Dam.....	13
Figure 4.3.2b CCP3 Disinfection – Free Chlorine at Back Beach Reservoir.....	13
Figure 4.3.2c CCP3 Disinfection – pH at Back Beach Reservoir outlet.....	14
Figure 4.3.3a CCP 1 Abstraction – Turbidity at Raw water inlet	15
Figure 4.3.3b CCP3 Disinfection – Free Chlorine Clear water to retic.....	15
Figure 4.3.3c CCP3 Disinfection – pH Clear water to retic	15
Figure 4.3.4a CCP 1 Abstraction – Turbidity at Raw water inlet	16
Figure 4.3.4b CCP 2 Filtration – Turbidity after filters	16
Figure 4.3.4c CCP3 Disinfection – Free Chlorine Gregory Street Reservoir outlet	17
Figure 4.3.4d CCP3 Disinfection – pH Gregory Street Reservoir outlet	17
Figure 4.3.4e CCP4 Fluoridation – WTP outlet & Gregory Street Reservoir	17
Figure 4.3.5a CCP 1 Abstraction – Turbidity at Raw water inlet	18
Figure 4.3.5b CCP 2 Filtration – Turbidity after filters	18
Figure 4.3.5c CCP3 Disinfection – Free Chlorine Stuarts Point Reservoir	18
Figure 4.3.6a CCP 1 Abstraction – Turbidity at Raw water inlet	19
Figure 4.3.6b CCP3 Disinfection – Free Chlorine Willawarrin Reservoir	19
Figure 4.6.7a CCP 1 Abstraction – Turbidity at Raw water inlet	20
Figure 4.6.7b CCP 2 Filtration – Turbidity after filters	20
Figure 4.6.7c CCP3 Disinfection – Free Chlorine Clear water tank outlet	21
Figure 4.6.7d CCP3 Disinfection – pH Clear water tank outlet	21
Figure 4.3.8a - CCP 1 Abstraction – Turbidity at Raw water inlet.....	22
Figure 4.3.8b - CCP3 Disinfection – Free Chlorine Thungutti Reservoir outlet.....	22
Figure 6 Total ADWG and WQI exception comparison; 2019-2020 and 2020-2021	27

1. Report Purpose

The *Public Health Act 2010* (NSW) requires that “a supplier of drinking water must establish, and adhere to, a quality assurance program that complies with the requirements prescribed by the regulations”.

The NSW Guidelines for Drinking Water Management Systems (NSW Ministry of Health 2013) provides guidance on the implementation of a Drinking Water Management System, in accordance with the *Public Health Act 2010* (NSW) and the *Public Health Regulation 2012* (NSW). These Guidelines are based on the Framework for Management of Drinking Water Quality, as outlined in the Australian Drinking Water Guidelines (ADWG) (NRMMC, NHMRC 2011).

This report provides a summary of Councils annual review of the performance of its water supply systems, for the 12-month period from 1 July 2020 to 30 June 2021.

It has been prepared to support; reporting (Element 10), evaluation (Element 11) and review and continual improvement (Element 12) requirements of the Councils DWMS.

This report includes the following areas:

- DWMS document review
- Supply summary and upgrades
- Performance of critical control points
- Reservoir inspection programs
- Water quality verification
- Water quality incidents or emergency
- Customer enquires
- Monitoring programs
- Staff development and training
- Continuous improvement - implementation plan (IP)

2. DWMS Document Review

The NSW Guidelines for DWMS require that all water suppliers review their DWMS and major components on an annual basis.

Councils DWMS Risk Management Team undertakes annual internal reviews on the following DWMS documents.

- Overall Manual
- Sub plans (8 separate supply systems)
- Water Quality Incident Response and Reporting plan
- Risk Register and
- Implementation Plan (IP).

Based on the review outcomes, identified components are actioned and documentation updated as required.

External reviews of Councils DWMS occur on a five (5) year basis or when deemed necessary by Council and/or NSW Health. VIRIDIS Consultants facilitated an external review in May 2018; this was finalized in June 2019 and adopted by Council in August 2019.

Table 2.1 details internal review performed by Council during 2020-2021.

Table 2.1 DWMS Document Revision History

Document	Version & Date	Updates	Submitted to NSW Health and date submitted ?
Overall Manual	4.4 24 June 21	Contact list, Stakeholder organisational names (DoI to DPIE), Spelling change of Thungutti to Thungutti added to map overview. WaterOutlook as data storage management system, TEAMS (Microsoft) used document storage	Yes, to NCPHU on 14 July 2021
Incident Response and Reporting Plan	1.1 24 June 21	Contact List, position names, DoI to DPIE	Yes, to NCPHU on 14 July 2021
Subplans & CCP Procedures		Note: Updates to Tables 3 and CCPs will commence at the start of the 2021-2022 reporting period	
Kempspey and Lower Macleay	1.1 24 June 21	Table 3, CCPs SOPs, DoI to DPIE, position names, data storage change from F:Drive to WaterOutlook	
Crescent Head	1.1 24 June 21	Figure 1, Table 3, CCPs SOPs, DoI to DPIE, position names, data storage change from F:Drive to WaterOutlook	
Hat Head	1.1 24 June 21	Figure 1, Table 3, CCPs SOPs and adjustment of CCP1 location, DoI to DPIE, position names, data storage change from F:Drive to WaterOutlook	Yes, to NCPHU on 14 July 2021
South West Rocks	1.1 24 June 21	Figure 1, Table 3, CCPs SOPs, DoI to DPIE, position names, data storage change from F:Drive to WaterOutlook	
Stuarts Point	1.1 24 June 21	Figure 1, Table 3, CCPs SOPs, DoI to DPIE, position names, data storage change from F:Drive to WaterOutlook	
Willawarrin	1.1 24 June 21	Figure 1, Table 3, CCPs SOPs and inclusion of pH correction at CCP3, DoI to DPIE, position names, data storage change from F:Drive to WaterOutlook	
Bellbrook	1.1 24 June 21	Figure 1, Table 3, CCPs SOPs, DoI to DPIE, position names, data storage change from F:Drive to WaterOutlook	
Thungutti	1.1 24 June 21	Figure 1, Table 3, CCPs SOPs and inclusion of pH correction at CCP3, DoI to DPIE, position names, data storage change from F:Drive to WaterOutlook	
Risk Assessment	2.6 18 Oct 21	Internal yearly review by Councils DWMS Risk Team and Coordinators for Water Maintenance and Water Operations. Minor review only, update of risks that had comments against them from desktop review before workshop meeting on the 18 October 2021	Yes, to NCPHU apart of the 2020 - 2021 Annual Report and Review meeting
Implementation Plan	8 29 Oct 21	Internal annual review by the DWMS Risk Team and Coordinators for Water Maintenance and Water Operations on the 18 th , 25 th and 28 th October 2021 Update of positions and group names. Added new Status category of "Standing Item", reformatted and defined status categories	Yes, to NCPHU apart of the 2020-2021 Annual Report and review meeting


3. Supply Summary and Upgrades

Kempsey Shire Council is located on the north coast of NSW, covering an area of 3,380 square kilometres, between the Pacific Ocean to the east, Five Day Creek in the west, Grassy Head to the north and Kundabung to the south.

Council manages eight (8) water supply systems, providing drinking water to:

- Kempsey - Lower Macleay (KLM), (includes the Lower Macleay towns and surrounding areas of Frederickton, Smithtown, Gladstone, Kinchela, and Jerseyville)
- Crescent Head
- Hat Head
- South West Rocks
- Stuarts Point
- Willawarrin
- Bellbrook
- and the Thunggutti Aboriginal Community

Figure 3.1 provides locality map of each of the Councils supply systems and Table 3.1 provides a summary of each of the water supply systems and any upgrades that have occurred during the reporting year.



Kempsey Shire Council Drinking Water Supply



Figure 3.1 Kempsey Shire Water Supplies

Table 3.1. Councils Drinking Water Supply Systems Summary

Supply System	Source Water	Treatment	Treatment Capacity	Population serviced	Towns & Communities supplied	System upgrades in 2020/21
Kempsey and Lower Macleay	Groundwater, Sherwood (from the Macleay River)	Gas chlorine for disinfection and lime dosing for pH correction.	20 ML/day	~20 461	Kempsey Frederickton Gladstone Smithtown Kinchela Jerseyville and surrounding rural regions as depicted on Figure 2.1 New Burnt Bridge and Greenhill Aboriginal Communities	No additional upgrades in either treatment train Additional Notes: Working on application for Section 60 Endorsement for Option assessment and procurement for preparation of Concept Design.
	Steuart McIntyre Dam (Emergency Supply) From Groundwater Sherwood	Aeration and Ultrasound for Algae Control, Chlorine (Sodium hypochlorite) dosing for disinfection.	38.1 ML/day			
Crescent Head	Groundwater, Maguires Crossing Hat Head National Park	Lime and CO2 dosing for increasing alkalinity and pH correction.	2.6 ML/day	~1500 permanent population	Crescent Head Loftus Road Aboriginal Community	No additional upgrades Additional Notes: Working on application for Section 60 endorsement options decommissioning of the temporary storage tank to facilitate construction of New WTP.
		Gas chlorination for disinfection.		~4500 holiday population		
Hat Head	Groundwater, Hat Head National Park	Aerator for iron removal, soda ash for pH correction and chlorine gas for disinfection.	2.6 ML/day	~350 permanent population ~2000 holiday population	Hat Head	No additional upgrades
South West Rocks	Groundwater, Hat Head National Park	Aeration, membrane filtration, lime for pH correction, chlorine (sodium hypochlorite) and fluoridation.	6 ML/day	~5700 permanent population ~15 000 holiday population	South West Rock Figtree Aboriginal Community	Membrane renewal and associated system modifications

Supply System	Source Water	Treatment	Treatment Capacity	Population serviced	Towns & Communities supplied	System upgrades in 2020/21
Stuarts Point	Groundwater	Ferric dosing for coagulation and Iron and arsenic removal, sand filtration and chlorine gas for disinfection.	2.7 ML/day	~1000 permanent population ~4000 holiday population	Stuarts Point Fishermans Reach Grassy Head	Reservoir relined apart of the reservoir renewal program
Willawarrin	Surface water from Macleay River (bore on edge of river for gravel bed extraction)	Chlorine (sodium hypochlorite) dosing. Soda ash for pH correction (new)	200 kL/day	~130	Willawarrin	pH correction facilities installed at treated water (disinfection) in June 2020 Additional notes: Ongoing planning of land acquisition for design and Construction of a new WTP.
Bellbrook	Surface water from Macleay River (bore within river for gravel bed extraction)	Multi-media filtration including arsenic removal, soda ash for pH correction and chlorine (sodium hypochlorite) dosing.	140 kL/day	~100	Bellbrook	Additional notes: Ongoing planning of WTP augmentation
Thunggutti	Surface water from creek (bore on edge of river for gravel bed extraction)	Chlorine (sodium hypochlorite) dosing. Soda ash for pH correction (new)	110 kL/day	~120	Thunggutti Aboriginal Community	pH correction facilities installed at treated water (disinfection) in June 2020

4. Critical Control Points

A Critical Control Point (CCP) is defined as an “*activity, procedure or process at which control can be applied, and which is essential to prevent a hazard or reduce it to an acceptable level*” (NSW Ministry of Health 2013). These may be processes such as selective abstraction of raw water, filtration, disinfection, or reservoir integrity. For each CCP, a parameter, such as chlorine residual, can be measured to verify the effectiveness of the process or identify when corrective action is required.

Operational Target, Alert Level and Critical Limits are determined for each CCP parameter to identify normal and out of normal operational conditions, where:

- **Operational Target** identifies the normal operational conditions,
- **Alert Level** indicates that the parameter is outside the normal conditions and corrective action may be required.
- **Critical Limit**, if exceeded, indicates that process control has been lost and safe water quality can no longer be guaranteed.

4.1 Data Collection and Monitoring

Monitoring of CCPs is undertaken throughout Councils eight (8) supply systems, as per the requirements of Councils Drinking Water Management System (DWMS). System specific CCP Standard Operating Procedures (SOP) Tables (Appendix A) have been established for:

- CCP1 - Abstraction from groundwater (Turbidity),
- CCP1 - Abstraction from Steuart Macintyre Dam – Emergency Supply (Turbidity along with Algae, Toxins, Taste and Odour)
- CCP2 - Filtration (Turbidity)
- CCP3 - Disinfection (Free Chlorine and pH)
- CCP4 - Fluoridation (South West Rocks at WTP and Gregory St Reservoir)
- CCP5 - Reservoirs (Reservoir Integrity)

Monitoring includes sample collection and analysis using laboratory and field instruments and real-time monitoring of online instrumentation for pre and post treated water via telemetry.

4.2 Non-Compliant Data

The CCP exceptions, either Alert Level or Critical Limit, are managed by the Water Operators by undertaking corrective actions following the CCP Standard Operating Procedures (SOP) Tables (Appendix A) and through communications with the Team Leader Water Process.

Water Operators enter operational monitoring results into Councils WaterOutlook data management system specific to each supply. If an entered result is outside of the targeted CCP operational range, WaterOutlook automatically records and notifies via email the Water Operators and Water Management team of the CCP exception (either Alert Level or Critical Limit). This email notification triggers the Water Operator to complete an “Incident Report” also within WaterOutlook.

WaterOutlook assigns the incident report an “Incident Batch Number” for future reference and sends out an email copy of the report to the Water Operators and the Water Management Team. The incident report provides a record of the reason for the exception, the corrective actions undertaken and whether any further actions are required to ensure this exception does not occur again.

WaterOutlook tabulates CCP exceptions for each supply into “Monthly Run Reports”, these reports are further tabulated within WaterOutlook to produce “Water Quality Special Reports”. The Water Quality Special Reports displays all monthly exceptions for each supply into a single table, tabulates a combined CCP monthly total and a running “year to date” (financial year) total. The CCP tables are used for reporting purpose to Council Management and to external stakeholders as required (Annual DWMS Water Quality report).

For reporting purposes Alert Levels and Critical Limits are recorded as a discrete number, i.e., once a CCP falls outside of the Alert Level range and is in the Critical Limit range it is recorded at a Critical Limit only and is not counted in the Alert Level totals.

4.3 Reporting

In 2020-2021 fifty-three (53) CCP exceptions were reported. A 51% reduction from the one-hundred and nine (109) exceptions from the previous report year.

Fifty-one (51) Alert Level exceptions and two (2) Critical Limit exceptions from seven-thousand, one hundred and sixty (7160) tests (Table 4.1).

Of Councils eight (8) water supply systems, six (6) systems experienced CCP exceptions.

CCP exceptions for the year are discussed for the supply systems in which they occurred in except for:

- CCP1 - Abstraction from Steuart Macintyre Dam (Algae, Toxins, Taste and Odour); when not in use the monitoring details are captured in Section 9 – Monitoring Programs
- CCP5 Reservoir inspections which is discussed in Section 5 – Reservoir Inspections

CCP supply discussions reference the details provided in Table 4.1 and individual supply system CCP monitoring data graphs.

CCP SOP tables for each supply system are provided in Appendix A.

Table 4.1 Summary of Critical Control Point exceptions 2020-2021 comparison to 2019-2020

Supply System	CCP Numbers	Control Point	Hazard	Control Parameter	2019-2020			2020- 2021			CCP reduced/Increased from previous year			
					Alert Level	Critical Limit	Total No samples	Alert Level	Critical Limit	Total No samples	Alert Level	Critical Limit	Combined Total	
Kempsey and Lower Macleay	KLM CCP1	Raw Water Abstraction (Bores)	All Pathogens	Turbidity	0	0	220	0	0	335	-	-	-	
	KLM CCP1*	Raw Water Abstraction (SMD)	All Pathogens	Turbidity	4	0	335	Supply not in use			-4	-	-4	
	KLM CCP1*	Raw Water Abstraction (SMD)	Toxins	Algae	Biovolume	5	2	48	Supply not in use			-5	-2	-7
				Taste & Odour	MIB	6	N/A	48	-6	-	-6			
				Geosmin	4	N/A	48	-4	-	-4				
	KLM CCP3**	Disinfection (SMD)	Chlorine sensitive pathogens	Free Chlorine	pH	0	0	680	Supply not in use			-	-	-
				Chemicals	pH	16	0	680	-16	-	-16			
	KLM CCP3**	Disinfection (Bores)	Chlorine sensitive pathogens	Free Chlorine	pH	0	0	8	0	0	359	-	-	-
Chemicals				pH	0	0	8	13	0	359	-	-	-	
KLM Combined Total					35	2	1979	13	0	1053	-22	-2	-24	
KLM CCP % to number of Samples					1.8%	0.1%	1.9%	1.2%	0%	1.2%				
Crescent Head	CH CCP1	Raw water Abstraction	All Pathogens	Turbidity	16	0	326	9	0	335	-7	-	-7	
	CH CCP3	Disinfection	Chlorine sensitive pathogens	Free Chlorine	3	0	347	1	0	360	-2	-	-2	
				Chemicals	pH	22	0	347	9	0	359	-13	-	-13
	CH Combined Total					41	0	1020	19	0	1060	-22	-	-22
CH CCP % to number of Samples					4.0%	0%	4.0%	1.8%	0%	1.8%				

Supply System	CCP Numbers	Control Point	Hazard	Control Parameter	2019-2020			2020- 2021			CCP reduced/Increased from previous year			
					Alert Level	Critical Limit	Total No samples	Alert Level	Critical Limit	Total No samples	Alert Level	Critical Limit	Combined Total	
Hat Head	HH CCP1	Raw Water Abstraction	All Pathogens	Turbidity	0	0	202	0	0	217	-	-	-	
	HH CCP3	Disinfection	Chlorine sensitive pathogens	Free Chlorine	0	0	228	0	0	230	-	-	-	
				pH	7	0	228	1	0	230	-6	-	-6	
	HH Combined Total					7	0	658	1	0	677	-6	-	-6
	HH CCP % to number of Samples					1.1%	0%	1.1%	0.1%	0%	0.1%			
South West Rocks	SWR CCP1	Raw Water Abstraction	All Pathogens	Turbidity	0	0	333	0	0	321	-	-	-	
	SWR CCP2	Filtration	All Pathogens	Turbidity	0	0	327	0	0	322	-	-	-	
	SWR CCP3	Disinfection	Chlorine sensitive pathogens	Free Chlorine	0	0	309	0	0	356	-	-	-	
				pH	0	0	309	0	0	356	-	-	-	
	SWR CCP4	Fluoridation Leaving WTP Gregory St Outlet	Chemical	Fluoride	0	0	288	0	0	347	-	-	-	
					0	0	300	0	0	352	-	-	-	
	SWR Combined Total					0	0	1856	0	0	2054	-	-	-
SWR CCP % to number of Samples					0%	0%	0%	0%	0%	0%				
Stuarts Point	SP CCP1	Raw Water Abstraction	All Pathogens	Turbidity	0	0	211	0	0	180	-	-	-	
	SP CCP2	Filtration	All Pathogens	Turbidity	0	0	238	0	0	215	-	-	-	
	SP CCP3	Disinfection	Chlorine Sensitive pathogens	Free Chlorine	0	0	220	0	0	247	-	-	-	
	SP Combined Total					0	0	669	0	0	642	-	-	-
	SP CCP % to number of Samples					0%	0%	0%	0%	0%	0%			

Supply System	CCP Numbers	Control Point	Hazard	Control Parameter	2019-2020			2020- 2021			CCP reduced/Increased from previous year		
					Alert Level	Critical Limit	Total No samples	Alert Level	Critical Limit	Total No samples	Alert Level	Critical Limit	Combined Total
Willawarrin	WW CCP1	Raw Water Abstraction	All Pathogens	Turbidity	2	0	56	1	1	195	-1	+1	0
	WW CCP2	Disinfection	Chlorine sensitive pathogens	Free Chlorine	0	0	125	2	0	356	+2	-	+2
	WW Combined Total				2	0	181	3	1	551	+1	+1	+2
	WW % to number of Samples				1.1%	0%	1.1%	0.5%	0.2%	0.7%			
Bellbrook	BB CCP1	Raw Water Abstraction	All Pathogens	Turbidity	2	0	125	1	0	136	-1	-	-1
	BB CCP2	Filtration	All Pathogens	Turbidity	0	0	45	0	0	117	-	-	-
	BB CCP3	Disinfection	Chlorine Sensitive pathogens	Free Chlorine	4	0	138	5	1	216	-2	+1	-1
				pH	1	0	138	0	0	216	+1	-	+1
	BB Combined Total				7	0	446	6	1	685	-1	+1	0
BB % to number of Samples				1.6%	0%	1.6%	0.9%	0.1%	1.0%				
Thunggutti	TH CCP1	Raw Water Abstraction	All Pathogens	Turbidity	1	3	149	1	0	196	-	-3	-3
	TH CCP2	Disinfection	Chlorine sensitive pathogens	Free Chlorine	11	0	227	8	0	242	-3	-	-3
	TH Combined Total				12	3	376	9	0	376	-3	-3	-6
	TH % to number of Samples				3.2%	0.8%	4.0%	2.1%	0%	2.1%			
All Supply Systems	Total Sum all Critical Control Points				104	5	7185	51	2	7160	-53	-3	-56
	% to number of Samples				1.4%	0.1%	1.5%	0.7%	0.0%	0.7%			

Note 1: Multiple exceptions occurring on the same day are recorded as discrete events at each CCP point as they occur. The Total Alert Level, Critical Limit and Combined Yearly Total is the sum of each discrete exception occurrence on any given day from each individual category.

Note 2: Once a CCP exceeds the Alert Level value it is recorded at a Critical Limit only and is not counted in the Alert Level totals.

Note 3: * KLM CCP1 (SMD) –2019-2020 in use for 358 days: 2020-2021 not used

Note 4: ** KLM CCP3 (Bores) - 2019-2020 in use for 8 days: 2020-2021 in use 365days

4.3.1 Kempsey - Lower Macleay (KLM) Supply System

Monitoring data for each of the Kempsey - Lower Macleay supply systems CCPs is shown in Figures 4.3.1a, 4.3.1b and 4.3.1c.




Figure 4.3.1a - CCP 1 Abstraction – Turbidity at combined raw water Lime Plant




Figure 4.3.1b CCP3 Disinfection – Free Chlorine at Greenhill Reservoir outlet




Figure 4.3.1c CCP3 Disinfection – pH at Greenhill Reservoir outlet

No Critical Limit exceptions occurred in the Kempsey - Lower Macleay supply during the 2020-2021 reporting year (Table 4.1 and Figures 4.3.1a, 4.3.1b and 4.3.1c). A reduction of two (2) events from 2019-2020.

Thirteen (13) Alert Level exceptions occurred from one-thousand and fifty-three (1053) samples; a reduction of twenty-two (22) from 2019-2020 (Table 4.1). All exceptions were at CCP3 pH and being a low Alert Level of <6.8 pH (Figure 4.3.1c). Contributing faults include:

- Lime blockages in delivery shute
- Broken agitator
- Float jammed in lime plant causing mixer to over flow
- Lime Plant Stator Pump Fault

Corrective actions involved:

- blockage cleared, checked all dosing equipment and screw feeder
- Acid clean lime plant and replaced dosing line
- Adjusted float in mixer
- Replacement of Pump Stator, clean and check Lime plant.

4.3.2 Crescent Head Supply System

Monitoring data for each of the Crescent Head supply systems CCPs is shown in Figures 4.3.2a, 4.3.2b and 4.3.2c.




Figure 4.3.2a - CCP 1 Abstraction – Turbidity at Front Dam




Figure 4.3.2b CCP3 Disinfection – Free Chlorine at Back Beach Reservoir outlet




Figure 4.3.2c CCP3 Disinfection – pH at Back Beach Reservoir outlet

No Critical Limits exceptions occurred in the Crescent Head supply in 2020-2021, (Table 4.1 and Figures 4.3.2a, 4.3.2b and 4.3.2c).

Nineteen (19) Alert Level exceptions occurred from one-thousand and sixty (1060) samples. These were reported across the following CCP locations (Table 4.1).

- CCP1 – Abstraction: Turbidity >4 NTU, nine (9) occurrences
- CCP3 – Disinfection
 - Free Chlorine >3 mg/L - one (1) occurrence
 - pH >8.0 - four (4) occurrences
 - pH <6.8 - five (5) occurrences

The nine (9) abstraction Turbidity Alert Levels all occurred in June 2021 (range between 4.07 to 4.90 NTU, Figure 4.3.2a); being a result of declining water quality within the borefield. Bore selection based on water quality testing and scouring of transfer line help to lower turbidity levels at the front dam.

The single Free Chlorine Alert (25/02/2021 – 3.2 mg/L; Figure 4.3.2b) was caused by daily fluctuations in demand due to rainfall. Adjustment to the dosing rate corrected the Free Chlorine concentration back within acceptable operating levels.

The nine pH Alert Levels (Figure 4.3.2c) included:

- Four (4) high Alert Level pH caused by low water levels in the reservoirs that impact lime dilution. The low water levels were caused by:
 - Power outages on 23/07/20. Once power was restored and water fill commenced, the system self-corrected with 24hrs
 - Increased water demand in holiday time drained reservoir faster. Reservoirs fill at off peak energy tariffs. The lime set points were pre-emptive adjusted (decreased) multiple times in the days leading up to the single Alert Level exception and on the day of the exception (7/10/20).
 - A main break in March 2021 caused a rapid water level decrease in the reservoir level; pH self-corrected two days after the main break.
- One (1) marginal (6.79 pH) low pH Alert Level in April 2021 (Figure 4.3.2c). No action was taken the system self-corrected with the following day with a result of 6.88 pH.
- Four (4) low pH Alert Levels in May 2021 from mechanical breakdowns of the pH dosing system; pH was self-corrected a few days after repairs completed.

Future proposed upgrades to the Crescent Head supply include the construction of a Water Treatment Plant for Crescent Head which is in the design and planning stage.

4.3.3 Hat Head Supply System

Monitoring data for each of the Hat Head supply systems CCPs is shown in Figures 4.3.3a, 4.3.3b and 4.3.3c.




Figure 4.3.3a - CCP 1 Abstraction – Turbidity at Raw water inlet




Figure 4.3.3b CCP3 Disinfection – Free Chlorine Clear water to retic




Figure 4.3.3c CCP3 Disinfection – pH Clear water to retic

No Critical Limit exceptions occurred in the Hat Head supply during the 2020-2021 reporting year (Table 4.1 and Figures 4.3.3a, 4.3.3b and 4.3.3c).

A single (1) Alert Level exception was recorded from six-hundred and seventy-seven (677) samples (Table 4.1). This is a reduction of six (6) from 2019-2020. The single Alert Level exception occurred at CCP3 Disinfection (pH) on the 6/04/2021. No action was taken, the system self-corrected, as shown in the trend line of Figure 4.3.3c.

4.3.4 South West Rocks Supply System

Monitoring data for each of the South West Rocks supply system CCPs is shown in Figures 4.3.4a, 4.3.4b, 4.3.4c, 4.3.4d and 4.3.4e.




Figure 4.3.4a - CCP 1 Abstraction – Turbidity at Raw water inlet




Figure 4.3.4b - CCP 2 Filtration – Turbidity after filters




Figure 4.3.4c CCP3 Disinfection – Free Chlorine Gregory Street Reservoir outlet




Figure 4.3.4d CCP3 Disinfection – pH Gregory Street Reservoir outlet




Figure 4.3.4e CCP4 Fluoridation – WTP outlet & Gregory Street Reservoir outlet

No Critical Limit or Alert Level exceptions occurred in the South West Rocks supply during the 2020 – 2021 reporting year (Table 4.1 and Figures 4.3.4a, 4.3.4b, 4.3.4c, 4.3.4d and 4.3.4e). This supply has not recorded any exceptions for the past two (2) reporting years.

4.3.5 Stuarts Point Supply System

Monitoring data for each of the Stuarts Point supply systems CCPs is shown in Figures 4.3.5a, 4.3.5b and 4.3.5c.




Figure 4.3.5a - CCP 1 Abstraction – Turbidity at Raw water inlet




Figure 4.3.5b - CCP 2 Filtration – Turbidity after filters




Figure 4.3.5c CCP3 Disinfection – Free Chlorine Gregory Street Reservoir outlet

No Critical Limit or Alert Level exceptions occurred in the Stuarts Point supply during the 2020-2021 reporting year (Table 4.1 and Figures 4.3.5a, 4.3.5b and 4.3.5c). This supply has not recorded any exceptions for the past three (3) reporting years.

4.3.6 Willawarrin Supply System

Monitoring data for each of the Willawarrin supply systems CCPs is shown in Figures 4.3.6a and 4.3.6b. Water carting to this supply from KLM occurred intermittently from 23/12/2020 to 11/01/2021 and 18/03/2021 to 13/04/2021 due in wet weather events that impacted source water.




Figure 4.3.6a - CCP 1 Abstraction – Turbidity at Raw water inlet




Figure 4.3.6b CCP3 Disinfection – Free Chlorine Willawarrin Reservoir outlet

A single CCP1 Abstraction Critical Limit exception occurred in the Willawarrin supply during the 2020-2021 reporting year (Table 4.1) on 29/10/2020; this is discussed in section 7 Water Quality Incident or Emergency.

Three (3) Alert Level CCP exception occurred from five-hundred and fifty (550) samples (Table 4.1 and Figures 4.3.6a and 4.3.6b) were reported across the following CCP locations:

- CCP1 – Abstraction: Turbidity >4 NTU, one (1) occurrence
- CCP3 – Disinfection: Free Chlorine <0.6 mg/L – two (2) occurrences

The three (3) Alert Levels (Figure 4.3.6a and 4.3.6b) include:

- One (1) CCP1 Abstraction Alert Level (1.48 mg/L) on 26/02/2021 caused by rainfall in the catchment increasing river turbidity. Pre-emptive actions included isolation of the bores and

- initiating water carting to the supply until rain ceased and turbidity levels returned to operational targets.
- Two (2) CCP3 disinfection Alert levels for low Free Chlorine:
 - 4/08/2020 Free Chlorine (0.42 mg/L) due to operator and SCADA alarms errors that ceased the production of chlorinated water to the reservoir that was identified on the 5/08/2020. Corrective actions included, resetting of set points both physically and in the telemetry control system and adding calcium chlorine pills to the reservoir to increase Free Chlorine residual. Preventative action includes operators to check the SCADA system at the end of every shift along with the SCADA alarms limits to be fixed with change access restriction applied.
 - 20/2/2021 Free Chlorine (0.51mg/L) due to the chlorine pump not dosing correctly. Corrective action includes the changing over to the spare pump and adding ½ a Calcium hypochlorite tablet to the reservoir to bring Free Chlorine residuals back to within operational target.

4.3.7 Bellbrook Supply System

Monitoring data for each of the Bellbrook supply system CCPs is shown in Figures 4.6.7a, 4.6.7b, 4.6.7c and 4.6.7d. Water carting to this supply from KLM occurred intermittently from 22/12/2020 to 7/01/2021 and from 21/3/2021 to 30/06/2021 due to wet weather and flood events that impacted source water quality.




Figure 4.6.7a - CCP 1 Abstraction – Turbidity at Raw water inlet




Figure 4.6.7b - CCP 2 Filtration – Turbidity after filters




Figure 4.6.7c - CCP3 Disinfection – Free Chlorine Clear water tank outlet




Figure 4.6.7d CCP3 Disinfection – pH Clear water tank outlet

One (1) CCP1 Abstraction Critical Limit exception and an associated Alert Level exception occurred in the Bellbrook supply on the 1/07/2020 (Table 4.1 and Figure 4.6.7c); this event is discussed in Section 7 Water Quality Incident or Emergency.

A further six (6) Alert level exceptions were reported from six-hundred and eighty-six (686) samples. These were reported across the following CCP locations:

- CCP1 – Abstraction: Turbidity >4 NTU, one (1) occurrence
- CCP3 – Disinfection: Free Chlorine <1.0 mg/L – five (5) occurrences

The single CCP1 Abstraction Alert Level on the 24/09/2020 (5.33) NTU; Figure 4.6.7a) was the result of rainfall in the catchment increasing river turbidity. SOPs were followed to ensure that no breakthrough in the filtration system entered the network. This water treatment plant (WTP) has automatic interlocks that shut the plant down if Turbidity levels reach the Critical Limit of 20 NTU.

The five (5) CCP3 Disinfection Alert Levels occurred intermittently throughout the year (Figure 4.6.7c) were caused by high manganese's levels that consumed free chlorine residuals. On each occasion Water Operators followed CCP SOP that included checking dosing equipment and confirming adequate disinfection throughout the network.

4.3.8 Thungutti Supply System

Monitoring data for the Thungutti supply system CCPs is shown in Figures 4.3.8a and 4.3.8b.




Figure 4.3.8a - CCP 1 Abstraction – Turbidity at Raw water inlet




Figure 4.3.8b - CCP3 Disinfection – Free Chlorine Thungutti Reservoir outlet

No Critical Limit exceptions occurred in the Thungutti supply during the 2020-2021 reporting year (Table 4.1 and Figures 4.3.8a and 4.3.8b). A reduction of three (3) events from 2019-2020.

Nine (9) Alert Level CCPs exceptions were reported from four-hundred and thirty-eight (438) samples (Table 4.1) These were reported across the following CCP locations.

- CCP1 – Abstraction: Turbidity >0.8 NTU, one (1) occurrence
- CCP3 – Disinfection: Free Chlorine <0.8 mg/L – eight (8) occurrences

The single CCP1 Abstraction Alert Level exception occurring on the 24/02/21 was due to rain in the catchment that saw turbidity levels increase and recover within 24hours (Figure 4.3.8a). This water treatment plant (WTP) has automatic interlocks that shut the plant down if Turbidity levels reach the Critical Limit of 20 NTU.

The eight (8) CCP3 Disinfection Free Chlorine exceptions were all in the second half of the reporting year (Figure 4.3.8b). Contributing factors include:

- Plant interlock isolated plant and was non-operational for two days due to increase Turbidity from rain
- No access to asset due to land slide over road - wet weather induced
- Air lock in dosing pump
- Modem drop outs, shutting plant down – wet weather induced
- Chlorine decay due to inconsistent batching intervals

Corrective actions involved:

- Manually boosting chlorine within reservoir by addition of calcium hypochlorite tablets
- Fresh batching and adjustment of chlorine dosing once access to plant restored
- Degas dosing pump, check dosing lines and check/adjust dosing settings
- Reset plant modem
- Consistent batch intervals

The Thungutti supply is a part of the NSW ACWSP overseen by DPI, water quality is reported on at the quarterly meetings; This program is further discussed in section 9.1 Aboriginal Communities Water and Sewer Program.

5. Reservoir Inspections

Council has fifteen (15) above ground storage reservoirs and manages two (2) reservoirs in the Thungutti supply as part of the NSW ACWSP. Maintaining Reservoir integrity is included as a CCP for each of Councils water supplies, as this is the last point of contact with the water where control can be affected prior to the network. Maintaining reservoir integrity is critical to a water supply system, to ensure that no contaminants, such as vermin, stormwater, or bird faeces, can freely access the treated stored water. Cleaning and inspection of the reservoirs is crucial to water supply ensuring that the water quality is not contaminated, or sediments are not disturbed.

5.1 Data Collection and Monitoring

Councils' reservoirs are inspected monthly by operational staff who complete the "Reservoir Inspection Check List" that is a function of the WaterOutlook program. Any reported issues trigger email notification to the Water Management Team. Tracking of completed inspections can be viewed in a generated "Reservoir Inspection" report which also provides a link to the physical report via individual report batch number. Any breach of integrity detected during Monthly Inspections would be reported as a CCP Critical Limit exception and be reported to the local PHU.

Reservoirs are also inspected by contractors on a three-year rotation, for cleaning and detailed internal and external integrity inspections. These findings are collated, reported, and tracked within the contractor's web database "ASAM RT".

5.2 Reporting

No breaches of integrity were detected during inhouse monthly CCP reservoir inspections.

Three (3) reservoirs (Clybucca, Willawarrin, and Bellbrook) have been clean and inspected by external contractors during this reporting period.

Twelve (12) reservoirs have been cleaned and inspected in the previous 24-month period and one (1) reservoir (Greenhill) has been inspected only as it is unable to be isolated for cleaning purposes.

Table 5.1 provides programmed schedule for Councils external contractors and inspection program.

Table 5.2 lists the findings from the previous and most recent inspections that still require rectification or items that were rectified in 2019-2020.

Table 5.1 Reservoir Schedule for external contractor inspections and cleaning

Reservoir	Report Year last inspected	Date Last Inspected/cleaned	Next Due Date Inspection/clean
Kempsey - Lower Macleay Supply			
Green Hill	2019-2020	12/02/2020	12/02/2023
John Lane	2019-2020	03/08/2019	03/08/2022
Potters Hill	2019-2020	03/08/2019	03/08/2022
Billy Goat Hill	2018-2019	26/10/2018	26/10/2021
Frederickton	2018-2019	26/10/2018	26/10/2021
Clybucca	2020-2021	17/02/2021	17/02/2024
Crescent Head Supply			
Back Beach	2018-2019	25/10/2018	25/10/2021
Big Nobby	2018-2019	15/11/2018	15/11/2021
Hat Head			
Reservoir 1	2018-2019	28/10/2018	28/10/2021
Reservoir 2	2019-2020	4/08/2019	04/08/2022
South West Rocks Supply			
Gregory Street	2018-2019	27/10/2018	29/10/2021
New Entrance	2018-2019	27/10/2018	27/10/2021
Stuarts Point Supply			
Stuarts Point Reservoir	2018-2019	22/07/2018	22/07/2021
Willawarrin Supply			
Willawarrin reservoir	2020-2021	16/02/2021	16/02/2024
Bellbrook Supply			
Bellbrook reservoir	2020-2021	17/02/2021	17/02/2024
Thungutti			
Reservoir 1	2018-2019	15/11/2018	15/11/2021
Reservoir 2	2018-2019	15/11/2018	15/11/2021

Table 5.2 Reservoir Inspection Report Summary

Date	Reservoirs	Findings	Corrective actions
12/05/2015	Crescent Head Big Nobby	A lot of the aluminium wire ventilation mesh is corroded and should be replaced when the fascia support sections are upgraded	Work delayed due to EME radiation hazard
06/08/2019		The existing level indicator system needs to be removed to seal the tank against vermin access	
13/05/2015	Stuarts Point	Corrosion present on the internal ladder.	In Progress – Internal Ladder to be replaced/repared in conjunction with in planned internal refurbishment expected completion in Sept 2021

Date	Reservoirs	Findings	Corrective actions
7/07/2017	Willawarrin	There is no secure compound around the tank.	In Progress - Planning occurring for a WTP at Willawarrin and the construction will include the construction of a secure compound for the WTP and Reservoir. Currently awaiting on land acquisition to build the plant.
12/02/2018	Greenhill	The two mechanical roof vents need to have mesh fitted to keep out birds and vermin	Work still to be completed
4/08/2019	Hat Head No2	There is corrosion present on the sketch plate area. This needs to be recoated ASAP to prevent further damage from occurring	Work still to be completed
5/08/2019	John Lane	There is significant corrosion appearing around the sketch plate area. The bitumen sealing material is packed too high and water is ponding and contributing to the deterioration	Work still to be completed
17/02/2021	Clybucca	Corrosion present on wall hatch fixings, hold down bolts, on roof fascia at 3 o'clock, and hand rails on the access stairs	New Items
16/2/2021	Willawarrin	<p>Calcification and minor seepage present in the concrete walls</p> <p>Top fill inlet is disturbing the floor sediments when the water levels are low, and fill is done by tankers</p> <p>Frog flap to be fitted at the end of the overflow pipe</p>	New Items

6. Water Quality Verification

The Australian Drinking Water Guidelines (ADWG) (NHMRC 2011) provide an authoritative reference that defines what is safe and good water quality and how this can be achieved and assured, using the latest and best available scientific evidence. The ADWG provide detailed information on the measurable characteristics of drinking water, including microbiological, physical and chemical aspects, and these are grouped into two different types:

- A **health guideline** value – that is the concentration or measure of a water quality characteristic that, based on present knowledge, does not result in any significant risk to the health of the consumer over a lifetime of consumption.
- An **aesthetic guideline** value – that is the concentration or measure of a water quality characteristic that is associated with acceptability of water to the consumer, such as, appearance, taste and odour.

Additional Water Quality Indicators (WQI) recommended by NSW Health include Total Coliforms and Free Chlorine residuals.

- A positive Total Coliforms result when used in operational monitoring, may indicate inadequate treatment, breakdowns in system integrity, or the presence of biofilms.
- Low Free Chlorine of <0.2mg/L is an indication that disinfection of the system may be compromised or lost.

Fluoride is monitored as per the Fluoridation Code (NSW Health 2018); an overdosing incident is the result of the fluoride concentration exceeding 1.5 mg/L in the treated water entering the network and operational exceptions is defined by any failure to maintain the fluoride concentration above 0.9 mg/L. The ADWG health limit is 5 mg/L.

6.1 Data Collection and Monitoring

Council participates in NSW Health's sponsored Drinking Water Monitoring Program; network monitoring is undertaken on a routine basis to ensure that Council's customers receive safe and acceptable water quality.

Council tests drinking water for thirty-two (32) health and aesthetic ADWG, and other recommended WQI characteristics. These samples are taken from twenty-five (25) sample sites within the Council's area of operation, all of which are post-treatment.

The water quality characteristics that are monitored as part of this program are specified by NSW Health. Council liaises with NSW Health regarding the total number of samples required for each supply system and the frequency of collection; a yearly sampling schedule is produced by Council to ensure the expected frequency of sampling is met.

Results are recorded in the NSW Drinking Water Database and reported against the ADWG and WQI. A summary of the water quality data for each supply system, obtained directly from the NSW Drinking Water Database is provided in Appendix C.

In addition to monitoring undertaken as part of NSW Health's Drinking Water Monitoring Program, Council also independently monitors water quality parameters as part of our daily operations (pre- and post-treatment at the water supply systems). Results are recorded within WaterOutlook for each individual supply.

6.2 Non-Compliant data

For the NSW Health sponsored monitoring, NSW Forensic & Analytical Science Services (FASS) Laboratory advises Council via email of any ADWG health and/or WQI guideline limit exceptions including positive results for microbiological tests (Total Coliforms and E. coli). Upon receiving email notification Council performs an internal investigation that involves confirmation of water quality at the exception location and from the supply reservoir, checking for potential sources of contamination i.e., breaks and repairs and if required a flush of mains. A resample is collected for confirmational laboratory analysis, and the local PHU is notified (initial phone and follow up emails).

The WaterOutlook application triggers an alert for anomalies found outside of the ADWG and WQI in relation to the daily operations monitoring. Water Operators complete a report within WaterOutlook (cause, action, preventive measures) with email notification sent to the Water Management Team. Monthly ADGW/WQI reports are produced within WaterOutlook that tabulates results into the system that they occurred providing a monthly total with a running “year to date” totals for each supply. External communication to the local PHU of daily results is limited to the Annual DWMS Water Quality report or if there is a gross and/or consistent exceedance.

6.3 Reporting

Seventy-eight (78) ADWG and WQI exceptions from both reporting platforms were recorded across Council’s water supply systems (Figure 6). This is a 63.9% decrease from the two-hundred and sixteen (216) exceptions recorded in the previous reporting year. The main contributing factors to the decline was the KLM supply change from the emergency supply of SMD back to supply via the Sherwood borefield along with the improved source water quality across each of the supply systems (excluding Willawarrin and Thunggutti) after the 2019-2020 drought broke.




Figure 6: Total ADWG and WQI exception comparison between 2019-2020 and 2020-2021 reporting years

The ADWG and WQI non-compliant results are discussed in the supply systems in which they occurred with reference to Figure 6, and Tables 6.1. and 6.2.

Table 6.1 ADWG and WQI non-compliances - NSW Health sponsored monitoring program

Supply Area	Parameter								Total
	Total Coliforms *	Free Chlorine **	pH	Turbidity	Fluoride ***	Iron	Manganese	Nickel	
	No detection (WQI)	< 0.2 mg/L (WQI)	< 6.5 - > 8.5 (A)	>5 NTU (H)	<0.9 - >1.2 mg/L (WQI)	≥ 0.3 mg/L (A)	≥ 0.1 mg/L (A) ≥ 0.3 mg/L (H)	≥ 0.02 mg/L (H)	
KS01 - Kempsey & Lower Macleay	3	0	0	0	N/A	0	0	1	4
KS05 - Crescent Head	0	3	0	0	N/A	0	0	0	3
KS08 - Hat Head	0	0	1	0	N/A	0	0	0	1
KS07 - South West Rocks	0	0	0	0	0	0	0	1	1
KS06 - Stuarts Point	0	0	0	0	N/A	0	0	0	0
KS04 - Willawarrin	0	0	5	0	N/A	0	0	1	6
KS03 - Bellbrook	0	0	0	0	N/A	0	0	0	0
KS09 - Thungutti	1	0	3	0	N/A	0	0	0	4
Combined Total	4	3	9	0	0	0	0	3	19

*Total Coliform no ADWG set however a positive result is an indicator for further investigation.

**Free Chlorine no minimum ADWG set however minimum level of 0.2 mg/L recommend for maintaining disinfection.

*** Fluoride levels based on Fluoride code; Health ADWG set at ≥5 mg/L

A – Aesthetic ADWG

H - Health ADWG

WQI – No ADWG available, guidelines are based on best practice or codes of practice

Table 6.2 ADWG and WQI non-compliances - Operational monitoring program

Parameter	Chlorine (Free) *	Chlorine (Total)	pH	Turbidity	Fluoride **	Iron	Manganese ***	Totals
Guidelines	< 0.2 mg/L (WQI)	≥ 5 mg/L (H)	< 6.5 - > 8.5 (A)	≥5 NTU (H)	<0.9 - >1.2 mg/L (WQI)	≥ 0.3 mg/L (A)	≥ 0.1 mg/L (A) ≥ 0.3 mg/L (H)	
Kempsey and Lower Macleay								
Number of Exceedances	0	0	0	0	N/A	0	0	0
Number of Tests	2193	2523	2190	2518	N/A	0	0	9424
Rate of Exceedances	0%	0%	0%	0%	N/A	0%	0%	0%
Crescent Head								
Number of Exceedances	0	0	0	0	N/A	0	0	0
Number of Tests	635	997	634	990	N/A	15	8	3279
Rate of Exceedances	0%	0%	0%	0%	N/A	0%	0%	0%
Hat Head								
Number of Exceedances	0	0	0	0	N/A	0	0	0
Number of Tests	163	393	162	377	N/A	24	11	1130
Rate of Exceedances	0%	0%	0%	0%	N/A	0%	0%	0%
South West Rocks								
Number of Exceedances	0	0	0	0	0	0	0	0
Number of Tests	567	923	566	913	77	9	10	3065
Rate of Exceedances	0%	0%	0%	0%	0%	0%	0%	0%

Parameter	Chlorine (Free) *	Chlorine (Total)	pH	Turbidity	Fluoride **	Iron	Manganese ***	Totals
Guidelines	< 0.2 mg/L (WQI)	≥ 5 mg/L (H)	< 6.5 – > 8.5 (A)	≥ 5 NTU (H)	< 0.9 - > 1.2 mg/L (WQI)	≥ 0.3 mg/L (A)	≥ 0.1 mg/L (A) ≥ 0.3 mg/L (H)	
Stuarts Point								
Number of Exceedances	0	0	0	0	N/A	0	0	0
Number of Tests	380	627	627	562	N/A	18	17	2231
Rate of Exceedances	0%	0%	0%	0%	N/A	0%	0%	0%
Willawarrin								
Number of Exceedances	0	0	33	0	N/A	0	4	37
Number of Tests	121	477	116	442	N/A	9	15	1214
Rate of Exceedances	0%	0%	28.45%	0%	N/A	0%	26.67%	3.05%
Bellbrook								
Number of Exceedances	0	0	0	0	N/A	0	0	0
Number of Tests	338	337	338	337	N/A	0	0	1350
Rate of Exceedances	0%	0%	0%	0%	N/A	0%	0%	0%
Thungutti								
Number of Exceedances	0	0	22	0	N/A	0	0	22
Number of Tests	102	2343	99	342	N/A	4	4	894
Rate of Exceedances	0%	0%	22.22%	0%	N/A	0%	0%	2.46%
Totals								
Number of Exceedances	0	0	55	0	0	0	4	59
Number of Tests	4499	6620	4732	6515	77	79	65	22587
Rate of Exceedances	0%	0%	1.16%	0%	0%	0%	6.15%	0.26%

*Free Chlorine no minimum ADWG set however minimum level of 0.2 mg/L recommend for maintaining disinfection.

**Fluoride levels based on Fluoride code; Health ADWG set at ≥ 5 mg/L

*** Manganese Aesthetic ADWG reported only (No Health ADWG recorded)

A – Aesthetic ADWG

H - Health ADWG

WQI –Guidelines are based on Codes of Practice or recommendations from NSW Health

6.3.1 Kempsey - Lower Macleay (KLM) Supply System

The KLM supply had a four (4) ADWG and WQI exceptions; all reported from the NSW Health Sponsored monitoring program (Table 6.1). This is a reduction of one-hundred and eighty (180) from the previous reporting year. This significant decline is due from the breaking of the 2019-2020 drought where Council changed the source water supply in June 2020 back to the Sherwood borefield from the SMD emergency supply.

Exceptions during 2020-2021 are reported as: (Table 6.1 and Appendix C; Table C.1)

- One (1) Nickel ADWG health ≥ 0.02 mg/L
 - 21-07-2020 at KS01-348 Setters Way, result of 0.0302 mg/L
- Three (3) Total Coliforms WQI
 - 23-02-2021 at KS01-129 Mahogany Crescent, result of 1 mpn/100mL
 - 2-03-2021 at KS01-798 Edgar Street, result of 1 mpn/100mL
 - 11-05-2021 at KS01-127 Euroka Zone, result of 1 mpn/100mL

Resampling for Nickel was performed on 04/08/2020 (result of 0.0004 mg/L) this is below the ADWG health limit of 0.02mg/L. Since 2018 Council has had re-occurring Nickel results above the ADWG

from across multiple supply systems. For each re-sample, the results have returned below the ADWG. Ongoing investigations of eliminating potential sources of nickel when sampling in the network has included:

- Checking of sample site fittings are non-nickel base coated
- Sampling raw water in the KLM of Nickel levels (KLM supply has had the most re-occurring events with results above the ADWG, including when water carting to other supplies (Willawarrin)
- Eliminating repair works of pipes as a possible source of contamination – cross compared work orders location against sample locations when exceptions been recorded
- Plans to replace detachable goose neck sampling taps with fixed brass taps

For each Total Coliform exception, Council followed SOP as described in 6.2 Non-Compliant data. All resample results returned <1 mpn mg/L for both E. coli and Total Coliform; no further action was warranted for each event.

6.3.2 Crescent Head Supply System

No bacteriological (Total Coliforms or E.coli) exceptions were reported (Table 6.1 and Appendix C: Table C.2); in the Crescent Head supply during 2020-2021.

The supply recorded three (3) WQI exceptions; a reduction of four (4) from the previous year (Figure 6). The improved outcomes are due to the re-commencement of the flushing and scouring program of the Loftus Road water main after lifting drought-imposed water restrictions in March/April 2020.

All three (3) exceptions were for the WQI of low Free Chlorine <0.2mg/L, at KS05-321 Loftus Road and reported in the NSW Health Monitoring program (Table 6.1). Breakdown is:

- 28-07-2020 - result of 0.04mg/L
- 08-09-2020 – result of 0.01mg/L
- 29-09-2020 – result of 0.04mg/L

Corrective actions for low Free Chlorine residuals include:

- additional flushing of affected mains and monitoring the network downstream of the supply reservoir.
- checking of dosing equipment
- testing reservoir outlets

6.3.3 Hat Head Supply System

No bacteriological (Total Coliforms or E.coli) exceptions were reported (Table 6.1 and Appendix C: Table C.3); in the Hat Head supply during 2020-2021.

A single (>8.50 pH) ADWG aesthetic exception of 8.71 pH was reported in the NSW Health Monitoring program at KS08-123 Fish Tables on the 1/06/2020 (Table 6.1). This site is located at the end of the reticulation and has reduced usage during winter. With no hydrant nearby, flushing is performed through the sample taps only.

6.3.4 South West Rocks Supply System

No bacteriological (Total Coliforms or E. coli) exceptions were reported in the South West Rocks supply in 2020-2021 (Table 6.1 and Appendix C: Table C.4).

One (1) ADWG exception occurred in 2020-2021, a reduction of seven (7) from the previous reporting year (Figure 6).

The single exception was reported from the NSW Health monitoring program (Table 6.1) for a Nickel ADWG health detection (≥ 0.02 mg/L) at KS07-121 Primary School on the 01/09/2020; a result of 0.0227 mg/L. A re-sample was collected on the 15/09/2020 albeit at site KS07-126 Little Bay; results returned as < 0.0004 mg/L.

Investigations into re-occurring Nickel events are ongoing as per details outlined in 6.3.1 Kempsey - Lower Macleay Supply.

6.3.5 Stuarts Point Supply System

No ADWG or WQI exceptions were recorded in the Stuarts Point supply, a reduction of two (2) events from the previous reporting year (Figure 6).

6.3.6 Willawarrin Supply System

No bacteriological (Total Coliforms or E. coli) exceptions were reported in the Willawarrin supply during 2020-2021 (Table 6.1 and Appendix C: Table C.6).

The Willawarrin supply had forty-three (43) ADWG and WQI exceptions during 2020-2021 an increase of twenty-nine (29) from the fourteen (14) exceptions reported in 2019-2020 (Figure 6). This increase however remains comparative low to the one-hundred and five (105) exceptions during 2018-2019 (Kempsey Shire Council 2018-2019).

The two main contributing factors for the increase include

1. Increase in the number of days the supply was from its local source water (during 2019-2020 the supply was under water carting for 240 days).
2. Shift in source water acidity after a wet weather event December 2020. Average raw water six months pre wet weather event was 6.96 pH, average pH six months post wet weather event 6.26 pH.

Exceptions during 2020-2021 are reported as (Figure 6, Tables 6.1 and 6.2 and Appendix C; Table C.6):

- Thirty-eight (38) pH ADWG aesthetic < 6.5 pH. Five (5) from the NSW Health monitoring program (Table 6.1) and thirty-eight (38) from operational monitoring (Table 6.2). With a minimum of 6.11 pH and maximum of 6.49 pH spread across all of the systems reticulation monitoring sites
 - KS04-121 Football Grounds
 - Ks04-122 St Thomas Church
 - KS04-123 Willawarrin School

All exceptions occurred from 22/01/2021 after the catchment had received significant rainfall that shifted the source water to a naturally lower acidity; pH correction was added to the system in early June 2021. No pH exceptions were reported after 7/06/2021.

- Four (4) Manganese ADWG aesthetic ($> 0.1 - < 0.5$ mg/L) exceptions were recorded from operational monitoring at the Reservoir outlet between 20/11/2020 to 14/12/2021 (0.18mg/L, 0.193 mg/L, 0.2mg/L and 0.159 mg/L respectively). Future WTP upgrades are to include filtration options for Manganese and Iron removal.

A single Nickel ADWG health (≥ 0.02 mg/L) (Table 6.1 and Appendix C; Table C.6) occurred on the 16/03/2021 at KS04-123 Willawarrin School; result of 0.0204 mg/L. Resampling was performed on the 30/03/2021 returning a result of 0.0005 mg/L. Investigations into re-occurring Nickel events are ongoing as per details outlined in 6.3.1 Kempsey - Lower Macleay Supply.

6.3.7 Bellbrook Supply System

No ADWG or WQI exceptions were recorded in the Bellbrook supply for the past two (2) reporting years (Figure 6).

6.3.8 Thunggutti Supply System

The Thunggutti supply had twenty-six (26) ADWG and WQI exceptions during 2020-2021 an 100% increase from the previous year (Figure 6).

Similarly, to the Willawarrin supply, the Thunggutti supply had increasing acidity in the source water of Nulla Nulla creek that lowered pH to below the ADWG.

Twenty-five (25) of the twenty-six (26) detections recorded were for low pH (< 6.5 pH); A single Total Coliform exception was additionally recorded (Figure 6, Tables 6.1 and 6.2 and Appendix C: Table C.8).

Like in the Willawarrin supply all pH exceptions were recorded from January 2021 after significant rainfall in the catchment. Sites monitored include the WTP Service line and KS09-121 Community Centre. The minimum result was 6.31 pH. In early June 2021 pH correction facilities were installed at Thunggutti.

The single Total Coliform detection of 1 mpn/100mL occurred on the 25/02/2021 at KS09-121 Community Centre. A re-sample was collected on the 31/05/2021 returning a result of < 1 mpn/100mL. Council followed SOP as described in 6.2 Non-Compliant data.

The Thunggutti supply is a part of the ACWSP overseen by DPI, water quality is reported on at the quarterly meetings; This program is further discussed in section 9.2 Aboriginal Communities Water and Sewer Program.

7. Water Quality Incident or Emergency

A water quality incident or emergency is an event where a controlled response is required to ensure that Council continues to protect public health. Although preventative strategies, such as CCP SOP have been developed by Council, some events cannot be anticipated or controlled.

These events need a managed response to ensure the incident is responded to adequately, investigated following the event, and preventative actions are implemented to reduce the risk of the event re-occurring.

Council had two (2) recorded Critical Limits in two (2) separate incidents for this reporting period, these are summarised in Table 7.1.

Table 7.1 Water Quality Incident or Emergency Summary

Details of incident/emergency	Actions and Preventive actions undertaken	Investigation & recommendations
<p>July 2020 – Bellbrook Supply Adjustment on chlorine levels (increase) to combat high manganese levels combined with low water level in Clear Water Tank / increased concentration of chlorine due to lack of dilution potential. CCP SOP were followed and confirmed that no impacts on supply water were observed.</p> <p>Two (2) Alert Limits and one (1) Critical Limit for Free Chlorine was recorded during this incident at CCP3 Clear Water Tank outlet. 30/06/2020 Alert Level 3.7 mg/L 1/07/2020 Critical Limit 4.1 mg/L 2/07/2020 - CCP3 Alert Level 4.0 mg/L 3/7/2020 – CCP3 Target 2.03 mg/L</p> <p>Additional Background information Plant has been offline from 13/01/2020 to 18/06/2020; with water being carted from the KLM supply due to persistent high manganese levels in source water amplified by the drought event. Plant had been back in operation for 13 days before Critical Limit event. Fresh batch and stronger hypo used (from SMD) delivery on the Monday before the incident Persistent high Iron and Manganese into CWT, impacting analysers causing “trip outs” on low chlorine reads. Main break in system increased the call amount of water being drawn in the system Free Chlorine residuals dilute in larger body of the Reservoir before going to the customer</p>	<p>30/6/2020 ~10:38 - WQ test result – Free Chlorine 3.7 mg/L (Alert Level)</p> <p>~13:30 - Chlorine dosing pumps adjusted (turned down from 85% to 80%)</p> <p>1/07/2020 ~12:05 - WO contacted TL to inform them of likely hood of increased Free Chlorine from the CWT and Chlorine dosing pumps adjusted further (from 80% to 65% to reduce Free Chlorine residuals Analyser faults on Free Chlorine issues unable to automatically inhibit plant ~15:15 - WQ test result - Free Chlorine 4.1 mg/L (Critical Limit) ~16:00 - Critical Incident Report completed WO checked SCADA in the evening</p> <p>02/07/2020 ~07:00 – analyser trends checked Free Chlorine remains >4 mg/L ~07:10 – plant inhibited ~07:26 - Email from WO to Management team; update on WQ and planned actions ~8:30 – Drain and Clean of Clear Water Tank - Instrument tech fix analyser reader 10:18 - Phone notification to NSW Health 12: 57 - Follow up email to NSW Health</p> <p>03/07/2020 14:20 - WQ test result 2.03 mg/L (within operational target)</p>	<p>Automatic interlock shutoff to stop the transfer of water from the Clear Water tank to the Reservoir if Free Chlorine reaches the Critical Limit of >4 mg/L.</p> <p>Familiarity of CCP with updated DWMS</p> <p>Current DWMS CCP placed at Plant</p> <p>Lessons Learnt</p> <ol style="list-style-type: none"> 1. What we did well capturing information for investigation purposes 2. What we can improve on complete incident report at time of incident (Alert not completed on 30/06/2020 <p>knowledge base of CCPs and confirmation of a secondary testing</p> <p>remove email rules to stop alerts from going into inbox</p> <p>Instrument maintenance schedule/ regular checks/calibrations</p>
<p>October 2020 – Willawarrin Supply Upriver catchment area received rainfall in late October that increased turbidity in the Macleay River. The Willawarrin operational bore 1 had a rise in turbidity from 0.32 NTU 28/10/2020 to 3.12 NTU 29/10/2020. Resulting the CCP1 Critical Limit exceedance (limit of 2 NTU). The secondary bore was also tested returning an Alert Level result of 1.91 NTU.</p> <p>Additional Background information The plant had not run when the river became dirty; No water was transferred from borefield to the reservoir. Reservoir WQ results were - 1.24 NTU, 1mg/L Free Chlorine, 1.09mg/L Total Chlorine.</p>	<p>29/10/2020 The plant was shut down, and both bores tagged out and inhibited.</p> <p>Water Carting arrangement initiated with deliveries to the Willawarrin Reservoir from the KLM supply (Greenhill Reservoir) on 30/10/20, 31/10/20 and 2/11/20.</p> <p>2/11/2020 Flushing of bores commenced in the afternoon once when river cleared up</p> <p>3/11/2020 reservoir stated to be filled around 3 pm producing good quality water – result of 0.48 NTU.</p> <p>5/11/2020 Email sent to LPHU that included full incident report</p>	<p>Isolation of bores pre wet weather events</p> <p>Council is progressing with the Willawarrin plant upgrade project that includes filtration.</p> <p>Action 2.85 in the DWMS IP relates to the Upgrade the telemetry and SCADA system and online monitoring for all sites to improve operational monitoring capabilities and response times. This action is a rolling project with scheduled upgrades for each financial year.</p>

8. Customer Enquiries

Water quality and loss of service enquiries are received by Councils Customer Services Section. The enquires are entered and tracked via Councils front of house records management system, that includes automated notification to the responsible delegate for actioning within Councils Service Standards timeframes. Investigation findings and any resolving actions are documented against the service request.

Table 8.1 provides a summary of the customer enquiries for the KLM water supply and Table 8.2 provides a summary of the customer enquiries for Councils other seven (7) water supplies. Appendix D provides descriptors for each supply area within the KLM supply.

Table 8.1 Customer Enquires for the KLM Water Supply System

KLM Supply Areas	Dirty	Air or Cloudy	Taste & Odour	Illness	Loss of Supply	Other	Annual Total
Kempsey	1	0	0	0	0	0	1
West Kempsey	0	0	0	0	1	0	1
Aldavilla	0	0	0	0	2	0	2
Smithtown/Gladstone	0	0	0	0	1	0	1
Belmore River	1	0	0	0	0	0	1
Kinchela	0	0	0	0	0	0	0
Frederickton	1	1	0	0	5	0	7
South Kempsey	1	0	0	0	3	0	4
East Kempsey	3	0	0	0	0	0	3
KLM Total	7	1	0	0	12	0	20

Table 8.2 Customer Enquires for Councils Water Supply Systems excluding KLM

Supply System	Dirty	Air or Cloudy	Taste & Odour	Illness	Loss of Supply	Other	Annual Total
Crescent Head	1	0	0	0	0	0	1
Hat Head	2	0	0	0	0	0	2
South West Rocks	4	1	3	0	1	0	9
Stuarts Point	0	0	0	0	0	0	0
Willawarrin	2	0	0	0	0	0	2
Bellbrook	2	0	0	0	0	0	2
Thungutti	0	0	0	0	0	0	0
Combined Total	11	1	3	0	1	0	16

A combined total of thirty-six (36) (Tables 8.1 and 8.2) customer enquiries were recorded by Council for this reporting year; a decrease of 67.5% from the one-hundred and eleven (111) enquiries from 2019-2020. The majority of these were in the KLM supply with twenty (20) enquires received.

No customer enquiries were recorded in the Stuarts Point and Thungutti water supplies (Table 8.2).

The decrease in the number of customers enquiries is due to the KLM supply reverting to source water supply from the Sherwood Borefield instead of the SMD emergency supply in June 2020 after

the drought broke. Typically, supply from SMD sees an increased in customer enquiries for both dirty water and taste and odour due to the dams' algae loadings.

Loss of supply and dirty water accounted for the majority of the enquires (31) across all the supplies.

The main contributing elements to the received enquiries of loss of supply, dirty water and air or cloudy were from broken mains/pipes and programmed sewer asset renewal projects.

Standard corrective measures include:

- investigation on site
- liaising with customer for additional information
- asset repair/replacement where required
- flushing of mains for minimum of 15min or until water runs clear
- confirmation of onsite water quality testing (Chlorine residuals, pH and Turbidity)
- Where deemed necessary sample collection for laboratory analyses to assist in root cause diagnosis including processes of elimination.

In the South West Rocks supply three (3) taste and odour enquires where logged on the 23rd and 24th July 2020 of strong chlorine/bleach odour in the water. System investigations showed no increase in Chlorine residuals at the outlet of Gregory Street Reservoir with Free Chlorine levels of 1.16mg/L and 1.11 mg/L which are slightly less than the operating target of 1.2mg/L. Reticulation water quality results had Free Chlorine at 0.9mg/L. A flush of the system at the properties was performed. No other issues were reported.

9. Monitoring Programs

9.1 Stuart Macintyre Dam (SMD) Algae Monitoring Program

Algae, along with Methylisoborneol (MIB) & Geosmin (Taste and Odour), samples are collected by Council on a routine basis and form a CCP component when SMD is in use. This sampling program, designed in 2016 and updated in June 2019, considers local conditions, historic data and aligns with the Blue-Green Algae Alert Level Framework. Samples are sent to the Port Macquarie-Hastings Council Laboratory for analysis. Appendix B, Figures B.1 and B.2 depicts monitoring data from 2015 to the end of this reporting period for Cyanobacteria Biovolumes, Phytoplankton groupings, and taste and odour compounds.

9.2 Aboriginal Communities Water & Sewage Program

Five (5) discrete Aboriginal Communities are identified within the drinking water supply areas of Council. Council partnerships with DPI and NSW Health to deliver the NSW ACWSP for the following communities:

- Bellbrook (Thunggutti)
- Greenhill (West Kempsey)
- New Burnt Bridge (South Kempsey)
- Loftus Rd (Crescent Head)
- Fig Tree (South West Rocks)

9.2.1 Pesticide Testing

Pesticide monitoring from water supplies servicing discrete Aboriginal communities is funded by the ACWSP every five (5) years.

No pesticide testing was conducted in 2020-2021. Table 9.1 provides a summary of last conducted monitoring and when next schedule sampling is due for each community. Pesticide analysis testing includes:

- Acidic Herbicides – Method CET8B
- Glyphosate – Method CET17A
- Organochlorine & Organophosphorus by LCMSMS – Method CET43A
- Organochlorine, Organophosphorus & Synthetic Pyrethroid Pesticides by GCMSM – Method CET7D
- Triazines/Phenylurea & Carbamates – Methods CET19C

Table 9.1 Pesticide Monitoring at Aboriginal communities

Catchment	Location	Last Sampled	Comments	Scheduled Next
Thunggutti	Network	2017	No Pesticides Detected from 1 sample	2022
Crescent Head	Network (Loftus Rd)	2019	No Pesticides Detected from 1 sample	2024
South West Rocks	Network (Figtree)	Feb 2017 to Dec 2017	No Pesticides Detected from 12 samples	2022
KLM	Burnt Bridge or Greenhill	Dec 2017	No Pesticides Detected	2022

9.2.2 Inspections and Water Quality Testing to ADWG

Along with pesticide monitoring, the water supply and sewerage systems at the Aboriginal communities are inspected by DPI. Inspections includes a water quality testing component that checks the supplied water meets the required ADWG and WQI for the tested parameters.

The Thunggutti community is inspected quarterly, and the Fig Tree, New Burnt Bridge, Greenhill, and Crescent Head (Loftus Rd) communities are inspected yearly (Table 9.2). During this reporting year the inspection timetable was impacted due to resource pressures from ongoing COVID-19.

Table 9.2. DPE inspection Water Quality results

Community	Sample Location	Date Inspected	Turbidity (NTU)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	pH	Colour (pt/Co)
Fig Tree	SPS R8	16/06/2020	0.98	0.66	0.91	7.80	<1
New Burnt Bridge	SPS K26	16/06/2020	0.39	1.35	2.24	7.60	0
Greenhill	SPS K2	16/06/2020	1.0	0.02	0.14	8.38	0
Loftus Road	SPS C4	16/06/2020	0.38	0.2	3.7	8	<5
Thunggutti	Network	18/08/2020	0.35	1.46	1.62	6.55	0
		19/01/2021	0.64	0.88	0.97	6.64	0
		02/06/2021	0.21	1.22	1.38	6.5	0

Note: SPS K2 is at a dead-end in the reticulation and off a side line that does not service the Greenhill Aboriginal Community. A more suitable Water Quality testing location would be the NSW Health monitoring site of KS01-122 Armidale Rd.

10. Staff Training and Development

Training and development for Water Process personal are based on statutory requirements, position duties, operational needs, and industry best practices.

Minimum Certification requirements for Water Process Operators include:

- Certificate III in Water Industry Operations; Fluoridation certificate; Dam Safety Surveillance certificate and Control Liquefied Chlorine Gas Disinfection certification.

Additional identified training and development along with any recertification and/or verification of competencies (VOC) are conducted as required by either Registered Training providers or in house by subject matter experts.

Training and development are managed by Councils Human Resources department with records held within Councils Training Record Management System.

Council is committed in the training and development of a skilled work force and participates in State funded Traineeship programs for the Water Industry. Councils takes on between four (4) to six (6) Trainees each year to mentor and guide them through the attainment of their Certificate II and Certificate III in Water Industry Operations certification.

Training and development programs completed by the Water Process Team during 2020-2021 is captured in Table 10.1.

Table 10.1. Completed Staff Training and Development Summary

Training Details	Trainees	Water Process Operators	Management Team
Pollution Incident Response Management Plan (PIRMP) Yearly VOC	4	6	4
DWMS Water Quality Incident Response Yearly VOC	4	6	4
NSW Health Fluoride Plant Operator Certificate		3	
Asbestos Awareness		5	2
Chemical Awareness	4	6	4
Apply Fist Aid and Perform CPR		1	
Working at Heights	1		
Governance and Risk Management 101			1

11. Continuous Improvement – Implementation Plan

Councils Implementation Plan (IP) was developed as part of the DWMS to document the improvement actions identified during the detailed risk assessment of the drinking water supplies. The IP encompasses Element 12 of the DWMS and demonstrates Council's commitment to continual improvement of its water supply services from a quality and safety perspective.

Since completion of the DWMS in 2014, the IP has been reviewed yearly by the Risk Management Team in conjunction with the Risk Register. Table 11.1 provides an overview of the IP reviews with a summary of progress of the actions.

Any new actions that are identified in the Risk Register are added into the IP. As actions are completed their status is changed to “completed” and remain in the IP for one review cycle before being marked as “remove” and taken off the IP.

Table 11.1. Implementation Plan Review History

Review Date	Removed *	Completed	Standing Items**	In progress	Ongoing (long term action)	Not Started	Items Added	Total Ongoing
Nov 2014 & Jan 2015	4	7		49	Not Reported	111	23	171
Aug & Sept 2015	4	8		75	Not Reported	83	0	157
April 2016	N/A	N/A		N/A	N/A	N/A	16	173
March 2017	N/A	24		73	64	65	0	202
August 2018	14	54		51	27	28	0	106
Oct 2019	48	23		63	24	7	18	112
November 2020	19	20		68	23	6	12	109
October 2021	17	16	7	53	27	9	0	96

*Removed items are the number of items that have been completed in the previous year review. The figures from “Completed” and “Removed” may not match due to confirmation in the current review year that the task has been completed. If an item is deemed “not-completed” its status is changed back into “in progress”

** Standing Items is a new category added from local PHU 2019-2020 Annual review meeting actions. Standing items are a constant action in the IP that have no end date.

Table 11.2. Progress on actions based on risk ranking

Residual Risk	Removed	Completed	Standing Items	In progress	Ongoing (Long term actions)	Not Started	New	Tasks Remaining
Very High	2	3	0	4	4	1	0	9
High	5	3	4	25	8	3	0	40
Medium	7	8	0	13	9	3	0	25
Low	3	2	3	11	6	2	0	22
Total	17	20	9	53	27	9	0	96

Ninety-six (96) tasks remain outstanding; twenty (20) tasks were assessed as completed and seventeen (17) tasks removed from the IP (i.e., confirmed as completed from the previous year review) (Table 11.2).

Of the seventeen (17) removed tasks, seven (7) had a risk ranking of high or very high and of the sixteen (16) tasks assessed as completed; six (6) had a rating of high or very high.

Nine (9) very high risks tasks remain outstanding in the IP, this is a 25% reduction from the twelve (12) outstanding high-risk tasks from 2019-2020 annual review.

Table 11.3 provides a summary of the actions that have been completed during 2020-2021.

Table 11.4 provides a summary of actions confirmed as completed in 2019-2020 and removed in 2020-2021.

A summary of the remaining IP outstanding actions is included in Appendix E.

Table 11.3 Summary of Completed tasks in Implementation Plan

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Comments
2.26	Kem	M	Include the selection of off takes in to the SMD Operational Manual.	2012	31/10/2019 - When Dam is online the water off take level is to be captured in WaterOutLook - When KLM system is operation in WaterOutLook this action can be removed 23/12/2020 - Offtakes are to be added into to WaterOutlook WTL to check where in the program this should be added 25/10/2021 - gates in WaterOutlook for when SMD in use for recording what gate level is in use - action completed
2.37	Kem	L	Install online pH monitoring after treatment at the Sherwood Lime plant.	2012	4/11/2019 - on hold until confirmation of new plant at dam - if so will no longer be required 23/12/2020 - pH monitoring to be installed at Greenhill regardless of new plant at SMD, money has been allocated 18/10/2021 Inlet to GH res has Cl2 and pH online instruments install 2021
2.38	Kem	M	Item change to - Ensure that duty pump is available at Greenhill Res only, Alarms are already in place	2012	4/11/2019 - standby pumps do need to be installed , check that alarms are operational 3/02/2021 -critical to have standby pump installed for Greenhill, but Belgrave and JL can stay with one dosing pump - ME to action as a reactive job 18/10/21 - this action is being closed off - plant will not be utilised until new WTP in place. SMD is only a backup emergency supply
2.42	Kem/All	H	Back to base security alarm system required for all treatment facilities.	2012	4/11/2019 - BMS into SCADA investigation - scoping yet to begin 3-2-21 - Facility management is responsible for security alarming at all facility - in progress (SCADA alarming on Doors on all treatment facilities and dosing buildings) 25/10/2021 this action works in with and has been integrated into 7.06 and can be closed off
2.58	Kem	VH	Propose a water carting fill station installation at Clybucca to encourage turnover of reservoir.	2012	4/11/2019 - MWS working on grants - for water stations for one per scheme 3/2/2021 - this project is underway - Clybucca is not on the program, locations include Armidale Rd, Belmore River - Gladstone, Gregory - SWR, River St (moved to Armidale Road), South St (replaced), Stuarts point 18/10/21 all fill stations are in. In regard to, Clybucca WQ currently no issues and will also improve more with new WTP. Risk Team has discussed and confirmed that this action is not required. NB back in 2012 SMD was main supply this is no longer the case - it is an emergency supply only
3.98	BB	M	Current location of final turbidity analyser to be confirmed, and relocated if required to sample location, post filters and prior to pH correction.	Dec-14	21/11/2019 - This will be captured and actioned when the plant is upgraded 10/2/2021 - as 2019 notes 25/10/2021 - Confirmed on the 21/10/21 that analysers are correctly positioned - this action is completed

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Comments
4.04	KLM	M	Confirm that the HMI trends at SM Dam are available and establish a setup of downloading trend data regularly and recording, for historical purposes, until Clear SCADA is established at this site.	Dec-14	Clear SCADA established 21/11/2019 - this is set up however "ME" to confirm data capture is historized 5/2/21 -Trends are now in Clear SCADA and historized since 2016 - will be improved in the new SCADA standard 23/09/2021 - MC - confirming with Tristan on length of data historization. 25/10/2021 MC has confirmed that all tends have been historized into SCADA since 2017 upgrade - Action can be marked as "Completed"
4.18	All	M	Consider developing an SOP which is a risk-based approach to determining whether a Bacto sample is warranted following a mains break.	Dec-14	21/11/2019 - not started yet 18/2/21 - yet to be started 18/10/2022 - Risk Team discussion that Bacto is not suitable and that SOP in main repairs/flushing and use of flushing calculator is sufficient, along with insitu WQ testing onsite (NTU and CL2) to confirm water is within ADWG. Bacto results take over 24hours to obtain an interim result.
5.14	Th	H	Integrate SCADA onsite & Door alarms connected to SCADA	Apr-16	21/11/2019 - this will be incorporated with the roll out of upgrades across all sites 10/2/2021 - This action has been confirmed that it is captured in New Action No 7.06 for all supplies not just Thungutti
6.07	SWR	M	Regular Scour programme of delivery line into WTP from borefield	Nov-19	Develop scour programme - Some engineering controls need to be developed for capture of contaminated water EPA is happy with filter bag to stormwater 5/2/2021 - SWR & Crescent Head done yearly, other supplies are pended on budgets 18/10/2021 - this action is being closed as it is a duplicate of action item 2.76 which is a Standing item
6.13	SWR	M	Fluoride - Investigation of design limit so system cannot overdose and set at that level	Nov-19	TLW to confirm that you cannot overdose - once confirmed this action can be closed 18/2/21 - Still to be confirmed 25/10/2021 - Conversation with Risk Team, is that we have reduced the risk as much as possible. Manual dose is set to plant max flow. This action is completed
6.17	ALL	VH	Review optimal operating water levels to confirm accuracy (report recently undertaken) to be checked then remove task F:\UTILITIES\DRAFT New Water Services\WATER SUPPLIES\POTABLE WATER\RESERVOIRS	Nov-19	PE to confirm data and update if required 10/2/2021 - review of the spreadsheet required 21/05/21 Health Meeting - verified in real time by MWS this action can be closed off at next review 18/10/2021 - Confirmed to be closed off - MWS and risk team, info in spread sheet is correct

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Comments
6.19	All	H	Consider a notification through customer service/Facebook to customers that will experience loss of supply due to power outages at booster pump stations and consider emergency power generation role out plan	Nov-19	Collaboration between PE, ME and Comms group. Plan to be developed for emergency generator rollout across critical assets 5/2/21- generators are request as required & Comms group is notified if required. Outstanding action is the Investigation to continue for emergency generator rollout 25/10/2021 - Comms team is notified if there is a loss of service - this action in completed
7.04	SWR	M	- Update entry signage protocols - electronic key entry only - Check if Master key opens room (it should not) - Check key on double door access "	Nov-20	10/2/2021 -Electronic access has been completed - Dec2020 Fluoride Master Key with WTL WTL to confirm that all parts have been completed and then this action can be closed off 25/10/2021 - confirmed as competed
7.1	ALL	VH	Tender instrumentation services	Nov-20	10/2/2021 - In progress of writing tender plan for the preventative maintenance of all water instrumentation 23/09/2021 - Phil (MC) - this is done, and can now be closed - Completed
7.12	SP	L	Stuarts Point supply Automatic Shutdown interlocks on Turbidity at CCP2 post filtration	Feb-21	18/2/2021 - To be investigated 25/10/2021 - this action has been incorporated into above action 7.09

Table 11.4 Summary of removed tasks from Implementation Plan

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Comments
2.21	Kem	M	Consider undertaking a monthly monitoring program for indicator microbiological levels at take-off point of SMD	2012	Has been done, will be formalised 31/10/2019 - Check schedule and then close off once confirmed 23/12/2020 - micro sample taken weekly - action is completed 25/10/2021 - Confirmed as completed can be removed for IP
2.72	Kem	H	Alternative power to be installed for power outages on pressurised zones (Burnt Bridge, Bloomfield St & Everingham Lane) or investigate alternative water supplies (i.e. tank on tower).	2012	7/11/2019 - to be implemented need to check for power point for generator and/or permanent on site back up power supplier 5/2/21 - All sites converted for generator plug in the event of power outages 25/10/2021 - this action has been confirmed as completed and can be removed

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Comments
2.91	Kem	VH	KSC to establish a centralised water quality data base for the recording of operational and compliance monitoring, including response to WQ incidents and abnormal results. Field operators need online data entry facilities and automated notification for abnormal results. Implement a regime of regular review water quality results, including daily entry of data by operators and at least weekly review by TLW The data base is to have the ability to produce reports, trend graphs and alert notifications (including site events).	2012	Outlook water system is under development 7/11/2019 - WaterOutLook developed for the SWR system and will be rolled out across other systems from Nov 2019 18/2/21 - WaterOutlook has been rolled out for Water monitoring data - this action can be closed out 25/10/2021 - This has been confirmed at completed and can be removed "
3.14	All (bores)	H	SOP required around the monitoring and selection of best water quality bores	2014	10/2/21 - SOP not required. Bores selection is driven by water quality at each bore and conversions between WO and TLW when WQ begins to deteriorate - this action is to be closed off 25/10/2021 - Confirmed as completed can be removed for IP"
3.19	SWR, SP, BB	H	Develop an SOP for chlorine top-up dosing into clear water tanks		10/2/21 - This action/SOP is being incorporated into new action 7.05 slug dosing reservoirs SOP that includes confirmation of calculations by the Team Leader and/or Senior Water Operator - this action is being closed off 25/10/2021 - Confirmed as completed can be removed for IP
3.22	HH, SP, CH, SWR	L	Develop SOP for chlorine - managing increased water demand/supply during holiday periods	2014	10/2/2021 this is managed by daily operations checks and review of trends, chlorine is adjusted accordingly. SOP not required and this action is closed off 25/10/2021 - confirmed as completed - this action can be removed

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Comments
3.6	ALL	M	Develop a comprehensive public and media communications strategy and include draft public and media notifications and leverage, where possible, existing mechanisms by which council communicates with the community. Define communication protocols with the involvement of relevant agencies and include in the protocols a contact list of relevant agencies and businesses and their relevant key people and update contact details (also include in DWMS).	2014	Council to investigate and check if community strategic plan. Social media (FB) used currently. 19/11/2019 - No Update 10/2/2021 - Communication team has their own strategy in place to inform the community, Key contacts are in the DWMS contact list. This action is being closed off this action was developed before the new DWMS was implemented and DWMS has protocols for external contacts and when they are contacted 25/10/2021 - Confirmed as completed - can be removed
3.88	ALL	L	Develop internal audit procedures and schedules appropriate to functionality of council and the water supply systems. Identify appropriate personnel to undertake the internal audit and provide training in auditing.	2014	Undertaken informally, systems continuously audited, SOP for internal audit to be developed to ensure process is documented 21/11/2019 - Water Systems currently done informally Council has recently hired an Internal Auditor and systems at a higher level are currently being develop 10/02/2021 - Departmental audits are being completed and are soon to be captured in Councils new VAULT system for findings, actions and their outcomes Council internal reports are kept in Councils Share point system Council has a qualified internal auditor and departmental audits are carried out by staff who are SME. This action is considered to be completed and can be closed off 28/10/21 action has been confirmed as completed and can be removed
4.09	All	H	Council needs to ensure that a log is kept of all changes to SCADA limits and ensure that security controls are in place for changes to CCP levels. Council should also consider an approval process for making these process adjustments.	Dec-14	All changes logged automatically, including who changed it (the event page) 21/11/2019 - Need to double check that dosing set points affecting the CCPs are clamped and that alarms are reviewed 5/2/21 - the ongoing review of setpoints is incorporated into action No 3.76. All other parts of this action are completed as noted 25/10/2021 this action has been confirmed as completed and can be removed
4.1	All	L	Council currently only has one test kit for testing hypo strength, and this is located at the Dam. Council should consider purchasing another kit for the upriver sites.	Dec-14	Will be ordered, may be required for each plant that uses hypo 21/11/2019 -confirmation of purchase of additional kits required 10/2/2021 Kits have been purchased, kits are located at SMD and SWR. - this action is completed and can be closed off 25/10/2021 - this action is confirmed as completed and can be removed

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Comments
4.11	All	M	Council to contact Port Macquarie Lab to determine protocols for micro sampling on weekends if required during a CCP failure.	Dec-14	Protocol to be discussed, formalising process will be considered 21/11/2019 - Process in place with Port Lab. Need to develop SOP for confirmation of steps in the event of CCP failure and taking a non-routine micro sample on the weekend 10/2/2021 - this protocol is already captured in the DWMS - incident management plan. A SOP is not required. This action can be closed off 25/10/2021 - this action is confirmed as completed and can be removed
5.05	BB	M	Proper signage should be displayed in the chemical storage areas instead of marker pen written signage on the storage tanks and hazardous chemical signage should be improved	Apr-16	21/11/2019 - TLW & PE to conduct an audit of all signage to confirm all correct signage is in place 10/2/2021 - this action has been completed and can be closed off 18/10/21 - this action has been confirmed as completed and can be removed
6.03	SMD	H	Investigate options for Destratification (other than aeration)	Nov-19	Re-visit based on outcome of emergency treatment plant at SMD 10/2/2021 - Council is no longer in drought and emergency plant is now not being looked at - however Council is in concept stage at SMD new treatment plant where technologies will mitigate against destratification, and aeration needed - this action is no longer needed and can be closed off 18/10/2022 - Action confirmed to be completed and can be removed for IP
6.14	WW	M	When filling Willawarrin reservoir from a tanker, the tanker should have a spray nozzle diffuser attached/installed to reduce sediment stirring	Nov-19	18/2/21 - Spray Nozzle in Reservoir - completed can be removed next review 25/10/2021 action confirmed - can be removed
7	KLM	M	Inspections of aeration line - Create frequency plan of aeration line inspection by divers	Nov-20	PE - To incorporate into the reservoir cleaning plan 10/2/2021 - this action has been completed and can be closed off 18/10/21 - confirmed can be removed
7.06	ALL	M	add plant power generator sizes to the BCP plan for in the event of loss of power at treatment plants due to storm events or planned outages.	Nov-20	10/2/2021 - further investigation required 23/09/2021 - Phil (MC) - ongoing - MO following this up. (Same as action 4.14) duplicated actions - close off /remove

12. References

1. NSW Government (2010), *Public Health Act 2010*, NSW Government Parliamentary Counsel's Office.
2. NSW Ministry of Health (2013), *NSW Guidelines for Drinking Water Management Systems*, NSW Ministry of Health
3. NHMRC (2011) *Australian Drinking Water Guidelines*, National Water Quality Management Strategy, National Health and Medical Research Council, National Resource Management Ministerial Council, Commonwealth of Australia, Canberra.
4. AECOM (2014), *Kempsey Shire Council Drinking Water Management System* AECOM, Sydney NSW
5. Aqualift (2014), *Kempsey and Lower Macleay Drinking Water Supply Description*, Aqualift Project Delivery, 2014
6. Census 2016
http://www.censusdata.abs.gov.au/census_services/getproduct/census/2016/quickstat/LGA14350?opendocument
7. *Population Forecast for Kempsey Shire* - <http://forecast.id.com.au/kempsey/home>
8. NSW Government (2012), *Public Health Regulation 2012*, NSW Government Parliamentary Counsel's Office
9. NSW Health (2018) *New South Wales Code of Practice for Fluoridation of Public Water Supplies, Fluoridation of Public Water Supplies Act 1957*, NSW Health
10. Peter Anderson (2018) *Condition Report – Reservoirs*, Kempsey Shire Council (in Draft)
11. Water Directorate (2014), *Blue-Green Algae Management Protocols 2014*, Water Directorate, 2014
12. VIRIDIS (2019), *Drinking Water Management System - Overall Manual*, prepared for Kempsey Shire Council by Viridis Consultants Pty Ltd.
13. Kempsey Shire Council (2021), *DWMS Risk Register V.2.6*. Kempsey Shire Council
14. Kempsey Shire Council (2020) *DWMS Implementation Plan Update Review V.8*. Kempsey Shire Council
15. Kempsey Shire Council (2018-2019) *DWMS Annual Water Quality Report*. Kempsey Shire Council
16. Kempsey Shire Council (2019-2020) *DWMS Annual Water Quality Report*. Kempsey Shire Council
17. Kempsey Shire Council (2020) *Kempsey Shire Council Water Restriction Review 2019-2020*. Kempsey Shire Council
18. NSW Government (2020) *Kempsey LALC Aboriginal Communities Water Supply and Sewerage Systems Periodical Inspection*, Report and minutes, NSW Government, Department of Industry

Appendix A Summary of Critical Control Points (CCP) for each Supply System

Table A.1a CCP Kempsey and Lower Macleay Water Supply – Sherwood Lime Plant in use

System	CCP ID	Control Point	Indicator Parameter	Testing Location	Frequency	Target	Alert Level	Critical Limit	Justification for critical limit
Kempsey and Lower Macleay	Sherwood Lime Plant in use								
	CCP1	Raw Water Abstraction	Turbidity	Combined bore water to Sherwood Lime Plant	Continuous online	<1 NTU	1 NTU	2 NTU	There is no filtration undertaken, critical limit provides an interim barrier to control contaminant/ microbial load. Plant is shut off at critical limit.
	CCP2	Filtration	Turbidity	NA	NA	NA	NA	NA	NA
	CCP3	Disinfection	Free Chlorine pH	Outlet of Reservoir – Greenhill	Daily grab	1.2 mg/L pH 7.5	<0.9 mg/L or > 3 mg/L pH <6.8 or >8.0	<0.6 mg/L or >4 mg/L pH <6.5 or >8.5	Lower chlorine critical limit ensures that C.t is met at the monitoring location. Upper chlorine critical limit ensures that total chlorine does not get >5 mg/L (health limit). pH correction undertaken. Lower pH critical limit protects asset corrosion. Upper pH critical limit ensures efficiency of chlorination is not compromised (ADWG).
	CCP4	Fluoridation	Fluoride	NA	NA	NA	NA	NA	NA
CCP5	Reservoir	Reservoir integrity	All Reservoirs	Monthly	No breach of integrity	Any sign of integrity breach	Evidence of contamination	Ensures treated water does not get contaminated.	

Table A.1a.1 SOP for KLM CCP1 Turbidity at Raw Water Abstraction - Sherwood Lime Plant in use

Water Scheme	Kempsey and Lower Macleay – Sherwood Lime Plant in use		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Continuous online
Monitoring location	Sherwood Lime Plant (SLP) inlet pre disinfection		
What will initiate response?	Confirmation of result with immediate grab sample re-test		

Operating Target <1 NTU	Alert Level 1 NTU	Critical Limit 2 NTU
<ul style="list-style-type: none"> Observe weather and flood warnings Routine site and operational checks Instrument calibration and records maintained Monitor and measure raw water turbidity daily Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) Visual checks at Bore sites and Bore water monitoring program Individual Bore testing 	<p>Corrective actions</p> <p>General:</p> <ul style="list-style-type: none"> Confirm with immediate grab sample re-test Contact Team Leader Consider shutting SLP down Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample Check Recharge Channel for any water quality impacts such as flooding Check borefield for signs of damage to bore or any impacts to sites areas around bores Investigate operating bores in use at time of sampling to identify source of increased turbidity levels Check individual production Bores for turbidity & iron and isolate where required <u>Make arrangements</u> for isolation & repairs to problem bore Check readiness of alternate supply 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Shutdown the system Switch to alternate supply, if possible Check turbidity levels downstream to validate any infiltration to receiving reservoirs Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample.

Table A.1a.2 SOP for KLM CCP3 Free Chlorine and pH at Disinfection - Sherwood Lime Plant in use

Water Scheme	Kempsey and Lower Macleay - Sherwood Lime Plant in use		
CCP ID	CCP3		
What is the control point?	Disinfection and pH correction	What are the hazards?	Chlorine sensitive pathogens
What is being monitored?	Free chlorine residual & pH	Monitoring Frequency:	Daily grab (7 days)
Monitoring location	Reservoir(s) outlet: Greenhill		
What will initiate response?	Confirmation of result with immediate grab sample re-test		

Operating Target	Alert Limit	Critical Limit
Free chlorine 1.2 mg/L pH 7.5	Free chlorine <0.9 or >3 mg/L pH <6.8 or >8.0	Free chlorine <0.6 or >4 mg/L pH <6.5 or >8.5
<ul style="list-style-type: none"> • Routine site and operational checks at Dosing Plant • Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) • Chemical dosing rate checks • Disinfection residual checks performed at the outlet of Reservoir • Instrument calibration and records maintained • Chemical procurement and delivery requirements • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Regular inspection of the lime dosing system including cleaning of injection lines for change over • Flow meter checks • Redox probes within Reservoirs 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Confirm result with an immediate re-sample. • Validate disinfection levels (using high ranges or dilution methods if required) • Contact Team Leader • Check disinfection levels from primary dosing and adjust as required • Check raw water conditions • Check disinfection levels in Reservoir and manually dose if required (Refer Reservoir Manual Chlorine Dose Calculator) • Check integrity of Reservoir for any breaches or unauthorised access • Check primary dosing equipment (circulation pumps, injection point) • Consider scouring, flushing and sampling in the network where appropriate • Complete 'Initial Incident Report Form', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps • Test for total chlorine if free chlorine is >4 mg/L. Total chlorine should not be >5 mg/L. • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible. • Consider taking micro-sample for low disinfection levels • Process Engineer or Manager to call local PHU as soon as possible. • Contact DoI for operational advice as needed. • Implement additional response actions (e.g. boil water alert) in consultation with local PHU. • Complete 'Initial Incident Report Form', following confirmation of online result with grab sample.

Table A.1a.3 SOP for KLM CCP5 Reservoir Integrity - Sherwood Lime Plant in use

Water Scheme	Kempsey and Lower Macleay - Sherwood Lime Plant in use		
CCP ID	CCP5		
What is the control point?	Reservoir	What are the hazards?	All pathogens and all chemicals
What is being monitored?	Reservoir integrity	Monitoring Frequency:	Monthly
Monitoring location	All service reservoirs		
What will initiate response?	Any sign of reservoir integrity breach		

Operating Target No breach of integrity	Adjustment Limit Any sign of integrity breach	Critical Limit Evidence of contamination
<ul style="list-style-type: none"> Reservoir inspection program (routine) with records maintained Scheduled contractor reservoir cleaning and inspection program 	<p>Corrective actions</p> <ul style="list-style-type: none"> Conduct visual inspection (outside & inside) Check disinfection levels in Reservoir and top up if required (Refer to Reservoir Manual Chlorine Dose Calculator) Increase chlorine dose at plant, if needed Contact Team Leader Repair breach of integrity. Increase inspections until repaired Consider notifying local PHU Complete 'Initial Incident Report Form' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level corrective actions Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Take micro-sample if required Remove contaminants, if safe to do so Process Engineer or Manager to call local PHU as soon as possible. Contact Dol for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete 'Initial Incident Report Form'

Table A.1b CCP Kempsey and Lower Macleay Water Supply – SMD in use

System	CCP ID	Control Point	Indicator Parameter	Testing Location	Frequency	Target	Alert Level	Critical Limit	Justification for critical limit	
Kempsey and Lower Macleay	Steuart McIntyre Dam in use									
	CCP1	Raw Water Abstraction	Turbidity	Combined Bore Water to SM Dam Inlet Race	Continuous online / daily grab	<1 NTU	3 NTU	5 NTU	There is no filtration undertaken, critical limit provides an interim barrier to control contaminant/ microbial load into SM Dam.	
		Raw Water Abstraction	Turbidity	SM Dam outlet from an active transfer pump	Daily grab	<1 NTU	3 NTU	5 NTU	There is no filtration undertaken, critical limit provides an interim barrier to control contaminant/ microbial load. Plant is shut off at critical limit.	
		Raw Water Abstraction	Taste & Odour MIB / Geosmin Algae Biovolumes (Toxins)	SM Dam Tower and SM Dam sites 1, 2, & 3	As per Algae Monitoring Plan	Not detectable Not detectable Below Detection Limit	N/A >2 ug/L Alert Level 1	N/A N/A Alert Level 2	Algae Biovolume critical limit is based on the Water Directorate Alert Level Framework for management of cyanobacteria in drinking water. Taste and Odour along with MIB and Geosmin has no set critical limit, as these indicators in detectable levels are aesthetic in nature and not health related.	
	CCP2	Filtration	Turbidity	NA	NA	NA	NA	NA	NA	
	CCP3	Disinfection	Free Chlorine pH	Outlet of Reservoirs – Greenhill, John Lane, Potters Hill	Daily grab	1.8 mg/L pH 7.5	<1.0 mg/L or > 3 mg/L pH <6.8 or >8.0	<0.6 mg/L or >4 mg/L pH <6.5 or >8.5	Lower chlorine critical limit ensures that C.t is met at the monitoring location. Upper chlorine critical limit ensures that total chlorine does not get >5 mg/L (health limit). No pH correction readily available. Lower pH critical limit protects asset corrosion. Upper pH critical limit ensures efficiency of chlorination is not compromised (ADWG).	
	CCP4	Fluoridation	Fluoride	NA	NA	NA	NA	NA	NA	
	CCP5	Reservoir	Reservoir integrity	All Reservoirs	Monthly	No breach of integrity	Any sign of integrity breach	Evidence of contamination	Ensures treated water does not get contaminated.	

Table A.1b.1 SOP for KLM CCP1 Turbidity at Raw Water Abstraction at Inlet Race - SMD in use

Water Scheme	Kempsey and Lower Macleay – Steuart McIntyre Dam in use		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Continuous online / daily grab (7 days)
Monitoring location	Online instrument / daily grab (combined bore water) to SM Dam Inlet Race		
What will initiate response?	Confirmation of result with immediate grab sample re-test from the SM Dam Inlet Race		

Operating Target <1 NTU	Alert Level 3 NTU	Critical Limit 5 NTU
<ul style="list-style-type: none"> Observe weather and flood warnings Routine site and operational checks Instrument calibration and records maintained Monitor and measure raw water turbidity daily Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) Visual checks at Bore sites and Bore water monitoring program Individual Bore testing 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm with immediate grab sample re-test Contact Team Leader Consider ceasing supply to SM Dam Following confirmation of online result with grab sample. Check Recharge Channel for any water quality impacts such as flooding Check borefield for signs of damage to bore or any impacts to sites areas around bores Investigate operating bores in use at time of sampling to identify source of increased turbidity levels Check individual production bores for turbidity & iron and isolate where required <u>Make arrangements</u> for isolation & repairs to problem bore Check readiness of alternate supply Complete 'Initial Incident Report Form', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Cease borefield supply to SM Dam Check turbidity levels at SM Dam monitoring locations and at Active Transfer Pump to validate any infiltration to receiving reservoirs Check and confirm SM Dam volume for <u>sufficient</u> level as a supply source Process Engineer or Manager to call local PHU as soon as possible Contact Dol for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU Consider switch to Sherwood Lime Plant (alternative supply), if possible Complete 'Initial Incident Report Form', following confirmation of online result with grab sample.

Table A.1b.2 SOP for KLM CCP1 Turbidity Raw Water Abstraction at Active Pump Transfer – SMD in use

Water Scheme	Kempsey and Lower Macleay – Stuart McIntyre Dam in use		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	daily grab (7/days)
Monitoring location	SM Dam outlet from an active transfer pump		
What will initiate response?	Confirmation of result with immediate grab sample re-test		

Operating Target <1 NTU	Alert Level 3 NTU	Critical Limit 5 NTU
<ul style="list-style-type: none"> Routine site and operational checks Instrument calibration and records maintained Monitor and measure raw water turbidity daily Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) Maintain dam at required water level Weekly <u>shore line</u> monitoring for points of erosion (by boat and vehicle) Routine testing from Dam Routine monitoring of compressor run times (7days/wk) and visual checks and maintenance of Aeration line Aeration system to be run for approx. 7 hours during night to mix water body 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm with immediate grab sample re-test Contact Team Leader Increase visual monitoring for the formation of surface scum Check online temperature and DO trends to determine if dam has inverted Increase algae monitoring from different levels of offtakes as per Algae Monitoring Plan Select the most suitable offtake level Check aeration line for correct operation Adjust aeration system operational times Increase algae monitoring if algae detected with inclusion of toxin monitoring Adjust disinfection levels at treatment site. Check Sherwood Lime plant in readiness for alternate supply Undertake chlorine decay testing Consider moving into a higher water restriction level Source funding and availability of emergency containerised WTP Contact PHU and DoI Complete 'Initial Incident Report Form' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Process Engineer or Manager to call local PHU as soon as possible. Check turbidity levels downstream to validate any infiltration to receiving reservoirs Review pH Review algae species and toxicity Undertake chlorine decay testing Consider starting Sherwood Lime Plant (alternative supply) if possible Consider Boil water alert (based on pH, algae, and chlorine decay testing) until emergency containerised WTP is sourced. Consider moving into a higher water restriction level Contact DoI for operational advice as needed Consider obtaining emergency containerised WTP Complete 'Initial Incident Report Form'.

Table A.1b.3 SOP for KLM CCP1 Algae, Taste and Odour at Raw Water Abstraction @ In Dam – SMD in use

Water Scheme	Kempsey and Lower Macleay – Stuart McIntyre Dam in use		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	Taste and Odour compounds, Algae levels and Toxins
What is being monitored?	Algae Counts, Taste & Odour, & MIB/Geosmin levels	Monitoring Frequency:	As per Algal Monitoring Programme
Monitoring location	SM Dam Tower and Monitoring sites 1, 2 and 3		
What will initiate response?	Operator (in field monitoring) or Team Leader (in response to Laboratory results)		

Operating Target No detected T&O or MIB/Geosmin Algae biovolume below Limit	Alert Level Noticeable T&O or MIB/Geosmin > 2 ug/L Algae biovolume at Alert Level 1	Critical Limit Algae biovolume at Alert Level 2
<ul style="list-style-type: none"> Maintain dam at approximately 53m AHD (96% level) when possible. Observe weather warnings Weekly visual monitoring for algal blooms (boat and vehicle) Instrument calibration and records maintained Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) Algae monitoring as per the Algal Monitoring Programme Weekly Operator odour test from grab sample (conducted at same time Tb test) Routine monitoring of compressor run times Aeration system to be run for approx.7 hours during night to mix water body Routine monitoring for nutrients of raw water entering the dam (both in-house and external laboratory testing) 	<p>Corrective actions</p> <ul style="list-style-type: none"> Contact Team Leader Conduct in-house odour testing of raw & boiled water by operational staff Review the aeration operation rates and adjust as required Consider benthic algae inspection and sampling Increase visual monitoring for the formation of surface scum (boat and vehicle) Increase algae monitoring as per Algal Monitoring Programme with inclusion of toxin monitoring Select the most suitable offtake level for use Adjust aeration system operational times Check Sherwood Lime plant in readiness for operation Contact local PHU and DoI Consider moving into a higher water restriction level Source availability and funding of emergency containerised WTP Complete 'Initial Incident Report Form' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Contact Team Leader Team Leader to inform Process Engineer or Manager Process Engineer or Manager to contact local PHU and DoI Consider starting Sherwood Lime Plant (alternative supply) Consider moving into a higher water restriction level Consider obtaining emergency containerised WTP Complete 'Initial Incident Report Form'

Table A.1b.4 SOP for KLM CCP3 Free Chlorine and pH Disinfection at multiple reservoirs – SMD in use

Water Scheme	Kempsey and Lower Macleay – Stuart McIntyre Dam in use		
CCP ID	CCP3		
What is the control point?	Disinfection and pH correction	What are the hazards?	Chlorine sensitive pathogens
What is being monitored?	Free chlorine residual & pH	Monitoring Frequency:	Daily grab (7 days)
Monitoring location	Reservoir(s) outlet: Greenhill, John Lane, Potters Hill		
What will initiate response?	Confirmation of result with immediate grab sample re-test		

Operating Target	Alert Limit	Critical Limit
SMD – chlorine 1.8 mg/L pH 7.5	SMD - <1.0 or >3 mg/L pH <6.8 or >8.0	SMD – chlorine <0.6 or >4 mg/L pH <6.5 or >8.5
<ul style="list-style-type: none"> • Routine site and operational checks at Dosing Plant • Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) • Chemical dosing rate checks • Disinfection residual checks performed at the outlet of Reservoir • Instrument calibration and records maintained • Chemical procurement and delivery requirements • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Regular inspection of the lime dosing system including cleaning of injection lines for change over • Flow meter checks • Redox probes within Reservoirs 	<p style="color: #ff0000;">Corrective actions</p> <ul style="list-style-type: none"> • Confirm result with an immediate re-sample. • Validate disinfection levels (using high ranges or dilution methods if required) • Contact Team Leader • Check disinfection levels from primary dosing and adjust as required • Check raw water conditions • Check disinfection levels in Reservoir and manually dose if required (Refer Reservoir Manual Chlorine Dose Calculator) • Check integrity of Reservoir for any breaches or unauthorised access • Check primary dosing equipment (circulation pumps, injection point) • Consider scouring, flushing and sampling in the network where appropriate • Complete 'Initial Incident Report Form', 	<p style="color: #ff0000;">Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps • Test for total chlorine if free chlorine is >4 mg/L. Total chlorine should not be >5 mg/L. • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible. • Take micro-sample for low disinfection levels • Process Engineer or Manager to call local PHU as soon as possible. • Contact DoI for operational advice as needed. • Consider boil water alert in consultation with local PHU. • Consider moving into a higher water restriction level • Consider obtaining emergency containerised WTP. • Complete 'Initial Incident Report Form',

Table A.1b.5 SOP for KLM CCP5 Reservoir Integrity

Water Scheme	Kempsey and Lower Macleay - Steuart McIntyre Dam in use		
CCP ID	CCP5		
What is the control point?	Reservoir	What are the hazards?	All pathogens and all chemicals
What is being monitored?	Reservoir integrity	Monitoring Frequency:	Monthly
Monitoring location	All service reservoirs		
What will initiate response?	Any sign of reservoir integrity breach		

Operating Target No breach of integrity	Adjustment Limit Any sign of integrity breach	Critical Limit Evidence of contamination
<ul style="list-style-type: none"> Reservoir inspection program (routine) with records maintained Scheduled contractor reservoir cleaning and inspection program 	<p>Corrective actions</p> <ul style="list-style-type: none"> Conduct visual inspection (outside & inside) Check disinfection levels in Reservoir and top up if required (Refer to Reservoir Manual Chlorine Dose Calculator) Increase chlorine dose at plant, if needed Contact Team Leader Repair breach of integrity. Increase inspections until repaired Consider notifying local PHU Complete 'Initial Incident Report Form' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level corrective actions Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Take micro-sample if required Remove contaminants, if safe to do so Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete 'Initial Incident Report Form'

Table A.2 CCP Crescent Head Water Supply

Scheme	CCP ID	Control Point	Control Parameter	Testing Location	Frequency	Target	Alert Level	Critical Limit	Justification for critical limit
Crescent Head	CCP1	Raw Water Abstraction	Turbidity	Front Dam	Daily grab	<1 NTU	4 NTU	5 NTU	There is no filtration undertaken, critical limit provides an interim barrier to control contaminant/ microbial load. Plant is shut off manually at critical limit.
	CCP2	Filtration	Turbidity	NA	NA	NA	NA	NA	NA
	CCP3	Disinfection	Free Chlorine	Back Beach Reservoir Outlet	Daily grab	1.5 mg/L pH 7.5	<0.7 or >3 mg/L pH <6.8 or >8.0	<0.5 or >4 mg/L pH <6.5 or >8.5	Lower chlorine critical limit ensures that C.t is met at the monitoring location. Upper chlorine critical limit ensures that total chlorine does not get >5 mg/L (health limit). Lower pH critical limit protects asset corrosion. Upper pH critical limit ensures efficiency of chlorination is not compromised (ADWG).
	CCP4	Fluoridation	Fluoride	NA	NA	NA	NA	NA	NA
	CCP5	Reservoirs	Reservoir integrity	All reservoirs	Monthly	No breach of integrity	Any sign of integrity breach	Evidence of contamination	Ensures treated water does not get contaminated.

Note: Daily grab is taken 7 days/week

Table A.2.1 SOP for CH CCP1 Turbidity Raw Water Abstraction at Front Dam

Water Scheme	Crescent Head		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Daily grab (7 days)
Monitoring location	Front Dam		
What will initiate response?	Confirmation of result with immediate follow up test		

Operating Target <1 NTU	Alert Level 4 NTU	Critical Limit 5 NTU
<ul style="list-style-type: none"> • Routine site and operational checks • Equipment correlation checks (Bench meter instruments cross checked results against similar instruments). • Monitor and measure raw water turbidity daily at the Front Dam, weekly at the combined Balance Tank and weekly at individual Bores • Visual checks at Bore sites and Bore water monitoring program • Visual Inspections for Algae in Dam daily 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Repeat manual test to confirm result • Investigate bore integrity and Collection Tank for contamination • Test turbidity for each bore and Collection Tank and isolate problem bore if required. • Contact Team Leader • Check turbidity at Back Beach Reservoir. • Check Total Chlorine levels at Back Beach Reservoir (refer to Chlorination SOP) • Increase Total Chlorine dose at plant, if needed • Initiate an incident algal monitoring program in Front Dam if required. • Complete 'Initial Incident Report Form', following confirmation with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps • Contact Team Leader • Team Leader to inform, Process Engineer or Manager as soon as possible. • Isolate and contain source of high turbidity • Shutdown the Dosing Plant • Consider alternative water supply/storage where possible (i.e. Onsite Raw water tanks) • Maintain appropriate disinfection levels in the network • Check turbidity levels downstream to validate any infiltration to Dosing (if automatic shutdown has failed) • Consider isolation & scour the Collection Tank • Process Engineer or Manager to call local PHU as soon as possible • Contact DoI for operational advice as needed. • Implement additional response actions (e.g. boil water alert) in consultation with local PHU. • Complete 'Initial Incident Report Form', following confirmation with grab sample

Table A.2.2 SOP for CH CCP3 Free Chlorine and pH Disinfection at Back Beach Reservoir

Water Scheme	Crescent Head		
CCP ID	CCP3		
What is the control point?	Disinfection (chlorine gas and Calcium Hypochlorite pills) and pH correction (lime & CO ₂)	What are the hazards?	Chlorine sensitive pathogens
What is being monitored?	Free chlorine residual & pH	Monitoring Frequency:	Daily grab (7 days)
Monitoring location	Back Beach Reservoir outlet		
What will initiate response?	Confirmation of result with immediate follow up test		

Operating Target 1.5 mg/L pH 7.5	Alert Limit <0.7 or >3 mg/L pH <6.8 or >8.0	Critical Limit <0.5 or >4 mg/L pH <6.5 or >8.5
<ul style="list-style-type: none"> Routine site and operational checks at Dosing Plant Equipment correlation checks (Bench meter instruments cross checked results against similar instruments. Chlorine gas, CO₂ & lime dose rate checks Disinfection residual checks performed at the outlet of Reservoir Instrument calibration and records maintained Chemical procurement and delivery requirements Regular inspection of the lime dosing system including cleaning of injection lines for change over Chemical storage levels monitoring 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm result with an immediate re-sample. Validate disinfection levels (using high ranges or dilution methods if required) Check primary dosing equipment and gas cylinder weight (physically by rocking) Contact Team Leader Check disinfection levels from primary dosing and adjust as required Check raw water conditions Check disinfection levels in Reservoir and manually dose if required (Refer Reservoir Manual Chlorine Dose Calculator) Check integrity of Reservoir for any breaches or unauthorised access Consider scouring, flushing and sampling in the network where appropriate Complete 'Initial Incident Report Form', following confirmation with grab sample 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Test for total chlorine if free chlorine is >4 mg/L. Total chlorine should not be >5 mg/L. Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Consider taking micro-sample for low disinfection levels Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete 'Initial Incident Report Form', following confirmation with grab sample.

Table A.2.3 SOP for CH CCP5 Reservoir Integrity at all Reservoirs

Water Scheme	Crescent Head		
CCP ID	CCP5		
What is the control point?	Reservoir	What are the hazards?	All pathogens and all chemicals
What is being monitored?	Reservoir integrity	Monitoring Frequency:	Monthly
Monitoring location	All service reservoirs (Back Beach & Big Nobby)		
What will initiate response?	Any sign of reservoir integrity breach		

Operating Target No breach of integrity	Adjustment Limit Any sign of integrity breach	Critical Limit Evidence of contamination
<ul style="list-style-type: none"> Reservoir inspection program (routine) with records maintained Scheduled contractor reservoir cleaning and inspection program 	<p>Corrective actions</p> <ul style="list-style-type: none"> Conduct visual inspection (outside & inside) Check disinfection levels in Reservoir and top up if required (Refer to Reservoir Manual Chlorine Dose Calculator) Increase chlorine dose at plant, if needed Contact Team Leader Repair breach of integrity Consider notifying local PHU Complete 'Initial Incident Report Form' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level corrective actions Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Take micro-sample if required Remove contaminants, if safe to do so Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete 'Initial Incident Report Form'

Table A.3 CCP Hat Head Water Supply

Scheme	CCP ID	Control Point	Control Parameter	Testing Location	Frequency	Target	Alert Level	Critical Limit	Justification for critical limit
Hat Head	CCP1	Raw Water Abstraction	Turbidity	Raw Water Inlet	Continuous online / grab sample	<1 NTU	2 NTU	4 NTU	There is no filtration undertaken, critical limit provides an interim barrier to control contaminant/ microbial load. Plant is shut off at critical limit.
	CCP2	Filtration	Turbidity	NA	NA	NA	NA	NA	NA
	CCP3	Disinfection	Free Chlorine	Clear water to retic leaving dosing plant	Continuous online / grab sample	1 mg/L pH 7.5	<0.6 or >3 mg/L pH <6.8 or >8.0	<0.5 or >4 mg/L pH <6.5 or >8.5	Lower chlorine critical limit ensures that C.t is met at the monitoring location. Upper critical chlorine limit ensures that total chlorine does not get >5 mg/L (health limit). Lower pH critical limit protects asset corrosion. Upper pH critical limit ensures efficiency of chlorination is not compromised (ADWG).
	CCP4	Fluoridation	Fluoride	NA	NA	NA	NA	NA	NA
	CCP5	Reservoirs	Reservoir integrity	All reservoirs	Monthly	No breach of integrity	Any sign of integrity breach	Evidence of contamination	Upon advice from NSW Health. Ensures treated water does not get re-contaminated.

Note: Grab sample is taken daily (7 days/week). Raw Water Abstraction and Disinfection CCPs have continuous online monitoring.

Table A.3.1 SOP for HH CCP1 Turbidity Raw Water Abstraction at Plant Inlet

Water Scheme	Hat Head		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Continuous online / daily grab (7 days)
Monitoring location	Raw Water Inlet to dosing plant		
What will initiate response?	Confirmation of online result with grab sample		

Operating Target <1 NTU	Alert Level 2 NTU	Critical Limit 4 NTU
<ul style="list-style-type: none"> • Routine site and operational checks • Instrument calibration and records maintained • Monitor and measure raw water turbidity daily • Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Visual checks at Bore sites and Bore water monitoring program • Aeration system maintenance & operation • Balance Tank cleaning program 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Confirm or cross check online turbidity with portable instrument and clean if needed • Contact Team Leader • Check Balance Tank for turbidity and iron levels • Check diffuser/ aeration operation within Balance Tank • Check individual production Bores for turbidity & iron and isolate where required • Dose chlorine to Reservoirs and/or increase dose at plant, if needed • Consider shutting dosing plant down • Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible. • Shut down the treatment plant • Check turbidity levels downstream to validate any infiltration to dosing plant (if automatic shutdown has failed) • Consider isolation & scour the Balance Tank • Process Engineer or Manager to call local PHU as soon as possible. • Contact DoI for operational advice as needed. • Implement additional response actions (e.g. boil water alert) in consultation with local PHU. • Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample.

Table A.3.2 SOP for HH CCP3 Free Chlorine and pH Disinfection at outlet of Reservoirs

Water Scheme	Hat Head		
CCP ID	CCP3		
What is the control point?	Disinfection (Chlorine gas) & pH correction (Soda ash)	What are the hazards?	Chlorine sensitive pathogens
What is being monitored?	Free chlorine residual & pH	Monitoring Frequency:	Continuous (online) / daily grab (7 days)
Monitoring location	Clear water to reticulation – leaving dosing plant		
What will initiate response?	Confirmation of online result with grab sample		

Operating Target 1mg/L pH 7.5	Alert Limit <0.6 or >3 mg/L pH <6.8 or >8.0	Critical Limit <0.5 or >4 mg/L pH <6.5 or >8.5
<ul style="list-style-type: none"> • Routine site and operational checks at DOSING PLANT • Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) • Soda ash and chlorine gas dose rate checks • Disinfection residual checks performed at the outlet of Reservoir • Instrument calibration and records maintained • Chemical procurement and delivery requirements • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Regular inspection of the Soda ash dosing system Chemical storage levels monitoring 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Confirm or cross check online result with portable instrument • Validate disinfection levels (using high ranges or dilution methods if required) • Check primary dosing equipment and adjust as required • Contact Team Leader • Check disinfection levels from primary dosing and adjust as required • Check raw water conditions • Check disinfection levels in Reservoir and manually dose if required (Refer Reservoir Manual Chlorine Dose Calculator) • Check integrity of Reservoir for any breaches or unauthorised access • Consider scouring, flushing and sampling in the network where appropriate • Complete 'Initial Incident Report Form', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps • Test for total chlorine if free chlorine is >4 mg/L. Total chlorine should not be >5 mg/L. • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible. • Consider taking micro-sample for low disinfection levels • Process Engineer or Manager to call local PHU as soon as possible. • Contact Dol for operational advice as needed. • Implement additional response actions (e.g. boil water alert) in consultation with local PHU. • Complete 'Initial Incident Report Form', following confirmation of online result with grab sample.

Table A.3.3 SOP for HH CCP5 Reservoir Integrity at all Reservoirs

Water Scheme	Hat Head		
CCP ID	CCP5		
What is the control point?	Reservoir	What are the hazards?	All pathogens and all chemicals
What is being monitored?	Reservoir integrity	Monitoring Frequency:	Monthly
Monitoring location	All service reservoirs		
What will initiate response?	Any sign of reservoir integrity breach		

Operating Target No breach of integrity	Adjustment Limit Any sign of integrity breach	Critical Limit Evidence of contamination
<ul style="list-style-type: none"> Reservoir inspection program (routine) with records maintained Scheduled contractor reservoir cleaning and inspection program 	<p>Corrective actions</p> <ul style="list-style-type: none"> Conduct visual inspection (outside & inside) Check disinfection levels in Reservoir and top up if required (Refer to Reservoir Manual Chlorine Dose Calculator) Increase chlorine dose at plant, if needed Contact Team Leader Repair breach of integrity Consider notifying local PHU Complete '<i>Initial Incident Report Form</i>' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level corrective actions Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Take micro-sample if required Remove contaminants, if safe to do so Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete '<i>Initial Incident Report Form</i>'

Table A.4 CCP South West Rocks Water Supply

Scheme	CCP ID	Control Point	Indicator Parameter	Testing Location	Frequency	Target	Alert Level	Critical Limit	Justification for critical limit
South West Rocks	CCP1	Raw Water Abstraction	Turbidity	Inlet to WTP	Continuous online / daily grab	<5 NTU	10 NTU	20 NTU	Plant is shut off for turbidity >20 NTU for membrane protection. [Note: online result is verified with grab sample].
	CCP2	Filtration	Turbidity	After filters at WTP / on main after transfer pump	Continuous online / daily grab	<0.1 NTU	0.5 NTU	1 NTU	Critical limit ensures solids removal and that effectiveness of chlorination is maintained. Protozoa risk is low as source is bores. [Note: online result is verified with grab sample].
	CCP3	Disinfection	Free Chlorine pH	Reservoir outlet	Daily grab	1.2 mg/L pH 7.5	<0.8 or >3 mg/L pH <6.8 or >8.0	<0.6 mg/L or >4 mg/L pH <6.5 or >8.5	Lower chlorine critical limit ensures that C.t is met at the monitoring location. Upper chlorine critical limit ensures that total chlorine does not get >5 mg/L (health limit). Lower pH critical limit protects asset corrosion. Upper pH critical limit ensures efficiency of chlorination is not compromised (ADWG).
	CCP4	Fluoridation	Fluoride	Leaving WTP & Gregory St Res Outlet	Continuous online / daily grab	1 mg/L	<0.9 mg/L for >72 hrs OR >1.2 mg/L	>1.5 mg/L	One of the monitoring points is located downstream of dosing but prior to any reservoir/tank, as per Fluoridation Code. Critical limit is set at the health guideline value.
	CCP5	Reservoir	Reservoir integrity	All Reservoirs	Monthly	No breach of integrity	Any sign of integrity breach	Evidence of contamination	Ensures treated water does not get contaminated.

Note: Grab sample is taken daily (7 days/week). Raw water abstraction, Filtration and Fluoridation CCPs have continuous online monitoring.

Table A.4.1 SOP for SWR CCP1 Turbidity Raw Water Abstraction at Inlet to WTP

Water Scheme	South West Rocks		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Continuous online / daily grab (7 days)
Monitoring location	Inlet to WTP		
What will initiate response?	Confirmation of online result with grab sample		

Operating Target <5 NTU	Alert Level 10 NTU	Critical Limit 20 NTU
<ul style="list-style-type: none"> • Routine site and operational checks • Instrument calibration and records maintained • Monitor and measure raw water turbidity • Equipment correlation checks (Bench meter instruments cross checked results against similar instruments). • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Visual checks at Bore sites and Bore water monitoring program • Aeration system maintenance & operation • Balance Tank cleaning program 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Confirm or cross check online turbidity with portable instrument and clean if needed • Contact Team Leader • Check Balance Tank for turbidity and iron levels • Check diffuser/ aeration operation within Balance Tank • Check individual production Bores for turbidity & iron and isolate where required • Consider shutting WTP down • Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible. • Ensure automatic interlock has shut down the treatment plant, otherwise shutdown the system • Check turbidity levels downstream to validate any infiltration to WTP (if automatic shutdown has failed) • Consider isolation & scour the Balance Tank • Process Engineer or Manager to call local PHU as soon as possible. • Contact Dol for operational advice as needed. • Implement additional response actions (e.g. boil water alert) in consultation with the local PHU. • Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample.

Table A.4.2 SOP for SWR CCP2 Turbidity Filtration at Outlet of filters

Water Scheme	South West Rocks		
CCP ID	CCP2		
What is the control point?	Membrane Filtration	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Continuous online / daily grab (7 days)
Monitoring location	After filters at WTP / on main after transfer pump		
What will initiate response?	Confirmation of online result with grab sample		

Operating Target <0.1 NTU	Alert Limit 0.5 NTU	Critical Limit 1 NTU
<ul style="list-style-type: none"> • Routine site and operational checks • Instrument calibration and records maintained • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Daily automatic backwashing and extended backwashing of membranes • Regular MIT and Manual initiated clean, ensure membrane replacement and repair program is current and up to date • Actions related to coagulants, pH correction, screen at head of plant, pH correction of membrane sump, etc. Note: Results are recorded and actioned as per GE membrane recommendations • Chemical procurement and delivery requirements 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Confirm or cross check online turbidity with manual instrument • Check trans-membrane pressure and initiate a CIP if required • Check turbidity of raw water into plant • Check upstream chemical dosing • Isolation of modules that may be leaking and repair ASAP to ensure full treatment capacity of membrane train • Contact Team Leader • Complete 'Initial Incident Report Form', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible. • Automatic shutdown of treatment plant • Check Reservoir Turbidity, if automatic shutdown has failed • Consider isolation & scour of the Reservoir where appropriate • Check turbidity in distribution and flush mains if appropriate • Process Engineer or Manager to call local PHU as soon as possible. • Contact Dol for operational advice as needed. • Implement additional response actions (e.g. boil water alert) in consultation with PHU. • Complete 'Initial Incident Report Form', following confirmation of online result with grab sample.

Table A.4.3 SOP for SWR CCP3 Free Chlorine and pH Disinfection at Reservoir

Water Scheme	South West Rocks		
CCP ID	CCP3		
What is the control point?	Disinfection (sodium hypochlorite) and pH correction (lime)	What are the hazards?	Chlorine sensitive pathogens
What is being monitored?	Free chlorine & pH	Monitoring Frequency:	Daily grab (7 days)
Monitoring location	Gregory Street Reservoir outlet		
What will initiate response?	Confirmation of result with immediate follow up grab sample test		

Operating Target 1.2 mg/L pH 7.5	Alert Limit <0.8 or >3 mg/L pH <6.8 or >8.0	Critical Limit <0.6 or >4 mg/L pH <6.5 or >8.5
<ul style="list-style-type: none"> Routine site and operational checks at WTP. Equipment correlation checks (Bench meter instruments cross checked results against similar instruments). Lime and Sodium Hypochlorite dose rate checks Disinfection residual checks performed at the outlet of Reservoir Instrument calibration and records maintained Chemical procurement and delivery requirements Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) Regular inspection of the lime dosing system including cleaning of injection lines for change over Chemical storage levels monitoring 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm result with an immediate re-sample. Validate disinfection levels (using high ranges or dilution methods if required) Check primary dosing equipment and hypo concentration and adjust as required Contact Team Leader Check disinfection levels from primary dosing and adjust as required Check upstream processes (mixing tanks, pH correction, membrane filters) Check raw water conditions Check disinfection levels in Reservoir and top up if required (Refer Reservoir Manual Chlorine Dose Calculator) Check integrity of Reservoir for any breaches or unauthorised access Consider scouring, flushing and sampling in the network where appropriate Complete 'Initial Incident Report Form', following confirmation of result with another test. 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Test for total chlorine if free chlorine is >4 mg/L. Total chlorine should not be >5 mg/L. Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Consider taking micro-sample for low disinfection levels Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete 'Initial Incident Report Form', following confirmation of result with another test.

Table A.4.4 SOP for SWR CCP4 Fluoride Fluoridation at WTP post dosing and Gregory St Reservoir

Water Scheme	South West Rocks		
CCP ID	CCP4		
What is the control point?	Fluoridation	What are the hazards?	Over or under-dose of fluoride
What is being monitored?	Fluoride concentration	Monitoring Frequency:	Continuous online / daily grab (7days)
Monitoring location	Monitoring point is downstream of dosing but prior to reservoir and outlet of Gregory St Reservoir		
What will initiate response?	Confirmation of online result with grab sample		

Operating Target 1 mg/L	Alert Limit <0.9 for >72 hrs OR >1.2 mg/L	Critical Limit >1.5 mg/L
<ul style="list-style-type: none"> Visual inspection of the system Raw water testing as required Daily measurement of volume treated, and weight fluoride dosed with calculation of average daily fluoride concentration Daily testing at outlet to water filtration plant (after transfer pumps) and outlet from Gregory St reservoir Flow meter calibrations (MCT & KSC Techs) Chemical procurement and delivery requirements Weekly testing in distribution system Weight records for Fluoride dosing Regular service by contractor 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm or cross check online result with manual instrument Confirm calculations Conduct screw feeder and pump drop tests Confirm current WTP flow rate and fluoride dosing rate Adjust fluoride powder screw feeder Test concentration leaving WTP more frequently Consider temporarily shutting down fluoride dosing system Contact Team Leader Complete 'Initial Incident Report Form', following confirmation of online result with grab sample. Complete Form 5 and submit to local PHU & NSW Health if fluoride level is <0.9 mg/L for more than 72hrs (3 consecutive days) 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Shutdown fluoride dosing system Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Test fluoride in Reservoirs and reticulation Identify cause & rectify problem Refer to Fluoride Overdose Response Plan Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Complete 'Initial Incident Report Form', following confirmation of online result with grab sample.

Table A.4.5 SOP for SWR CCP5 Reservoir Integrity at all Reservoirs

Water Scheme	South West Rocks		
CCP ID	CCP5		
What is the control point?	Reservoir	What are the hazards?	All pathogens and all chemicals
What is being monitored?	Reservoir integrity	Monitoring Frequency:	Monthly
Monitoring location	All service reservoirs (Gregory St & New Entrance)		
What will initiate response?	Any sign of reservoir integrity breach		

Operating Target No breach of integrity	Adjustment Limit Any sign of integrity breach	Critical Limit Evidence of contamination
<ul style="list-style-type: none"> Reservoir inspection program (routine) with records maintained Scheduled contractor reservoir cleaning and inspection program 	<p>Corrective actions</p> <ul style="list-style-type: none"> Conduct visual inspection (outside & inside) Check disinfection levels in Reservoir and top up if required (Refer to Reservoir Manual Chlorine Dose Calculator) Increase chlorine dose at plant, if needed Contact Team Leader Repair breach of integrity Consider notifying local PHU Complete '<i>Initial Incident Report Form</i>' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level corrective actions Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Take micro-sample if required Remove contaminants, if safe to do so Process Engineer or Manager to call local PHU as soon as possible. Contact Dol for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete '<i>Initial Incident Report Form</i>'

Table A.5 CCP Stuarts Point Water Supply

System	CCP ID	Control Point	Control Parameter	Testing Location	Frequency	Target	Alert Level	Critical Limit	Justification for critical limit
Stuarts Point	CCP1	Raw Water Abstraction	Turbidity	Raw Water Sample point (prior to pH and pre-disinfection)	Grab sample	<0.5 NTU	3 NTU	5 NTU	Plant is shut off at critical limit.
	CCP2	Filtration	Turbidity	Post filtration (inlet to clearwater tank)	Continuous online / grab sample	<0.3 NTU	0.8 NTU	1 NTU	Critical limit ensures solids removal and that effectiveness of chlorination is maintained. Protozoa risk is low as source is bores. [Note: online result is verified with grab sample].
	CCP3	Disinfection	Free Chlorine	Stuarts Point Reservoir Outlet	Continuous online / grab sample	1 mg/L	<0.8 or >3mg/L	<0.6 or >4 mg/L	Lower chlorine critical limit ensures that C.t is met at the monitoring location. Upper chlorine critical limit ensures that total chlorine does not get >5 mg/L (health limit). No pH correction undertaken. [Note: online result is verified with grab sample].
	CCP4	Fluoridation	Fluoride	NA	NA	NA	NA	NA	NA
	CCP5	Reservoirs	Reservoir integrity	All reservoirs	Monthly	No breach of integrity	Any sign of integrity breach	Evidence of contamination	Ensures treated water does not get contaminated.

Note: Grab sample is taken daily (7 days/week). Disinfection and Filtration CCPs have continuous online monitoring.

Table A.5.1 SOP for SP CCP1 Turbidity Raw Water Abstraction at WTP before disinfection

Water Scheme	Stuarts Point		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Daily grab (5 days)
Monitoring location	Raw Water Sample point (prior to pH and pre-disinfection)		
What will initiate response?	Confirmation of result with immediate follow up grab sample test		

Operating Target <0.5 NTU	Alert Level 3 NTU	Critical Limit 5 NTU
<ul style="list-style-type: none"> Routine site and operational checks Instrument calibration and records maintained Monitor and measure raw water turbidity daily at the CCP1 monitoring point and 2/weekly at individual bores Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) Visual checks at Bore sites and Bore water monitoring program Clearwater Tank cleaning program 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm result by re-testing Contact Team Leader Re-adjust chemical dosing to accommodate lowered flow rate if appropriate Check Clearwater Tank for turbidity and iron levels Check individual production Bores for turbidity & iron and isolate where required Consider shutting WTP down Complete '<i>Initial Incident Report Form</i>', following confirmation of result with re-test sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Shutdown the system Check turbidity levels downstream to validate any infiltration to WTP Consider isolation & scour the Clearwater Tank Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete '<i>Initial Incident Report Form</i>', following confirmation of result with re-test sample.

Table A.5.2 SOP for SP CCP2 Turbidity Filtration at WTP post filtration

Water Scheme	Stuarts Point		
CCP ID	CCP2		
What is the control point?	Filtration	What are the hazards?	Heavy metals and pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Continuous online & daily grab (5 days)
Monitoring location	Post filtration (inlet to clearwater tank)		
What will initiate response?	Confirmation of online result with grab sample		

Operating Target <0.1 NTU	Alert Limit 0.5 NTU	Critical Limit 1 NTU
<ul style="list-style-type: none"> Routine site and operational checks Instrument calibration and records maintained Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) Ferric chloride dosing equipment and dosage rate checks Chemical procurement and delivery requirements 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm or cross check online turbidity with manual instrument Visually check water quality on top of filters Adjust <u>air-line</u> and check air-line is working Check for filter blockage Check turbidity of raw water into plant Check upstream chemical dosing Contact Team Leader Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Automatic shutdown of treatment plant Check Reservoir Turbidity, if automatic shutdown has failed Consider isolation & scour of the Clearwater tank where appropriate Check turbidity in Reservoir and distribution and flush mains if appropriate Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample.

Table A.5.3 SOP for SP CCP3 Free Chlorine Disinfection at Clear Water Tank

Water Scheme	Stuarts Point		
CCP ID	CCP3		
What is the control point?	Disinfection (chlorine gas) & pH correction (soda ash) when in use	What are the hazards?	Chlorine sensitive pathogens
What is being monitored?	Free chlorine residual	Monitoring Frequency:	Continuous online & daily grab (7 days)
Monitoring location	Stuarts Point Reservoir outlet		
What will initiate response?	Confirmation of online result with grab sample		

Operating Target 1 mg/L	Alert Limit <0.8 or >3 mg/L	Critical Limit <0.6 or >4 mg/L
<ul style="list-style-type: none"> Routine site and equipment <u>checks</u> at WTP Instrument calibration and records maintained Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) Soda ash and chlorine gas dose rate checks Disinfection residual checks performed at the outlet of Reservoir Chemical procurement and delivery requirements Chemical storage levels monitoring 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm or cross check online result with manual instrument Validate disinfection levels (using high ranges or dilution methods if required) Check pre and post chlorine dosing Check the flow rates coming into plant Contact Team Leader Check disinfection levels from primary dosing and adjust as required Check upstream processes (mixing tanks, pH correction, membrane filters) Check raw water conditions Check disinfection levels in Reservoir and top up if required (Refer Reservoir Manual Chlorine Dose Calculator) Check integrity of CWT for any breaches or unauthorised access Consider scouring, flushing and sampling in the network where appropriate Complete 'Initial Incident Report Form', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Test for total chlorine if free chlorine is >4 mg/L. Total chlorine should not be >5 mg/L. Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Consider taking micro-sample for low disinfection levels Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete 'Initial Incident Report Form', following confirmation of online result with grab sample.

Table A.5.4 SOP for SP CCP5 Reservoir Integrity at all Reservoirs

Water Scheme	Stuarts Point		
CCP ID	CCP5		
What is the control point?	Reservoir	What are the hazards?	All pathogens and all chemicals
What is being monitored?	Reservoir integrity	Monitoring Frequency:	Monthly
Monitoring location	All service reservoirs		
What will initiate response?	Any sign of reservoir integrity breach		

Operating Target No breach of integrity	Adjustment Limit Any sign of integrity breach	Critical Limit Evidence of contamination
<ul style="list-style-type: none"> Reservoir inspection program (routine) with records maintained Scheduled contractor reservoir cleaning and inspection program 	<p>Corrective actions</p> <ul style="list-style-type: none"> Conduct visual inspection (outside & inside) Check disinfection levels in Reservoir and top up if required (Refer to Reservoir Manual Chlorine Dose Calculator) Increase chlorine dose at plant, if needed Contact Team Leader Repair breach of integrity Consider notifying local PHU Complete 'Initial Incident Report Form' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level corrective actions Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Take micro-sample if required Remove contaminants, if safe to do so Process Engineer or Manager to call local PHU as soon as possible. Contact Dol for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete 'Initial Incident Report Form'

Table A.6 CCP Bellbrook Water Supply

System	CCP ID	Control Point	Control Parameter	Testing Location	Frequency	Target	Alert Level	Critical Limit	Justification for critical limit
Bellbrook	CCP1	Raw Water Abstraction	Turbidity	Inlet to treatment plant prior to raw water tank	Continuous online / grab sample	<5 NTU	5 NTU for more than 20min	20 NTU	Plant is shut off for turbidity >20 NTU. [Note: online result is verified with grab sample].
	CCP2	Filtration	Turbidity	After filters at WTP	Grab sample	<0.5 NTU	0.8 NTU	1 NTU	Critical limit ensures solids removal and that effectiveness of chlorination is maintained.
	CCP3	Disinfection	Free Chlorine pH	Clear water tank outlet	Continuous online / grab sample	1.5 mg/L pH 7.5	<1 or >3.0 mg/L pH <6.8 or >8.0	<0.8 or >4 mg/L pH <6.5 or >8.5	Lower chlorine critical limit ensures that C.t is met at the monitoring location. Upper chlorine critical limit ensures that total chlorine does not get >5 mg/L (health limit). pH correction undertaken. Lower pH critical limit protects asset corrosion. Upper pH critical limit ensures efficiency of chlorination is not compromised (ADWG) [Note: online result is verified with grab sample].
	CCP4	Fluoridation	Fluoride	NA	NA	NA	NA	NA	NA
	CCP5	Reservoirs	Reservoir integrity	All reservoirs	Monthly	No breach of integrity	Any sign of integrity breach	Evidence of contamination	Ensures treated water does not get contaminated.

Table A.6.1 SOP for BB CCP1 Turbidity Raw Water Abstraction at Inlet to Plat

Water Supply System	Bellbrook		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Continuous online / daily grab sample (5 days)
Monitoring location	Pre raw water tank		
What will initiate response?	Confirmation of online result with grab sample		
Operating Target <5 NTU	Alert Level 5 NTU for more than 20min	Critical Limit 20 NTU	
<ul style="list-style-type: none"> • Routine site and operational checks • Weather and flood warnings observations • Conduct routine Bore maintenance program • Routine site and operational checks • Instrument calibration and records maintained • Monitor and measure raw water turbidity • Equipment correlation checks (Bench meter instruments cross checked results against similar instruments.) • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Raw Water Tank cleaning program • Annual checks for plant auto shut down 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Attend site and confirm or cross check online turbidity with portable instrument. • Check River for any water quality impacts, such as flooding. • Check bore for signs of damage to bore or any impacts to sites areas around bores. • Make arrangements for isolation & repairs to problem bore (if issue). • Increase monitoring of raw water turbidity levels until system returns to normal • If flooding is impacting the River, consider plans to commence water carting and consider early shutdown of plant. • Contact Team Leader. • Complete '<i>Initial Incident Report Form</i>' following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps. • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible. • Ensure automatic interlock has shut down the treatment plant, otherwise shutdown the system. • Ensure that Bore pumps are stopped (and are unavailable to automatic start up). • Management to consider the need to initiate an incident response • Process Engineer or Manager to call local PHU as soon as possible. • Contact DoI for operational advice as needed. • Implement additional response actions (e.g. water carting, boil water alert) in consultation with the local PHU. • Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample. 	

Table A.6.2 SOP for BB CCP2 Turbidity Filtration at WTP after filters

Water Supply System	Bellbrook		
CCP ID	CCP2		
What is the control point?	Filtration	What are the hazards?	Heavy metals and pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Daily grab sample (5 days)
Monitoring location	After filters at WTP		
What will initiate response?	Confirmation of result with immediate follow up test		

Operating Target <0.5 NTU	Alert Limit 0.8 NTU	Critical Limit 1 NTU
<ul style="list-style-type: none"> • Routine site and operational checks • Instrument calibration and records maintained • Media replacement program (as required) • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Annual checks for plant auto shut down • Maintenance cleaning of Raw Water Tank 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Confirm result with immediate follow up test • Look at pressure differentials across filters • Verify turbidity of Raw Water • Check upstream chemical dosing • Contact Team Leader • Complete '<i>Initial Incident Report Form</i>' following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible • Verify turbidity in Clearwater Tank, and if it exceeds 1 NTU, consult with Team Leader on actions required (e.g. empty and scour tank) • Check turbidity in Bellbrook Reservoir and if exceeds 1 NTU consider actions with Team Leader • Management to consider the need to initiate an incident response. • Process Engineer or Manager to notify local PHU as soon as possible • Contact DoI for operational advice as needed • Implement additional response actions (e.g. boil water alert) in consultation with local PHU • Complete '<i>Initial Incident Report Form</i>' following confirmation of online result with grab sample

Table A.6.3 SOP for BB CCP3 Free Chlorine Disinfection at out of Clear Water Tank

Water Supply System	Bellbrook		
CCP ID	CCP3		
What is the control point?	Disinfection	What are the hazards?	Chlorine sensitive pathogens
What is being monitored?	Free Chlorine & pH	Monitoring Frequency:	Continuous online/ daily grab sample (5 days)
Monitoring location	Clearwater Tank outlet		
What will initiate response?	Confirmation of online result with grab sample		
Operating Target 1.5 mg/L pH 7.5	Alert Limit <1 or >3.0 mg/L pH <6.8 or >8.0	Critical Limit <0.8 or >4 mg/L pH <6.5 or >8.5	
<ul style="list-style-type: none"> • Routine site and equipment checks at WTP • Instrument calibration and records maintained • Equipment correlation checks (Bench meter instruments cross checked results against similar instruments) • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Sodium hypochlorite and soda ash dosing rate checks • Disinfection residual checks performed at the outlet of CWT • Chemical procurement and delivery requirements 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Confirm online result with grab sample • Validate disinfection levels (using high ranges or dilution methods if required) • Check primary dosing equipment and hypo concentration and adjust as required • Contact Team Leader • Check raw water conditions • Check upstream processes (pH correction & filtration) • Check disinfection levels in Reservoir and top up if required (Refer Reservoir Manual Chlorine Dose Calculator) • Check integrity of CWT for any breaches or unauthorised access • Conduct sampling and flushing in the network as required • Complete '<i>Initial Incident Report Form</i>' following confirmation of online result with grab sample 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level corrective steps • Test for total chlorine if free chlorine is >4 mg/L. Total chlorine should not be >5 mg/L. • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible. • Consider taking micro-sample for low disinfection levels • Process Engineer or Manager to contact local PHU as soon as possible • Contact DoI for operational advice as needed. • Implement additional response actions (e.g. boil water alert) in consultation with local PHU. • Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample. 	

Table A.6.4 SOP for BB CCP5 Reservoir Integrity at all Reservoirs

Water Scheme	Bellbrook		
CCP ID	CCP5		
What is the control point?	Reservoir	What are the hazards?	All pathogens and all chemicals
What is being monitored?	Reservoir integrity	Monitoring Frequency:	Monthly
Monitoring location	All service reservoirs		
What will initiate response?	Any sign of reservoir integrity breach		
Operating Target No breach of integrity	Adjustment Limit Any sign of integrity breach	Critical Limit Evidence of contamination	
<ul style="list-style-type: none"> Reservoir inspection program (routine) with records maintained Scheduled contractor reservoir cleaning and inspection program 	<p>Corrective actions</p> <ul style="list-style-type: none"> Conduct visual inspection (outside & inside) Check disinfection levels in Reservoir and top up if required (Refer to Reservoir Manual Chlorine Dose Calculator) Increase chlorine dose at plant, if needed Contact Team Leader Repair breach of integrity Consider notifying local PHU Complete '<i>Initial Incident Report Form</i>' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level corrective actions Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Take micro-sample if required Remove contaminants, if safe to do so Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU Complete '<i>Initial Incident Report Form</i>' 	

Table A.7 CCP Willawarrin Water Supply

System	CCP ID	Control Point	Control Parameter	Testing Location	Frequency	Target	Alert Level	Critical Limit	Justification for critical limit
Willawarrin	CCP1	Raw Water Abstraction	Turbidity	Raw water rising main prior to chlorine injection	Daily grab	<0.6 NTU	1 NTU	2 NTU	There is no filtration undertaken, critical limit provides an interim barrier to control contaminant/ microbial load. Plant is shut off at critical limit.
	CCP2	Filtration	Turbidity	NA	NA	NA	NA	NA	NA
	CCP3	Disinfection	Free Chlorine	Willawarrin reservoir outlet	Continuous online / daily grab	1 mg/L	<0.6 or >3.0 mg/L	<0.4 or >4 mg/L	Lower critical chlorine limit ensures that C.t is met at the monitoring location. Upper critical chlorine limit ensures that total chlorine does not get >5 mg/L (health limit). No pH correction undertaken. [Note: online result is verified with grab sample].
	CCP4	Fluoridation	Fluoride	NA	NA	NA	NA	NA	NA
	CCP5	Reservoirs	Reservoir integrity	All reservoirs	Monthly	No breach of integrity	Any sign of integrity breach	Evidence of contamination	Upon advice from NSW Health. Ensures treated water does not get re-contaminated.

Note: Grab sample is taken daily (7 days/week). Disinfection CCP has continuous online monitoring.

Table A.7.1 SOP for WW CCP1 Turbidity Raw Water Abstraction at Raw Water Rising Main

Water Scheme	Willawarrin		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Daily grab (7 days)
Monitoring location	Raw water rising main prior to chlorine injection		
What will initiate response?	Confirmation with immediate follow up grab sample		

Operating Target <0.6 NTU	Alert Level 1 NTU	Critical Limit 2 NTU
<ul style="list-style-type: none"> Weather and flood warning observations Routine site and operational checks Instrument calibration and records maintained Monitor and measure raw water turbidity Equipment correlation checks Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) Visual checks at Bore sites and Bore water monitoring program Operational requirement to maintain Willawarrin Reservoir as full as possible at close of business day 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm result with portable instrument Check turbidity and disinfection levels in Reservoir Attend site and check river quality and river levels Contact Team Leader Check individual production Bores for turbidity & iron (scour to waste during tests) and isolate where required Shut down bore pumps if required Flush rising main to remove highly turbid water (using scour at plant) Consider shutting Dosing Plant down Initiate water carting protocol (on standby) Complete 'Initial Incident Report Form', following confirmation of result with re-test sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Continue water carting until raw water turbidity drops below 1 NTU Shutdown the system Check turbidity levels downstream to validate any infiltration to Dosing Plant Consider isolation & scour the Balance Reservoir Process Engineer or Manager to call local PHU as soon as possible. Contact Dol for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with PHU. Complete 'Initial Incident Report Form', following confirmation of result with re-test sample.

Table A.7.2 SOP for WW CCP3 Free Chlorine Disinfection at Reservoir

Water Scheme	Willawarrin		
CCP ID	CCP3		
What is the control point?	Disinfection	What are the hazards?	Chlorine sensitive pathogens
What is being monitored?	Free chlorine residual	Monitoring Frequency:	Continuous online/daily grab (7 days)
Monitoring location	Willawarrin reservoir outlet		
What will initiate response?	Confirmation of online result with grab sample		

Operating Target 1 mg/L	Alert Limit <0.6 or >3.0 mg/L	Critical Limit <0.4 or >4 mg/L
<ul style="list-style-type: none"> • Routine site and equipment <u>checks</u> • Instrument calibration and records maintained • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) • Sodium Hypochlorite dose rate checks • Disinfection residual checks performed at the outlet of Reservoir • Chemical procurement and delivery requirements • Sodium Hypochlorite chemical handling and dilution 1:5 requirements • Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractor) • Chemical storage levels monitoring 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Confirm online result with grab sample. • Validate disinfection levels (using high ranges or dilution methods if required) • Check primary dosing equipment and hypo concentration and adjust as required • Contact Team Leader • Check disinfection levels from primary dosing and adjust as required • Check raw water conditions • Check disinfection levels in Reservoir and top up if required (Refer Reservoir Manual Chlorine Dose Calculator) • Check integrity of Reservoir for any breaches or unauthorised access • Consider scouring, flushing and sampling in the network where appropriate • Complete 'Initial Incident Report Form', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> • Follow Alert Level steps • Test for total chlorine if free chlorine is >4 mg/L. Total chlorine should not be >5 mg/L. • Contact Team Leader • Team Leader to inform Process Engineer or Manager as soon as possible. • Consider taking micro-sample for low disinfection levels • Process Engineer or Manager to call local PHU as soon as possible. • Contact Dol for operational advice as needed. • Implement additional response actions (e.g. boil water alert) in consultation with local PHU. • Complete 'Initial Incident Report Form', following confirmation of online result with grab sample.

Table A.7.3 SOP for WW CCP5 Reservoir Integrity at Reservoir

Water Scheme	Willawarrin		
CCP ID	CCP5		
What is the control point?	Reservoir	What are the hazards?	All pathogens and all chemicals
What is being monitored?	Reservoir integrity	Monitoring Frequency:	Monthly
Monitoring location	All service reservoirs		
What will initiate response?	Any sign of reservoir integrity breach		

Operating Target No breach of integrity	Adjustment Limit Any sign of integrity breach	Critical Limit Evidence of contamination
<ul style="list-style-type: none"> Reservoir inspection program (routine) with records maintained Scheduled contractor reservoir cleaning and inspection program <p>Note: Water caters have access to Reservoir during high turbidity events</p>	<p>Corrective actions</p> <ul style="list-style-type: none"> Conduct visual inspection (outside & inside) Check disinfection levels in Reservoir and top up if required (Refer to Reservoir Manual Chlorine Dose Calculator) Increase chlorine dose at plant, if needed Contact Team Leader Repair breach of integrity Consider notifying local PHU Complete 'Initial Incident Report Form' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level corrective actions Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Take micro-sample if required Remove contaminants, if safe to do so Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete 'Initial Incident Report Form'

Table A.8 Thungutti Water Supply

System	CCP ID	Control Point	Control Parameter	Testing Location	Frequency	Target	Alert Level	Critical Limit	Justification for critical limit
Thungutti	CCP1	Raw Water Abstraction	Turbidity	Inlet to treatment plant	Continuous online / grab sample	<0.5 NTU	0.8 NTU	1 NTU	There is no filtration undertaken, critical limit provides an interim barrier to control contaminant/ microbial load. Plant is shut off at critical limit. [Note: online result is verified with grab sample].
	CCP2	Filtration	Turbidity	NA	NA	NA	NA	NA	NA
	CCP3	Disinfection	Free Chlorine	At reservoir outlet (bores should be run during off peak usage time – night)	Continuous online / Grab sample	1.0 mg/L	<0.8 or >3.0 mg/L	<0.3 or >4 mg/L	Lower critical chlorine limit ensures that C.t is met at the monitoring location. Upper critical chlorine limit ensures that total chlorine does not get >5 mg/L (health limit). No pH correction undertaken. [Note: online result is verified with grab sample].
	CCP4	Fluoridation	Fluoride	NA	NA	NA	NA	NA	NA
	CCP5	Reservoirs	Reservoir integrity	All reservoirs	Monthly	No breach of integrity	Any sign of integrity breach	Evidence of contamination	Upon advice from NSW Health. Ensures treated water does not get contaminated.

Note: Grab sample is taken 5 days/week (Mon-Fri). Raw Water Abstraction and Disinfection CCPs have continuous online monitoring.

Table A.8.1 SOP for TH CCP1 Turbidity Raw Water Abstraction at Inlet to WTP

Water Scheme	Thungutti		
CCP ID	CCP1		
What is the control point?	Raw Water Abstraction	What are the hazards?	All pathogens
What is being monitored?	Turbidity	Monitoring Frequency:	Continuous online & daily grab (5 days)
Monitoring location	Inlet to Dosing Plant – raw water pre disinfection		
What will initiate response?	Confirmation of online result with grab sample		
Operating Target <0.5 NTU	Alert Level 0.8 NTU	Critical Limit 1 NTU	
<ul style="list-style-type: none"> Weather and flood monitoring observations Routine site and operational checks Instrument calibration and records maintained Monitor and measure raw water turbidity Equipment correlation checks Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) Visual checks at Bore site and Bore water monitoring program 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm result with portable instrument Clean turbidity sensor if needed Contact Team Leader Check creek for any water quality impacts, such as flooding Check individual production Bores for turbidity & iron and isolate where required Consider shutting Dosing Plant down Shutdown bore pumps (if required) and organise repairs (if required) Consider flushing rising main to remove highly turbid water Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Ensure automatic interlock has shut down the treatment plant, otherwise shutdown the system Check turbidity levels downstream to validate any infiltration to the reservoirs (if automatic shutdown has failed) Commence and continue water carting until raw water turbidity drops to below 1 NTU Consider isolation & scour the Reservoir/s Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete '<i>Initial Incident Report Form</i>', following confirmation of online result with grab sample. 	

Table A.8.2 SOP for TH CCP3 Free Chlorine Disinfection at Inlet Reservoir

Water Scheme	Thungutti		
CCP ID	CCP3		
What is the control point?	Disinfection (sodium hypochlorite)	What are the hazards?	Chlorine sensitive pathogens
What is being monitored?	Free chlorine residual	Monitoring Frequency:	Continuous online & daily grab (5 days)
Monitoring location	At reservoir outlet (bores are run during off peak usage time – night)		
What will initiate response?	Confirmation of online result with grab sample		



Operating Target	Alert Limit	Critical Limit
1 mg/L	<0.8 or >3.0 mg/L	<0.3 or >4 mg/L
<ul style="list-style-type: none"> Routine site and equipment checks Instrument calibration and records maintained Calibration of online instruments (Programmed Instrument Maintenance Program conducted by Instrument Technicians and external contractors) Sodium Hypochlorite dose rate checks Disinfection residual checks performed at the outlet of Reservoir Chemical procurement and delivery requirements Chemical storage levels monitoring 	<p>Corrective actions</p> <ul style="list-style-type: none"> Confirm online result with grab sample Validate disinfection levels (using high ranges or dilution methods if required) Check primary dosing equipment and hypo concentration and adjust as required Contact Team Leader Check disinfection levels from primary dosing and adjust as required Check raw water conditions Check disinfection levels in Reservoir and top up if required (Refer Reservoir Manual Chlorine Dose Calculator) Check integrity of Reservoir for any breaches or unauthorised access Consider scouring, flushing and sampling in the network where appropriate Complete <i>'Initial Incident Report Form'</i>, following confirmation of online result with grab sample. 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level steps Test for total chlorine if free chlorine is >4 mg/L. Total chlorine should not be >5 mg/L. Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Consider taking micro-sample for low disinfection levels Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete <i>'Initial Incident Report Form'</i>, following confirmation of online result with grab sample.

Table A.8.3 SOP for TH CCP5 Reservoir Integrity at Reservoir

Water Scheme	Thungutti		
CCP ID	CCP5		
What is the control point?	Reservoir	What are the hazards?	All pathogens and all chemicals
What is being monitored?	Reservoir integrity	Monitoring Frequency:	Monthly
Monitoring location	All service reservoirs		
What will initiate response?	Any sign of reservoir integrity breach		

Operating Target No breach of integrity	Adjustment Limit Any sign of integrity breach	Critical Limit Evidence of contamination
<ul style="list-style-type: none"> Reservoir inspection program (routine) with records maintained Scheduled contractor reservoir cleaning and inspection program Note: Water caters have access to Reservoir during high turbidity events 	<p>Corrective actions</p> <ul style="list-style-type: none"> Conduct visual inspection (outside & inside) Check disinfection levels in Reservoir and top up if required (Refer to Reservoir Manual Chlorine Dose Calculator) Increase chlorine dose at plant, if needed Contact Team Leader Repair breach of integrity Consider notifying local PHU Complete '<i>Initial Incident Report Form</i>' 	<p>Corrective actions</p> <ul style="list-style-type: none"> Follow Alert Level corrective actions Contact Team Leader Team Leader to inform Process Engineer or Manager as soon as possible. Take micro-sample if required Remove contaminants, if safe to do so Process Engineer or Manager to call local PHU as soon as possible. Contact DoI for operational advice as needed. Implement additional response actions (e.g. boil water alert) in consultation with local PHU. Complete '<i>Initial Incident Report Form</i>'

Appendix B Steuart McIntyre Dam Algae Monitoring




Figure B.1: Steuart McIntyre Dam Total Cyanobacteria Biovolume and Alert Levels (Sep 2015 to June 2021)




Figure B.2: Total Phytoplankton and Taste and Odour Results at Tower Intake (July 2015 to June 2021). Algae samples taken from boat using 5m integrated collection method.

Appendix C Water Quality Verification Data

Data from Kempsey Shire Council network sampling sites has been collected from NSW Health Database covering the eight drinking water supply systems.

Results in each monitoring program (Physical-Chemical Monitoring, Microbiological Monitoring and Fluoride Monitoring) are attributed to specific sampling regimes.

Turbidity, pH and Fluoride are monitored in two sections, due to the difference in sampling regimes (indicated by the sample count) results of the analysts vary between monitoring programmes.

Fluoride is tested in all supply systems as a standard chemical test as a part of the Physical-Chemical Monitoring.

Fluoride Monitoring only occurs in the fluoride dosed supply system of South West Rocks.

Table C.1 Kempsey & Lower Macleay Supply System Water Quality Data

Characteristic	Guideline Value	Units	Mean	Min	Max	Sample Count	Exception Count	% Meeting Guidelines
Chemistry								
Aluminium	0.2	mg/L	0.02	0.01	0.05	12	0	100
Antimony	0.003	mg/L	0.0005	0.0003	0.0007	12	0	100
Arsenic	0.01	mg/L	0.0007	0.0005	0.002	12	0	100
Barium	2	mg/L	0.0182	0.0135	0.0276	12	0	100
Boron	4	mg/L	0.0177	0.0074	0.0247	12	0	100
Cadmium	0.002	mg/L	0.0001	0.00005	0.0003	12	0	100
Calcium	10000	mg/L	28.9	18.2	37.5	12	0	100
Chloride	250	mg/L	22	18	27	12	0	100
Chromium	0.05	mg/L	0.001	0.0005	0.003	12	0	100
Copper	2	mg/L	0.06	0.003	0.279	12	0	100
Fluoride	1.5	mg/L	0.05	0.05	0.05	12	0	100
Iodine	0.5	mg/L	0.01	0.01	0.01	12	0	100
Iron	0.3	mg/L	0.013	0.005	0.04	12	0	100
Lead	0.01	mg/L	0.0007	0.0001	0.0021	12	0	100
Magnesium	10000	mg/L	6.66	5.03	9.47	12	0	100
Manganese	0.5	mg/L	0.003	0.0011	0.0082	12	0	100
Mercury	0.001	mg/L	0.0004	0.0004	0.0004	12	0	100
Molybdenum	0.05	mg/L	0.0009	0.0002	0.0037	12	0	100
Nickel	0.02	mg/L	0.0044	0.0002	0.0302	12	1	91.67
Nitrate	50	mg/L	5	2	13	12	0	100
Nitrite	3	mg/L	0.05	0.05	0.05	12	0	100
pH	6.5 - 8.5		7.4	7.2	7.7	12	0	100
Selenium	0.01	mg/L	0.0035	0.0035	0.0035	12	0	100
Silver	0.1	mg/L	0.0001	0.0001	0.0001	12	0	100
Sodium	180	mg/L	15	12	21	12	0	100
Sulfate	500	mg/L	10	9	11	12	0	100
Total Dissolved Solids (TDS)	600	mg/L	136	119	172	12	0	100
Total Hardness as CaCO ₃	200	mg/L	99.5	66.2	132.6	12	0	100
True Colour	15	Hazen Units	0.7	0.5	2	12	0	100
Turbidity	5	NTU	0.31	0.05	0.8	12	0	100
Uranium	0.017	mg/L	0.0001	0.00005	0.0001	12	0	100
Zinc	3	mg/L	0.11	0.06	0.2	12	0	100
Microbiology								
E. coli	0	mpn/100 mL	0	0	0	162	0	100
Total Coliforms	0	mpn/100 mL	0	0	1	162	3	98.15
Free Chlorine	0.2 - 5	mg/L	1.23	0.47	2.01	162	0	100
Total Chlorine	5	mg/L	1.35	0.27	2.1	162	0	100
pH	6.5 - 8.5		7.17	6.57	8.12	162	0	100
Temperature	30	C	20.1	13.9	28.5	162	0	100
Turbidity	5	NTU	0.73	0.11	3.39	161	0	100

Table C.2 Crescent Head Supply System Water Quality Data

Characteristic	Guideline Value	Units	Mean	Min	Max	Sample Count	Exception Count	% Meeting Guidelines
Chemistry								
Aluminium	0.2	mg/L	0.11	0.1	0.11	2	0	100
Antimony	0.003	mg/L	0.0001	0.00005	0.00005	2	0	100
Arsenic	0.01	mg/L	0.0008	0.0005	0.001	2	0	100
Barium	2	mg/L	0.0041	0.0034	0.0047	2	0	100
Boron	4	mg/L	0.0105	0.0053	0.0157	2	0	100
Cadmium	0.002	mg/L	0.0001	0.00005	0.00005	2	0	100
Calcium	10000	mg/L	8.7	8.5	8.8	2	0	100
Chloride	250	mg/L	42	41	42	2	0	100
Chromium	0.05	mg/L	0.001	0.001	0.001	2	0	100
Copper	2	mg/L	0.0055	0.003	0.008	2	0	100
Fluoride	1.5	mg/L	0.05	0.05	0.05	2	0	100
Iodine	0.5	mg/L	0.01	0.01	0.01	2	0	100
Iron	0.3	mg/L	0.09	0.05	0.13	2	0	100
Lead	0.01	mg/L	0.0009	0.0008	0.001	2	0	100
Magnesium	10000	mg/L	1.79	1.73	1.84	2	0	100
Manganese	0.5	mg/L	0.0035	0.0026	0.0043	2	0	100
Mercury	0.001	mg/L	0.0004	0.0004	0.0004	2	0	100
Molybdenum	0.05	mg/L	0.0001	0.0001	0.0001	2	0	100
Nickel	0.02	mg/L	0.0002	0.0002	0.0002	2	0	100
Nitrate	50	mg/L	0.5	0.5	0.5	2	0	100
Nitrite	3	mg/L	0.05	0.05	0.05	2	0	100
pH	6.5 - 8.5		6.8	6.8	6.8	2	0	100
Selenium	0.01	mg/L	0.0035	0.0035	0.0035	2	0	100
Silver	0.1	mg/L	0.0001	0.0001	0.0001	2	0	100
Sodium	180	mg/L	16	16	16	2	0	100
Sulfate	500	mg/L	1	1	1	2	0	100
Total Dissolved Solids (TDS)	600	mg/L	76	73	78	2	0	100
Total Hardness as CaCO ₃	200	mg/L	29	28.8	29.1	2	0	100
True Colour	15	Hazen Units	5	4	5	2	0	100
Turbidity	5	NTU	1.1	1	1.2	2	0	100
Uranium	0.017	mg/L	0.0001	0.0001	0.0001	2	0	100
Zinc	3	mg/L	0.07	0.05	0.08	2	0	100
Microbiology								
E. coli	0	mpn/100 mL	0	0	0	63	0	100
Total Coliforms	0	mpn/100 mL	0	0	0	63	0	100
Free Chlorine	0.2 - 5	mg/L	1.09	0.01	2.3	63	3	95.24
Total Chlorine	5	mg/L	1.3	0.2	2.7	63	0	100
pH	6.5 - 8.5		19.3	13.9	25.4	63	0	100
Temperature	30	C	2.09	0.91	4.89	63	0	100
Turbidity	5	NTU	0	0	0	63	0	100

Table C.3 Hat Head Supply System Water Quality Data

Characteristic	Guideline Value	Units	Mean	Min	Max	Sample Count	Exception Count	% Meeting Guidelines
Chemistry								
Aluminium	0.2	mg/L	0.095	0.09	0.1	2	0	100
Antimony	0.003	mg/L	0.0001	0.00005	0.00005	2	0	100
Arsenic	0.01	mg/L	0.001	0.001	0.001	2	0	100
Barium	2	mg/L	0.0132	0.012	0.0144	2	0	100
Boron	4	mg/L	0.0135	0.0095	0.0175	2	0	100
Cadmium	0.002	mg/L	0.0001	0.00005	0.00005	2	0	100
Calcium	10000	mg/L	1.5	1.4	1.5	2	0	100
Chloride	250	mg/L	68	67	69	2	0	100
Chromium	0.05	mg/L	0.0005	0.0005	0.0005	2	0	100
Copper	2	mg/L	0.01	0.01	0.01	2	0	100
Fluoride	1.5	mg/L	0.05	0.05	0.05	2	0	100
Iodine	0.5	mg/L	0.01	0.01	0.01	2	0	100
Iron	0.3	mg/L	0.11	0.06	0.16	2	0	100
Lead	0.01	mg/L	0.0004	0.0003	0.0004	2	0	100
Magnesium	10000	mg/L	3.23	2.99	3.46	2	0	100
Manganese	0.5	mg/L	0.0058	0.0057	0.0058	2	0	100
Mercury	0.001	mg/L	0.0004	0.0004	0.0004	2	0	100
Molybdenum	0.05	mg/L	0.0001	0.0001	0.0001	2	0	100
Nickel	0.02	mg/L	0.0005	0.0002	0.0007	2	0	100
Nitrate	50	mg/L	0.5	0.5	0.5	2	0	100
Nitrite	3	mg/L	0.05	0.05	0.05	2	0	100
pH	6.5 - 8.5		7.6	7.5	7.7	2	0	100
Selenium	0.01	mg/L	0.0035	0.0035	0.0035	2	0	100
Silver	0.1	mg/L	0.0001	0.0001	0.0001	2	0	100
Sodium	180	mg/L	35	35	35	2	0	100
Sulfate	500	mg/L	8	7	8	2	0	100
Total Dissolved Solids (TDS)	600	mg/L	127	121	132	2	0	100
Total Hardness as CaCO ₃	200	mg/L	16.9	15.8	18	2	0	100
True Colour	15	Hazen Units	3	1	4	2	0	100
Turbidity	5	NTU	0.33	0.05	0.6	2	0	100
Uranium	0.017	mg/L	0.0001	0.00005	0.00005	2	0	100
Zinc	3	mg/L	0.02	0.01	0.02	2	0	100
Microbiology								
E. coli	0	mpn/100 mL	0	0	0	27	0	100
Total Coliforms	0	mpn/100 mL	0	0	0	27	0	100
Free Chlorine	0.2 - 5	mg/L	0.99	0.38	1.48	27	0	100
Total Chlorine	5	mg/L	1.09	0.43	1.58	27	0	100
pH	6.5 - 8.5		7.46	7	8.71	27	1	96.3
Temperature	30	C	21.1	14.3	26	27	0	100
Turbidity	5	NTU	0.57	0.13	2.75	26	0	100

Table C.4 South West Rocks Supply System Water Quality Data

Characteristic	Guideline Value	Units	Mean	Min	Max	Sample Count	Exception Count	% Meeting Guidelines
Chemistry								
Aluminium	0.2	mg/L	0.03	0.02	0.06	12	0	100
Antimony	0.003	mg/L	0.0001	0.00005	0.0001	12	0	100
Arsenic	0.01	mg/L	0.001	0.0005	0.001	12	0	100
Barium	2	mg/L	0.0105	0.0068	0.015	12	0	100
Boron	4	mg/L	0.0139	0.0018	0.0196	12	0	100
Cadmium	0.002	mg/L	0.0001	0.00005	0.0002	12	0	100
Calcium	10000	mg/L	12.7	10	24.1	12	0	100
Chloride	250	mg/L	34	31	38	12	0	100
Chromium	0.05	mg/L	0.001	0.0005	0.005	12	0	100
Copper	2	mg/L	0.005	0.001	0.021	12	0	100
Fluoride	1.5	mg/L	0.94	0.86	1	12	0	100
Fluoride (WU result)	1.5	mg/L	0.98	0.94	1.01	12	0	100
Fluoride Ratio	0.8 - 1.2	mg/L	1.04	0.97	1.11	12	0	100
Iodine	0.5	mg/L	0.01	0.01	0.01	12	0	100
Iron	0.3	mg/L	0.021	0.005	0.08	12	0	100
Lead	0.01	mg/L	0.0002	0.0001	0.0006	12	0	100
Magnesium	10000	mg/L	1.71	1.07	2.3	12	0	100
Manganese	0.5	mg/L	0.0011	0.00015	0.0035	12	0	100
Mercury	0.001	mg/L	0.0004	0.0004	0.0004	12	0	100
Molybdenum	0.05	mg/L	0.0008	0.0001	0.0063	12	0	100
Nickel	0.02	mg/L	0.0028	0.0002	0.0227	12	1	91.67
Nitrate	50	mg/L	0.5	0.5	0.5	12	0	100
Nitrite	3	mg/L	0.05	0.05	0.05	12	0	100
pH	6.5 - 8.5		7.6	7.3	7.9	12	0	100
Selenium	0.01	mg/L	0.0035	0.0035	0.0035	12	0	100
Silver	0.1	mg/L	0.0001	0.0001	0.0001	12	0	100
Sodium	180	mg/L	20	19	23	12	0	100
Sulfate	500	mg/L	3	3	4	12	0	100
Total Dissolved Solids (TDS)	600	mg/L	91	80	111	12	0	100
Total Hardness as CaCO3	200	mg/L	38.8	31.1	69.6	12	0	100
True Colour	15	Hazen Units	0.7	0.5	1	12	0	100
Turbidity	5	NTU	0.23	0.05	0.8	12	0	100
Uranium	0.017	mg/L	0.0001	0.00005	0.0001	12	0	100
Zinc	3	mg/L	0.06	0.03	0.12	12	0	100
Microbiology								
E. coli	0	mpn/100 mL	0	0	0	64	0	100
Total Coliforms	0	mpn/100 mL	0	0	0	64	0	100
Free Chlorine	0.2 - 5	mg/L	0.95	0.21	1.59	64	0	100
Total Chlorine	5	mg/L	1.05	0.38	1.63	64	0	100
pH	6.5 - 8.5		7.5	7.09	8.35	63	0	100
Temperature	30	C	20.75	0.43	27	63	0	100
Turbidity	5	NTU	0.28	0.06	0.86	63	0	100
Fluoride Operational Monitoring								
Fluoride (daily WU)	0.9 - 1.5	mg/L	1.01	0.90	1.2	359	0	100
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.98	0.92	1.05	107	0	100

Table C.5 Stuarts Point Supply System Water Quality Data

Characteristic	Guideline Value	Units	Mean	Min	Max	Sample Count	Exception Count	% Meeting Guidelines
Chemistry								
Aluminium	0.2	mg/L	0.005	0.005	0.005	13	0	100
Antimony	0.003	mg/L	0.0001	0.00005	0.00005	13	0	100
Arsenic	0.01	mg/L	0.001	0.0005	0.001	13	0	100
Barium	2	mg/L	0.0135	0.0105	0.0178	13	0	100
Boron	4	mg/L	0.0201	0.0071	0.0246	13	0	100
Cadmium	0.002	mg/L	0.0001	0.00005	0.0001	13	0	100
Calcium	10000	mg/L	49.7	41.6	58.3	13	0	100
Chloride	250	mg/L	36	33	39	13	0	100
Chromium	0.05	mg/L	0.0007	0.0005	0.001	13	0	100
Copper	2	mg/L	0.0223	0.002	0.061	13	0	100
Fluoride	1.5	mg/L	0.05	0.05	0.05	13	0	100
Iodine	0.5	mg/L	0.01	0.01	0.01	13	0	100
Iron	0.3	mg/L	0.017	0.005	0.08	13	0	100
Lead	0.01	mg/L	0.001	0.0001	0.004	13	0	100
Magnesium	10000	mg/L	2.88	2.63	3.46	13	0	100
Manganese	0.5	mg/L	0.0005	0.00015	0.0019	13	0	100
Mercury	0.001	mg/L	0.0004	0.0004	0.0004	13	0	100
Molybdenum	0.05	mg/L	0.0006	0.0003	0.0019	13	0	100
Nickel	0.02	mg/L	0.0014	0.0006	0.0061	13	0	100
Nitrate	50	mg/L	0.5	0.5	0.5	13	0	100
Nitrite	3	mg/L	0.05	0.05	0.05	13	0	100
pH	6.5 - 8.5		7.7	7.5	7.9	13	0	100
Selenium	0.01	mg/L	0.0035	0.0035	0.0035	13	0	100
Silver	0.1	mg/L	0.0001	0.0001	0.0001	13	0	100
Sodium	180	mg/L	16	3	20	13	0	100
Sulfate	500	mg/L	5	4	5	13	0	100
Total Dissolved Solids (TDS)	600	mg/L	180	167	188	13	0	100
Total Hardness as CaCO ₃	200	mg/L	136.0	115.9	159.8	13	0	100
True Colour	15	Hazen Units	0.6	0.5	1	13	0	100
Turbidity	5	NTU	0.23	0.05	0.7	13	0	100
Uranium	0.017	mg/L	0.0002	0.0001	0.0008	13	0	100
Zinc	3	mg/L	0.16	0.11	0.24	13	0	100
Microbiology								
E. coli	0	mpn/100 mL	0	0	0	50	0	100
Total Coliforms	0	mpn/100 mL	0	0	0	50	0	100
Free Chlorine	0.2 - 5	mg/L	0.98	0.77	1.22	50	0	100
Total Chlorine	5	mg/L	1.09	0.84	1.33	50	0	100
pH	6.5 - 8.5		7.50	7.29	7.71	50	0	100
Temperature	30	C	20	13.4	24.2	50	0	100
Turbidity	5	NTU	0.20	0.08	0.38	45	0	100

Table C.6 Willawarrin Supply System Water Quality Data

Characteristic	Guideline Value	Units	Mean	Min	Max	Sample Count	Exception Count	% Meeting Guidelines
Chemistry								
Aluminium	0.2	mg/L	0.011	0.005	0.04	13	0	100
Antimony	0.003	mg/L	0.001	0.0006	0.0013	13	0	100
Arsenic	0.01	mg/L	0.002	0.001	0.004	13	0	100
Barium	2	mg/L	0.0155	0.0126	0.0195	13	0	100
Boron	4	mg/L	0.0154	0.0099	0.0239	13	0	100
Cadmium	0.002	mg/L	0.0001	0.00005	0.00005	13	0	100
Calcium	10000	mg/L	19.0	12.7	37.7	13	0	100
Chloride	250	mg/L	18	13	27	13	0	100
Chromium	0.05	mg/L	0.0012	0.0005	0.006	13	0	100
Copper	2	mg/L	0.033	0.009	0.051	13	0	100
Fluoride	1.5	mg/L	0.05	0.05	0.05	13	0	100
Iodine	0.5	mg/L	0.01	0.01	0.02	13	0	100
Iron	0.3	mg/L	0.015	0.005	0.05	13	0	100
Lead	0.01	mg/L	0.0017	0.0003	0.0055	13	0	100
Magnesium	10000	mg/L	5.78	4.66	9.03	13	0	100
Manganese	0.5	mg/L	0.0141	0.0026	0.0627	13	0	100
Mercury	0.001	mg/L	0.0004	0.0004	0.0004	13	0	100
Molybdenum	0.05	mg/L	0.0007	0.0001	0.0051	13	0	100
Nickel	0.02	mg/L	0.0025	0.0002	0.0204	13	1	92.31
Nitrate	50	mg/L	3.3	0.5	10	13	0	100
Nitrite	3	mg/L	0.05	0.05	0.05	13	0	100
pH	6.5 - 8.5		7.2	6.6	7.8	13	0	100
Selenium	0.01	mg/L	0.0038	0.0035	0.008	13	0	100
Silver	0.1	mg/L	0.0001	0.0001	0.0001	13	0	100
Sodium	180	mg/L	14	5	19	13	0	100
Sulfate	500	mg/L	10	7	13	13	0	100
Total Dissolved Solids (TDS)	600	mg/L	103	82	151	13	0	100
Total Hardness as CaCO ₃	200	mg/L	71.3	50.9	131.3	13	0	100
True Colour	15	Hazen Units	0.9	0.5	1	13	0	100
Turbidity	5	NTU	0.43	0.05	1	13	0	100
Uranium	0.017	mg/L	0.0001	0.00005	0.0001	13	0	100
Zinc	3	mg/L	0.08	0.05	0.13	13	0	100
Microbiology								
E. coli	0	mpn/100 mL	0	0	0	26	0	100
Total Coliforms	0	mpn/100 mL	0	0	0	26	0	100
Free Chlorine	0.2 - 5	mg/L	0.93	0.51	1.4	26	0	100
Total Chlorine	5	mg/L	1.1	0.6	1.59	26	0	100
pH	6.5 - 8.5		6.92	6.33	7.54	26	5	80.77
Temperature	30	C	17.0	8.2	24.8	26	0	100
Turbidity	5	NTU	0.5	0.2	1.56	26	0	100

Table C.7 Bellbrook Supply System Water Quality Data

Characteristic	Guideline Value	Units	Mean	Min	Max	Sample Count	Exception Count	% Meeting Guidelines
Chemistry								
Aluminium	0.2	mg/L	0.012	0.005	0.03	12	0	100
Antimony	0.003	mg/L	0.0002	0.00005	0.0005	12	0	100
Arsenic	0.01	mg/L	0.0008	0.0005	0.003	12	0	100
Barium	2	mg/L	0.0203	0.0131	0.0257	12	0	100
Boron	4	mg/L	0.0147	0.0042	0.0298	12	0	100
Cadmium	0.002	mg/L	0.0001	0.00005	0.00005	12	0	100
Calcium	10000	mg/L	20.0	9.1	36.1	12	0	100
Chloride	250	mg/L	29	24	33	12	0	100
Chromium	0.05	mg/L	0.0014	0.0005	0.003	12	0	100
Copper	2	mg/L	0.014	0.005	0.028	12	0	100
Fluoride	1.5	mg/L	0.05	0.05	0.05	12	0	100
Iodine	0.5	mg/L	0.01	0.01	0.01	12	0	100
Iron	0.3	mg/L	0.025	0.005	0.18	12	0	100
Lead	0.01	mg/L	0.0006	0.0001	0.0017	12	0	100
Magnesium	10000	mg/L	6.12	3.35	8.81	12	0	100
Manganese	0.5	mg/L	0.0181	0.0021	0.0611	12	0	100
Mercury	0.001	mg/L	0.0004	0.0004	0.0009	12	0	100
Molybdenum	0.05	mg/L	0.0011	0.00005	0.0032	12	0	100
Nickel	0.02	mg/L	0.0042	0.0002	0.0128	12	0	100
Nitrate	50	mg/L	3.0	0.5	13	12	0	100
Nitrite	3	mg/L	0.05	0.05	0.05	12	0	100
pH	6.5 - 8.5		7.7	7.6	7.9	12	0	100
Selenium	0.01	mg/L	0.0035	0.0035	0.0035	12	0	100
Silver	0.1	mg/L	0.0001	0.0001	0.0001	12	0	100
Sodium	180	mg/L	19	3	25	12	0	100
Sulfate	500	mg/L	7	3	11	12	0	100
Total Dissolved Solids (TDS)	600	mg/L	124	99	161	12	0	100
Total Hardness as CaCO ₃	200	mg/L	75.1	36.5	126.4	12	0	100
True Colour	15	Hazen Units	0.6	0.5	1	12	0	100
Turbidity	5	NTU	0.63	0.05	1.7	12	0	100
Uranium	0.017	mg/L	0.0001	0.00005	0.00005	12	0	100
Zinc	3	mg/L	0.08	0.05	0.17	12	0	100
Microbiology								
E. coli	0	mpn/100 mL	0	0	0	26	0	100
Total Coliforms	0	mpn/100 mL	0	0	0	26	0	100
Free Chlorine	0.2 - 5	mg/L	1.21	0.51	1.82	26	0	100
Total Chlorine	5	mg/L	1.38	0.67	2.14	26	0	100
pH	6.5 - 8.5		7.41	6.98	7.85	26	0	100
Temperature	30	C	17.4	6.8	26.4	26	0	100
Turbidity	5	NTU	0.82	0.32	3.37	26	0	100

Table C.8 Thungutti Supply System Water Quality Data

Characteristic	Guideline Value	Units	Mean	Min	Max	Sample Count	Exception Count	% Meeting Guidelines
Chemistry								
Aluminium	0.2	mg/L	0.008	0.005	0.01	2	0	100
Antimony	0.003	mg/L	0.0002	0.0001	0.0002	2	0	100
Arsenic	0.01	mg/L	0.0005	0.0005	0.0005	2	0	100
Barium	2	mg/L	0.0134	0.0118	0.0149	2	0	100
Boron	4	mg/L	0.013	0.006	0.0192	2	0	100
Cadmium	0.002	mg/L	0.0001	0.00005	0.0001	2	0	100
Calcium	10000	mg/L	8.1	7.9	8.2	2	0	100
Chloride	250	mg/L	19	17	20	2	0	100
Chromium	0.05	mg/L	0.0005	0.0005	0.0005	2	0	100
Copper	2	mg/L	0.043	0.034	0.052	2	0	100
Fluoride	1.5	mg/L	0.05	0.05	0.05	2	0	100
Iodine	0.5	mg/L	0.01	0.01	0.01	2	0	100
Iron	0.3	mg/L	0.0075	0.005	0.01	2	0	100
Lead	0.01	mg/L	0.0006	0.0006	0.0006	2	0	100
Magnesium	10000	mg/L	4.65	4.42	4.88	2	0	100
Manganese	0.5	mg/L	0.0012	0.00015	0.0023	2	0	100
Mercury	0.001	mg/L	0.0004	0.0004	0.0004	2	0	100
Molybdenum	0.05	mg/L	0.0002	0.0001	0.0003	2	0	100
Nickel	0.02	mg/L	0.0009	0.0008	0.0009	2	0	100
Nitrate	50	mg/L	0.8	0.5	1	2	0	100
Nitrite	3	mg/L	0.05	0.05	0.05	2	0	100
pH	6.5 - 8.5		7	7	7	2	0	100
Selenium	0.01	mg/L	0.0035	0.0035	0.0035	2	0	100
Silver	0.1	mg/L	0.0001	0.0001	0.0001	2	0	100
Sodium	180	mg/L	15	14	15	2	0	100
Sulfate	500	mg/L	9	7	11	2	0	100
Total Dissolved Solids (TDS)	600	mg/L	72	65	78	2	0	100
Total Hardness as CaCO ₃	200	mg/L	39.3	38.7	39.8	2	0	100
True Colour	15	Hazen Units	0.5	0.5	0.5	2	0	100
Turbidity	5	NTU	0.3	0.1	0.4	2	0	100
Uranium	0.017	mg/L	0.0001	0.00005	0.0001	2	0	100
Zinc	3	mg/L	0.05	0.04	0.06	2	0	100
Microbiology								
E. coli	0	mpn/100 mL	0	0	0	24	0	100
Total Coliforms	0	mpn/100 mL	0	0	1	24	1	95.83
Free Chlorine	0.2 - 5	mg/L	1.16	0.53	2.06	24	0	100
Total Chlorine	5	mg/L	1.27	0.60	2.15	24	0	100
pH	6.5 - 8.5		6.75	6.40	7.15	24	3	87.50
Temperature	30	C	17.1	7.9	25.8	24	0	100
Turbidity	5	NTU	0.33	0.12	0.74	24	0	100

Appendix D Customer Enquiry Supply Area Descriptions

Table D.1 Customer Enquiry Supply Area Descriptions for KLM Supply System

Supply System	Supply Areas
Kempsey	Kempsey CBD
West Kempsey	West Kempsey & Greenhill
Aldavilla	Aldavilla & Yarravel
Smithtown/Gladstone	Smithtown, Gladstone, Bellimbopinni, Austral Eden
Belmore River	Belmore River
Kinchela	Kinchela, Jerseyville, Rainbow Reach, Summer Island, Seven Oaks & Plumbers Lane
Frederickton	Frederickton, Everinghams Lane, Clybucca
South Kempsey	Dondingalong, Euroka, Burnt Bridge, South Kempsey Service Centre
East Kempsey	East Kempsey, Verges Creek

Appendix E Continuous Improvement - Implementation Plan (IP) Outstanding Actions

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
1.02	All	L	Develop a comprehensive stakeholder/relevant agencies list which identifies all stakeholders who could affect, or be affected by, decisions or activities of the drinking water supplier, identifying the accountabilities and responsibilities of relevant agencies. The list should be stored in the TRIM DWMS document register and referenced in the DWMS and the IERP. Develop a regular review process to update the list of stakeholders	2012	Standing item	List exists, but not completed (not formally), will need to be formalised, will also be included in the DWMP Completed in 2019 DWMS update silt of stakeholder in Overall Manual 2020 - change from completed to an annual review and update of the Overall manual of the stakeholders and Emergency contacts (page 10) - this should be aligned with the DESP document 18/10/21 - this item changed to a "standing item" - contacts are reviewed and updated at least annually - register maintained by WQO
1.04	All Kem	H	KSC is to prepare SOP for the acceptance and delivery of chemicals to treatment sites, including check sheet. Develop a program to undertake spot checks of chemical quality compliance	2012	Ongoing	Under procurement mid ROC process, checklist to be developed, and chemical quality SOP to be developed including QC testing 30/10/19 - SOP currently being developed - Need to make a list of Chemicals that can be spot tested and develop procedure. 23/12/2020 - there is a chemical supply contract with specifications already in place, the SOPs and quality checks still need to be developed (should include a request of certificate of analysis for every delivery) 25/10/2021 - ongoing
1.05	All	H	Standard operational procedures are to be prepared on the sampling and testing program.	2012	Ongoing	Work undertaken; however usable spreadsheets need to be developed & reviewed 30/10/2019 - WaterOutlook look currently being rolled out to capture operational WQ data. Table 3 in each Sup plan captures WQ operational requirements with target levels - SOP are currently being developed for operational and verification monitoring 23/12/2020 - SOPs only remain on this action 25/10/2022 - as comments on 23/12/2020 SOP to be completed

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
1.06	All	H	<p>KSC to document the type of customer complaint relating to water quality issues in the following categories (illness, taste & odour, dirty water, blue water, air or white water, and other), to assist with the characterisation of the issues in the treated water supplies.</p> <p>Water technical operational staffs with appropriate knowledge are to review the incoming complaints, respond to and record relevant water quality data and actions to rectify the issue. Customer complaints database needs development to ensure it contains the ability to extract information for analysis. The record of incoming complaints and response actions will form part of the management reporting requirements.</p>	2012	Ongoing	<p>Customer complaint database must be developed. Currently actions aren't captured, Water section must work with customer service to develop this.</p> <p>30/10/2019 - WQO collates complaints monthly through the crystal report - Update process so that the actions and results are sent to the WQO to report on at the time on complaint - TLW to tool box WO on ensuring full completion of work order that include fault, corrective actions and test results</p> <p>one complete WO to forward work order to WQO to complete and close</p> <p>23/12/2020 - Council has changed to Synergy Soft and the reporting side of the data capture is still being developed - WQO to request from Chris Seam (NC) of notification of all main breaks with details of Location and size pipe and work with Kate to developed spreadsheet for work Order capture of pipe repairs</p> <p>18/10/21 - SS yearly downloads available - working on extracting data on a monthly view WQO to work with Admin officer to better capture information</p>
2.01	Kem	L	<p>KSC to address the long term need for the Belgrave Falls facility and to remove redundant infrastructure if deemed non-operational.</p>	2012	Ongoing	<p>Needs to be fenced, more water quality testing to be undertaken. Decision to be made whether or not to decommission this. Some concerns regarding salinity, Alkalinity, also iron. SWA analysis to be undertaken.</p> <p>31-10-2019 further discussion about the future actions based on pending WQ testing.</p> <p>31/10/2019 - need to confirm with Wes on actions plan for this asset</p> <p>TLW - to arrange WQ Chemistry sampling at this asset whilst in drought conditions</p> <p>23/12/2020 - WQ testing done all OK waiting on IWCM outcomes</p> <p>28/10/2021 As above</p>
2.02	Kem	L	<p>Management to determine the viability of maintaining Kinchela as an emergency supply as the site has operational issues and cannot become operational in a short term.</p>	2012	Ongoing	<p>Still under consideration, issues with high metals in bores, and pressure issues. Last time it was run was around 2004. Studies undertaken, pipes upgrades are being rolled out in that area, so capacity increase could allow the use of this.</p> <p>30-10-2019 - WQ testing current being undertaken due to drought conditions - initial results indicate Bore 1 is not viable due high salinity however other bores seem OK - pending completion of full sampling schedule this assts will most likely be kept and assts maintained and upgraded for use</p> <p>23/12/2020 - Some upgrades have been complete on the back of the 2019/2020 drought, waiting on final report from GHD and implement recommendations</p> <p>28/10/2021 - completion and commission planned before end of 21-22</p>

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.04	All	M	Develop a map of high-risk septic tank locations within the catchment for review by DC (Development and Compliance) for integration into their Septic Tank monitoring program.	2012	Ongoing	Work undertaken, awaiting finalisation 31-10-2019 - Outside Water department this sits with Development and Compliance 23/10/2020 - WQO to talk to C&D and GIS team to have a risk layers in GIS 25/10/2022 - Meeting with C&D held and risk methodology discussed = Risk Team accepted methodology at IP review 25/10/2020 - WQO/OC to stay in loop with high Risk OSMS development program
2.05	All	M	Upgrade existing GIS mapping systems with water infrastructure such as pipelines, easements, valve locations, sampling locations Develop a GIS mapping layer identifying high priority risk zones within catchment.	2012	Ongoing	Will be captured by new GIS 23/12/2020 - TLW to work with GIS team for sampling locations be put into a layer - other items done also refer to above action regarding septic in catchment areas particularly upriver communities 25/10/2022 - confirm that all sample location captured (Lachlan Lyttle) and passed onto GIS team " Water and Sewer sites layers - sewer sites captured in separate program with D&C
2.07	Kem	M	Develop and implement a catchment risk program to identify pathogens of concern in conjunction with NSW Health	2012	Ongoing	Work undertaken, summary not written, and awaiting finalisation. Council to contact Water Futures to discuss finalisation. 23/12/2020 - Report completed, NSW Health Dan Deer to develop a one-off sampling project 28/10/2021 - scoping to confirm catchment risks under the safe and secure funding program for category 5 catchments for chlorine resident pathogens
2.09	Kem	M	Water treatment plant installation for KLM to control pathogens, turbidity, agricultural chemicals and algae.	2012	Ongoing	Expression of interest being completed for concept design for Safe & Secure 31-10-2019 - Funding for emergency plant of 12ML waiting for NSW gov approval. Plant is designed for ease of future expansion to 18ML - If funding granted plant potentially operational by end of July 2020 23/12/2020 - Funding of \$4Mill approved for permanent water treatment plant, options assessment report endorsed by DPE, Concept design tender let and completion due end of 2022 28/10/2021 60% concept design workshop with DPE also safety in design review is competed, concept design due Dec 21

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.12	All	M	SOP to be developed on the operation of the bores and recharge channel includes what to do in floods for bore selection	2012	Ongoing	23/12/2020 = Develop a flood response SOP that covers all supply systems 25/10/2022 - ongoing - TLW - to assign the development of a SOP
2.15	Kem	M	KSC to purchase land surrounding the bore field when the opportunity arises, to isolate external risks.	2012	Ongoing	31/10/2019 - This is a long-term action 23/12/2020 - Desktop evaluations completed - some adjustments needed. Council Paper to Council before June 2021 28/10/21 - ongoing
2.16	All	M	Fencing around bore pumps to restrict animal access. Restrict use of bores where animal access is possible until fencing able to be undertaken	2012	Ongoing	Pending on land purchase for Sherwood 23/12/2020 - Implementation of perimeter fences to be placed on OP plan by TLW 25/10/2022 - not all bores can be fenced (ease access rights) look at feasibility of bores that can be
2.17	All	H	Initiate a Bore inspection and preventative maintenance program.	2012	Ongoing	31-10-2019 - The Bore Inspections have been captured as a monthly task in WaterOutLook which is in the rollout stage - COMPLETED To be developed and actioned by Trades - testing currents, checking the low levels, checking for hot spots, flow switches etc 23/12/2020 - ongoing MC - To be developed and actioned by Trades team - testing currents, checking the low levels, checking for hot spots, flow switches etc 23/09/2021 - Phil (MC) - on-going. working with trades to implement better Preventative Maintenance programs. This has been confirmed at it sits within the Maintenance program
2.19	Kem	L	Program regular maintenance for the SMD off-take gates.	2012	Ongoing	no mechanisms for these operate to maintain tasks to be documented, 31/10/2019 - Council yet to decide on an Asset management system platform, decision pending in the next 6 months 23/12/2020 - Asset management plan developed but current maintenance repairs are being task to TLW 25/10/2021 - ongoing
2.25	Kem	M	Erosion control around SMD to reduce sediment and nutrient loads during wind and rainfall events.	2012	In progress	31/10/2019 Rip Rap wall installed on dam foreshore - ongoing some area yet to be completed 23/12/2020 - this is ongoing 25/10/2021 - dam level currently to high - for continuation of this program - revisits when levels drop

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.28	Kem	L	A routine maintenance schedule for the SMD aeration line blowers to be developed and incorporated into the AMS	2012	Ongoing	Will be captured in AMS, maintenance schedules on hard copies, will be integrated electronically 23/12/2020 - To be included in AMS 25/10/2021 - AMS still being rolled out - Water and Sewer are last on the roll out program
2.29	Kem	L	Develop a response procedure for water source changes in KLM.	2012	In progress	SOP written, requires review 23/12/2020 - WTL to finalise review process 25/10/2022 - SOP done by Network (NC) department needs to be sent to Process (TLW) for collation in process side
2.31	Kem	L	To monitor animal numbers and introduce an 'animal control' program in the secured SMD area when required.	2012	Standing item	Number of Kangaroos decreased, inspections undertaken, fenced and blocked off, ongoing task 1/11/2019 - sufficient controls are in place and kangaroo numbers have been reduced and numbers are continually monitored - ACTION CLOSED 23/12/2020 - Risk Team decided for this to be an ongoing action to keep an eye on animal numbers - animal control program are initiate as required TWL to investigate if this should sit in the OM Dam Manual 25/10/2021 - check with Craig Doyle if there is a mention of animal control in the OM dam Manual - TLW to action, if not add into OM Dam Manual - item changes from "ongoing" to "Standing Item"
2.32	Kem	L	Include SMD perimeter and water surface inspections into site management procedures to monitor and minimise native and feral animal access to storage.	2012	In progress	As above 4/11/2019 - will be added to WaterOutlook WTL to confirm that perimeter fences are in WaterOutlook SMD 2/weekly inspection 25/10/2021 - reviewed not in WaterOutlook TLW to add into WO task list for SafeGroup to action

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.35	All	H	Online monitoring to be installed at Sherwood Lime plant & Greenhill Reservoir to measure and control chlorine dosing. Chlorine gas cylinder scales need to be installed and connected SCADA for remote monitoring. And automatic shutoff for chlorine cylinders	2012	In progress	4/11/2019- further information regarding if we need to have online chlorine at Sherwood (potential new plant and asset no longer needed). Still need online for Green Hill 23/12/2020 - PE = Chlorine audit to be undertaken to comply with new Aust Standards - ME as above 2019 comments 23/09/2021 - Phil (MC) - Online monitoring installed at Green Hill. Waiting for report from Murray to see if we still need to upgrade Sherwood & Bellimbopinni with auto-shutoff valves to CL2 gas cylinders (and any other upgrades).? 18/10/2021 - Chlorine analyser has been programmed the scales and auto shutoff for chlorine gas will be integrated into new plant at SMD
2.39	All	VH	Introduce a 'permit to work' approval system for all maintenance and isolations at key dosing sites. Improve communications between KSC business units for prior notification for all contractor works programmed and include training of all staff on the prior notification of works programmed and site visiting requirements - access permit introduction.	2012	Ongoing	4/11/2019 - Waiting on AMS and MMS to be confirmed and rolled out 03.02.21 - MWS to discuss and provide update with SAP (Erin) 28/10/2021 - Awaiting on AMS rollout
2.4	Kem	L	Introduce a treatment chemical stocktake system to monitor chemical stocks and turnover rates.	2012	Ongoing	Stock is ordered as needed, will be in ongoing list 4/11/2019 - This will be captured in WaterOutLook and removed shortly 3-2-21 - this is to look at chlorine cylinders and how much we are charged - there is no documentation to what is being dropped off at the stores - stock register. KSC also awaiting on chemical report from Murray Thompson in relation to moving, handling of chlorine bottles 18/10/2021 - ongoing - potential to resolve when chlorine will be delivered to SMD only when new plant built
2.41	Kem	L	Install automatic level sensors and alarms for Critical low level on Hypochlorite storage tanks or replace hypo system with chlorine gas system.	2012	In progress	SMD chlorine upgrade project underway 3-2-21 - SMD upgrade project will incorporate chlorine project - currently in concept design 23/09/2021 - Phil (M) - as above Feb comment

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.44	Kem	H	Investigate the possibility of emergency power sources for chemical dosing and transfer pumps to maintain supply and dosing for major reservoirs.	2012	In progress	SWR set up for generator, however investigation outcome was that due to the size required, generators are unrealistic 4/11/2019 - new plant at KLM designed for generator backup Additional consultation needed between Council and Power supplier regarding maximum time that power can be interrupted Future scoping of additional booster pump station for Green Hill Res water security. 23/09/2021 - Phil (MC) - to be a part of SMD WTP. This entire Implementation Plan will need to be brought to the table during the WTP design stage so that items like this are included into the scope of the plant, or, taken into consideration during the design phase
2.49	All	M	Include inspections after all storm event within the Reservoir Inspection Procedure.	2012	In progress	Will be captured in an SOP 4/11/2019 - SOPs are currently being developed and Storm event to be included on the Reservoir Inspection SOP 3-2-21 - in progress to be developed 25/10/2021 - Reservoir SOP to be completed
2.5	All	L	Modification required of inlet/outlets on reservoirs or installation of diversion plates, to prevent sediment disturbance.	2012	In progress	Mixer at Clybucca and John Lane completed, back beach nozzle also installed. 4/11/2019 - This Action is ongoing as new issues are identified 3/2/21 - ongoing as required pending of arising issues OC - to provide quarterly updates 18/10/2021 - ongoing as above
2.52	Kem	M	Develop priority planning for online chlorine monitoring and secondary dosing at key reservoirs and implement into capital works program.	2012	In progress	ORP probes installed, chlorine analysers on three reservoirs 4/11/2019 - Scoping being undertaken to include integration of secondary dosing at all Res yet to have this ability 3/2/21 ongoing and pending budget availability 25/09/2021 - Incorporate secondary dosing mechanism in to "key" new monitoring sheds (i.e., Tristian shed installs).
2.54	Kem	H	Interlock control placed on all primary disinfection systems where there is online monitoring of chlorine installed on the reservoirs.	2012	Ongoing	Investigation required, may not be feasible 3/2/21 - investigation yet to be scheduled OC & MC to investigate and scope 23/09/2021 - Interlock to be added into Greenhill res - confirm set point to match Cl2 CCP limit (WTL to confirm set point - MC to implement)

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.56	All	VH	Flow meter monitoring or derived flow monitoring on outlet of reservoirs.	2012	Ongoing	Need to be confirmed 4/11/2019 - Captured current outlet meters in WaterOutlook, Scope installing of flow meters in identified gaps 3/2/21 - exiting meters been captured in WO - ongoing identification of gaps of where metres on outlets may be required 23/09/2021 - Phil (MC) -this item is ongoing for all future reservoir upgrades.
2.59	All	VH	To formulate a WQ induction program for all contract staff that have access to water supply facilities and conduct in house training for maintenance staff on WQ protection.	2012	In progress	Is undertaken, however may not be formalised 4/11/2019 - SOPs to be developed for maintenance/operational staff 3/2/21 - SWIMS to be finalised then SOPs to be developed 18/10/21 - To be added to WHS0115
2.6	Kem	H	Include SOP for alternative or emergency supplies or water restriction implementation if taking Greenhill Res offline in an emergency.	2012	In Progress	SOP to be developed 4/11/2019 - A desk top plan needs to be completed - then a system check OC & NC A desk top plan needs to be completed including asset capabilities- then a system audit check 5/2/21 - Yet to be started - Main lines being place to John Lane for the ability to take GH off line 18/10/2021 - NC to scope plan and get project into 2022-2023 program then GH refurb project for 2023-2024 - The GIS layer is for isolation valves of supply water system still to be developed
2.62	All	H	Upgrade telemetry at reservoir sites and include a review of the critical levels set and associated alarms for individual reservoirs.	2012	In progress	Council is currently undertaking related work, will be applied to water section 4/11/2019 All Reservoir levels done except for Thungutti - Ongoing review of critical levels 3/2/21 - Thungutti completed review of res critical levels are ongoing 23/09/2021 - Phil (MC) - MC to work with opps team to implement spreadsheet of res operational levels set points (MWS to send spreadsheet to MC
2.64	All	VH	KSC to maintain an up-to-date register of high-risk connections.	2012	In progress	4/11/2019 - this could have already been completed - MWS and WQO to try and locate 10/2/2021 - NC to confirm that high risk connection are identified and documented 18/10/22 - NC to confirm existence, content and storage location of high-risk connection register

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.65	All	VH	KSC to ensure compliance to plumbing codes for back flow prevention and high-risk areas via a reporting system Consider backflow prevention device inspection program for external/private customers, including maintaining a register	2012	In progress	4/11/2019 - to provide annual report on backflow Compliance Compliance section - external customers are responsible for maintaining and confirming the backflow devices are compliant by having a plumber check and certify them. These records are kept with the compliance section and will need to be chased up to ensure requirements are being met and maintained for a register of compliance 5/2/21 0 WQO to chase up compliance for reporting in Annual report 25/10/2021 - Registers are kept in Civic View and in Content Manager - but no inspection program done on the registers - MSW/WQO to begin discussion of audit requirements of the backflow registers with manager of D&C
2.66	All	H	Maintenance crews require separate repair equipment and clothing for water main works and wash down & disinfection procedures TBD for equipment that cannot be duplicated.	2012	In progress	SOP to be developed and regularly truck audits conducted to ensure disinfection carried and used 5/2/21 - In construction crews only have been separated out to Water and sewer, SOPs to be developed 18/10/22 - NC - SOPs are the only outstanding item of this action. Maintenance operations will be covered by SOPs and audit program
2.67	All	H	Storage of water main repair & installation materials to be improved to prevent contamination from vermin, debris and faecal material.	2012	In progress	SOP to be developed 7/11/2019 - SOP still in the development stage 5/2/21 - SOP still in development 18/10/2022 - SOPs delayed but SWIMs completed. NC - SOPs next to be developed
2.68	All	H	Develop an SOP for chlorination of mains after repairs, to include a sampling and testing regime after repair work is completed. Train staff on SOP	2012	In progress	SOP to be developed 5/2/21 - Budget recommended to be developed for NTU and Cl2 instruments for maintenance crews. SOPs to be developed 18/10/2021 - Ongoing NC - SOP to be developed need to include what post testing is feasible and equipment required

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.73	All	H	KSC to Initiate a routine maintenance program for all supply pressure pumps and records to be stored in appropriate storage location.		In progress	7/11/2019 - this is being captured in the WaterOutLook rollout 10/2/2021 - was assigned to TLW but moved to ME design of preventative maintenance program 23/09/2021 - Phil (MC) - this has already taken place, we now have all the data, and any changes that needed to take place have been done. We still need to standardise and review the booster pumps and continually improve each year as part of the Operational Plan 21-22 - HS01.1.6 - "Refurbish pumping stations across water infrastructure network" - 25/10/2021 - location of maintenance reports to be provided to Process team then this action can be closed off - MC to liaise with WQO of location for reporting purposes
2.75	All	H	Networks staff to be trained on valve operation and flushing after repairs including an implementation of a valve 'Check Sheet' with tagging system.	2012	In progress	Training completed, tagging system not completed 7/11/2019 - lock out tag out been implemented - however training yet to be performed and the check sheet has been included in the work order completion sheet 5/2/21 - LOTO training has been carried out (current staff, missing gaps for new starts) - SOP to be developed 18/10/2021 - SOP ongoing, refinement of isolation practices implemented
2.76	All	H	Control biofilm levels within the distribution by conducting a regular mains cleaning program. Problem areas to be placed on routine flushing programs with the linking of mains where possible and 'dead ends' minimised in new developments.	2012	Standing item	Some mains cleaning undertaken in known problem areas 7/11/2019 - pigging program being implemented Flushing programme has yet to be developed and placed on temporarily hold whilst water restriction are in place 10/2/2021 - Pigging program to commence 18/10/2021 - Status changes to a "Standing Item" on going standing flushing pigging programs
2.77	All	H	Review customer complaints to identify dirty main areas.	2012	Ongoing	Tracked in Monthly WQ report 7/11/2019 - yet to be developed - potential for the tracking of problem clusters for preventative maintenance to be actioned 5/2/21 - Can this be automatically mapped in new synergy soft reports WQO to investigate 18/10/2021 yearly report can be produced out of SS - monthly view is still in development to extract data from SS

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.8	Kem	L	KSC to investigate a notification procedure to inform carters if there is a main breaks or supply issue for fill stations (4 fill stations for all of KSC). D&C to inform Water division of auditing of carters.	2012	In progress	7/11/2019 - this is two separate actions 1. develop and formalized communication between Water team and Rates for water carters' notification when supply issues from Reservoirs 2. Devolvement and Compliance to report on audits of water carters 5/2/21 - as notes above NC - 1. develop SOP for communication to TLW and rates of supply loss 2. WQO to contact Development and Compliance about obtaining water caters audit results 18/10/2021 - as above ongoing
2.81	All	L	Communication procedure to be initiated between KSC and Rural Fire services and NSW Fire and Rescue for prior notification of RFS & NSW Fire & Rescue exercises to prevent disturbances of mains.	2012	To be started	MoU existed, however requires update 18/2/2021 - NC to develop plan 18/10/21 - still to be started
2.82	All	VH	All new mains to be inspected and have a disinfection program and verification before connection.	2012	In progress	7/11/2019 this is being done however SOP needs to be created 5/2/21 SOP to be developed - NC - develop SOP based on current work practices 18/10/2021 - no change in status, ongoing
2.84	Kem	H	Introduce a 'water by agreement' (WBA) to customers on rising main that the WQ may be variable for drinking (highly chlorinated). Annual notification sent to customers reminding them of the WBA.	2012	To be started	10/2/2021 - yet to be started. Chris Seam may have some additional information Review meeting with Health 21/05/21 to check if started by Belinda Green 18/10/2021 - NC to organise a audit for customers GH, PH, TH, to identify those that a straight of the main - then organise a WBA. Sherwood borefield identified customers to go on to a non-potable agreement MWS - to provide update as required
2.85	All	H	Upgrade the telemetry and SCADA system and online monitoring for all sites to improve operational monitoring capabilities and response times. On call staff to regularly check SCADA for system alarms. Duplicate (mirrored service) for monitoring for key sites. To increase in-house staff knowledge of the system and introduce security access levels.	2012	Standing item	Staff Knowledge completed, rest to be undertaken 7/11/2019 - ongoing 5/2/21 - this action is a rolling project with scheduled upgrades each financial year NSW Health meeting 21/5/2021 Potential moved long term ongoing actions into a new grouping " standing Items" (18/10/2021 this action was taken up during the Oct 21 IP review) 23/09/2021 - Phil (MC) - this is happening. Sewer SCADA ASM standards are nearly finished, and these will roll straight over to water sites fairly seamlessly.

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
2.9	Kem	H	Develop a program for installation of Security (CCTV) on high-risk sites, on priority basis and implement into Capital works program.	2012	Standing item	Long term action, will be considered as budget is secured. 10/2/2021 - started to be rolled out - MWS - to provide update-based in budget availability and risk assessment of what is a high-risk site 28/10/21 HH WTP completed and rest rolled out as infrastructure is upgraded
3.08	All	H	Consider additional filling points (backflow prevention compliant) for water carters and tankers (with future recycled water filling option i.e. non-potable). Consider a strategy for community information.	2014	In progress	10/2/2021 - new fill station locations have been identified and rollout to be begin. Carters will be notified as each station comes line - ongoing 18/10/2020 - this has been completed apart from recycled water - which will be confirmed of possible future outcomes of the IWCM Plan
3.13	ALL	H	CCP monitoring locations should be identified and appropriately labelled on each treatment site	2014	In Progress	7/1/2019 - in progress and inclusion of retic monitoring sites 10/02/21 - in progress for signs to be made and then places at appropriate locations 25/10/2022 - proto type sign has been developed - program being rolled out
3.15	HH	H	Develop an SOP for maintenance of aeration towers and cleaning procedure for the Hat Head aeration tower that includes: * adequate isolation procedures * sufficient flushing prior to recommissioning	2014	In Progress	10/2/2021 - in progress Find SOP and close off - 25/10/2021 TLW to get SOP from Craig Doyle for review
3.18	HH	H	Develop an SOP for Soda ash batching	2014	In Progress	10/2/2021 - in progress 25/10/2021 - new dosing system installed new SOP required /updated from SOP that was being developed
3.21	SWR	H	SOP is required for neutralising after soak clean Items added to action 2021 - Contamination from chemical spill into membrane sump - incorrect chemical cleaning practises (not neutralising correctly) Check that there are SOPs if not need to add to SOP development list	2014	In Progress	10/2/2021 this SOP is 90% completed 25/10/2021 - ongoing TLW - to provide update on SOP development

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
3.28	All	H	Council should consider doing a review of existing SOPs to identify where SOP's are required and where gaps are. This review should include a review of existing control measures documented in the Risk Assessments and ensure that these are adequately documented or identified as gaps if not documented. Ensure that all documents are registered into the Document Register in TRIM. Staff will need to undertake competency-based training on all SOP's	2014	In Progress	Will be undertaken as part of review 2018 19/11/2019 this task will be closed off once the SOPs have been developed. The DWMS review that was completed in June 2019 covered the identification of SOP gaps 18/2/21 - SOPs have been identified and assigned to the TLW for development 25/10/2021 - as comments of 18/2/2021
3.29	All	H	Council should develop or review daily task lists at each treatment plant to ensure general operations are covered.	2014	In Progress	Will be included in Water Outlook system, connected with electronic check sheets 19/11/2019 - WaterOutlook transfer has started, and operational tasks have been reviewed in the 2019 DWMS 10/2/2021 - TLW is currently developing a weekly scheduled Brocken into daily tasks that need to be completed at each WTP, tracking of daily tasks will be captured in WaterOutLook 25/10/2021 - in progress as notes on 10/2/2021 - action sites with TLW
3.3	All	M	A high turnover of staff can result in loss of operational knowledge resulting in operational gaps. Council should develop a procedure for succession planning for key staff members.	2014	In Progress	Succession planning is a whole of Council and is being considered 19/11/2019 informal system in place to upskill staff in acting positions. Council is in the process of developing a succession plan. 10/2/2021 - a work force plan is currently being developed 28/10/21 ongoing - workforce plan will be completed by the end of 21/22, and staff regularly act up to upskill
3.38	CH, HH, SP	M	Consider upgrading the chlorine dosing systems to include automatic shutdowns & shutoff valves, flow switches, scales etc., and integration with SCADA system and automation	2014	In Progress	19/11/2019 - upgrades have started at this water plants 5/2/21 -HH initial safety upgrade completed CH to be part of the new treatment plant. SP - ongoing 23/09/2021 - Phil (MC) - Awaiting Murray's CL2 report.
3.47	CH	L	Council to undertake investigations of a dedicated rising main for Big Nobby Reservoir from Back Beach Res/Skyline.	Aug-19	In progress	21/11/2019 - MWS to provide update if this is feasible 10/2/2021 - NC to liaise with W&S planning to see if a new main is feasible 18/10/2021 - NC to investigate assets renew of existing line and scope if new main is feasible

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
3.48	All	M	Continue removal or replacement of internal ladders with FRP	2014	Ongoing	All concrete reservoirs been done, good progress (NE, HH, BB, NB, WW done in 2017/18), ladders will be done when refurbishments are undertaken 19/11/2019 - this project is ongoing and progress and schedules are captured in both ASAM and Councils reservoir progress document 25/10/2021 - this is a long term project that is incorporated with the res refurb projects and captured in both ASAM and Councils reservoir progress document - TO to continue to provide updates as required
3.7	ALL	L	Council may consider providing water quality data on residents rates notices and/or publishing some of this data on their website	2014	In progress	Used to be on the website, but was removed when NSW Health removed theirs, decision to be made by GM 19/11/2019 decision yet to made 10/2/2021 - Council has begun to place some WQ information on Councils WEB page and additional information is currently being developed and rolled out
3.76	ALL	M	Council should strongly consider investing in online monitoring at all CCPs. This would provide greater process control, as immediate notification would be provided in the event an alert limit is exceeded. Importantly, it would also provide the opportunity of an immediate response in the event a critical limit is exceeded (such as triggering a plant shut down). Online monitoring would also provide useful data for analysis of performance of processes used to control hazards at CCPs and would improve understanding of the WTP's effectiveness more generally.	2014	In progress	19/11/2019 - this is ongoing with some of the CCPs having already been captured onto Clear SCADA 5/2/21 - ongoing and incorporated into yearly sub plan review 23/09/2021 - Phil (MC) - on-going, we need to gather all WTP / Water System SCADA Set Points and review them. We need to set Min and Max allowable Set Points and lock them into SCADA. MC - to double check that dosing set points affecting the CCPs are clamped and that alarms are reviewed
3.84	ALL	L	Council should consider implementing a monthly water quality performance report to be supplied to councillors and uploaded to Councils website.	2014	Ongoing	10/2/2021 - This is started to be rolled out with some information being displayed on the Web page and communicated weekly via Councils Facebook page - WQO, TLW & PE to discuss what data and what format to be web displayed 18/10/2021 - dam levels, rainfall and water usage for KLM supply added weekly to web site - other systems to be rolled out

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
3.97	ALL	M	An SOP for plant start up following a period of shutdown needs to be developed	Dec-14	Ongoing	10/2/2021 - This action is being incorporated into each plants operation SOP that is in the progress of being developed. This action can be closed off 25/10/2021 - All SOP are still in development - until incorporated into a SOP this action is to remain in the IP
4.01	All	H	Operators to ensure that reservoir inspections are occurring monthly as required, currently they are not occurring regularly	Dec-14	Standing item	Monthly inspection sheets are stored in F:Drive and Reviewed by WQO 21/11/2019 - this is also being transferred into WaterOutlook 10/2/2021 - Reservoir inspection reporting has been transferred into WaterOutlook, which generates reminders to the WO for completion - Lack of completion to be addressed at team meetings 25/10/2021 TLW and WQO run a report at least monthly (calendar reminders set) missing inspections are communicated to the operators - status changed to a standing Item
4.05	KLM	L	New raw water sample location to be established in pump room on Greenhill line, prior to disinfection dosing. Could use existing soda ash dosing point. Currently sampling from 8 m sample at dam which is not ideal.	Dec-14	In progress	Soda Ash point currently being used, permanent point will be put in as upgrades are done 21/11/2019 - A dedicated sample location to be identified and installed 10/2/2021 - in progress TLW - to identify sample tap location and organise installation 25/10/2021 - sampling done as manual grab at depth, future raw water sampling will be done at new WTP - discuss status at next review meeting
4.14	All	M	Develop a list of priority meters and power supplies that should be maintained by Council to be used during incident response if required	Dec-14	In progress	Develop a list of emergency power needed by Council during incident response 21/11/2019 - ongoing 5/2/21 - currently sizing power requirements for every Council asset (e.g., treatment plants and pump stations) this is to go into the BCP 23/09/2021 - Phil (MC) - Actively in progress
4.15	All	M	Clear SCADA to include reservoir volume as well as level	Dec-14	In progress	Will be incorporated into Clear SCADA, 21/11/2019 - ongoing ME to investigate 5/2/21 - ongoing 23/09/2021 - Phil (MC) - job in, awaiting ETA.

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
4.17	All	M	An audit of all chemical dosing interlocks for each treatment plant should be undertaken	Dec-14	In progress	Already undertaken, actions to be followed up 21/11/2019 - Need to re-check all audit findings then develop & implemented any actions TLW, OO & MC - Need to re-check all audit findings then develop & implemented any actions 5/2/21 - to be looked at - refer to 2019 comments 18/10/2021 - SP needs further controls in place as there are no interlocks - other sites still need to be looked at - ongoing
5.02	All	H	There was no Hazardous substances register, Pollution Incident Response Management Plan or emergency documentation stored on site. A SDS register was on site but it was out of date. The PIRMP needs to be distributed to all WTP's and in the vehicles of the operators. A Hazardous substances register and updated SDS's also need to be provided on this site. Explore the capabilities to utilise KMS.	Apr-16	In Progress	21/11/2019 - need to locate or developed a hazardous substance register. Council BCP recently updated that covers pollution incident responses and emergency protocols The rest needs to developed 10/2/2021 -SDS have been updated and are in date - - PIRMP currently being updated and training to be given to WO (by WQO) - Outstanding action is updating of the Hazardous goods register (TLW) 25/10/2021 - outstanding action is to update the Dangerous Goods registers only all other actions from 10/2/2021 have been completed
5.03	HH	L	There were no instructions on site for number of soda ash bags to be loaded when batching up the soda ash and the operator was not clear on how many to use. A simple SOP, or work instruction, should be developed for this and be available on site.	Apr-16	In progress	SOP for batching up will be developed 21/11/2019 - SOP yet to be developed TLW - to delegate to WO for development 10/2/2021 - SOP in development 25/10/21 - as above
5.04	HH	M	Investigations should also be made into pre dosing Chlorine to help iron oxidization	Apr-16	In Progress	Council to investigate if this is required 21/11/2019 - ongoing 10/2/2021 - There is no Zeolite at HH. Investigate pre-dose chlorine for iron oxidization 18/10/2021 - Investigations to pre-dose chlorine for iron oxidization is ongoing
5.06	BB, Th, WW	L	The dilution instructions for the Hypo are written on the storage container and the manual backwash instructions for the arsenic filter is taped to the filter. These should be developed into controlled SOP's and maintained in the O&M Manual	Apr-16	In progress	SOP to be developed 21/11/2019 - Hypo SOP has been started Arsenic filter SOP yet to be started 10/2/2021 - SOP in progress 25/10/21 - ongoing

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
5.11	Th	VH	Permanent ladder access to both reservoirs Safety rail around second reservoir and replace swimming pool fencing on first reservoir and replace with safe access railing (pool fence collects debris on top of the reservoir) Consider security fencing around reservoirs Overflow is an open hole with a mesh covering, this needs to be fixed.	Apr-16	Ongoing	Overflow completed, rest to be undertaken 21/11/2019 - consultation to occur at next quarterly meeting with Health and Dol 10/2/2021 - quotes and proposal to be sent to DPE 25/10/2021 - quotes have not been sent - waiting for next DPE meeting (1/11/2021_ to bundle all projects together
5.12	Th	L	Reservoir diagrams of all valves, taps, pipes, scouring options and interconnections required Separate scours for each reservoir required (to be done)	Apr-16	In progress	21/11/2019 - PE investigate scouring options at Reservoir 10/2/2021 Investigation yet to begin 18/10/21 - Basic design has been scoped and quoted. Project to be tables with DPE
5.13	Th	H	Consider Security fencing around Treatment Plant Buildings	Apr-16	In progress	21/11/2019 - consultation to occur at next quarterly meeting with Health and Dol 10/2/2021 - further discussion required 18/10/2021 - still in consultation with DPE
6	KLM, CH, SP, WW BB Th	M	Chemicals from agricultural runoff near bores - Consult with NSW Health for sponsored sampling programme to test all bores 6monthly over 2-year period to develop base line for protection actions. This could include hydrocarbon testing to capture potential fuel ingress	Nov-19	To be started	Develop a project brief and send to NSW Health if not approved by Health consider adding into our sampling monitoring program 10/2/2021 - Project brief to developed 25/10/2021 - brief to be completed TLW & WQO to action
6.01	KLM	H	Investigate installation of online monitoring at SMD for nutrients e.g., TN & TP	Nov-19	In progress	To re-assess pending approval of emergency treatment plant. May need to consider move to balance tank 5/2/21 - if online Nutrient monitoring required will be implemented in new treatment plant 23/09/2021 - Phil (MC) - as previous comment, to be included into new WTP
6.02	ALL	H	Development of SOP for testing methodologies of Iron and Manganese	Nov-19	In progress	Development of all spot field methodologies 10/2/2021 - SOP in development 25/10/2021 - collate all instrument methodologies and distribute to operators TLW - to pass onto WO

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
6.04	SMD	H	Confirm inspections For SMD are included in the site management procedure - relating to access and contamination from animals	Nov-19	In progress	inspections to be included in site management procedure. (JN to confirm - then remove 16/09/19) 10/2/2021 - Inspections are included in 4.12.4. this action can be closed off 25/10/2021 - documentation has changed action to remain in IP until new documentation completed
6.05	HH & KNCH	H	Aeration at Hat Head - update maintenance programme to a 6 monthly frequency opposed to yearly	Nov-19	In progress	6-month inspection to be added with a separate yearly clean. This is to be captured in the plant SOP 10/2/2021 - SOP in progress, scheduled to be included in the overall plant SOP 25/10/2021 - ongoing
6.06	SWR	M	Failure of blowers at borefield affecting downstream process Development of SOPs for Blower inspections and investigate automatic plant shut down on interlocks into Clear SCADA	Nov-19	To be started	5/2/21 - Not yet started 25/10/2021 - MC - investigate SCADA interlocks TLW - to action development of SOP / integrate into WaterOutlook
6.08	BB, SWR, SP	M	Update and/or development of SOPs for use of coagulants and other chemicals at treatment plants. This Should include the process for Jar Testing - in context of Equipment failure resulting in under dosing chlorine and not precipitating iron and arsenic (chlorine added for oxidation and Coagulation for arsenic)	Nov-19	In progress	18/2/21 - In progress 25/10/2021 - ongoing TLW - to action
6.09	SWR & BB	M	Manganese & Iron issue in borefield Long term options are WTP extension with the inclusion of additional pre-treatments	Nov-19	In progress	10/2/2021 - BB WTP augmentation is being sort for the plant, this will include review of crypto risk and options for manganese and iron removal SWR long term options are ongoing 28/10/21 - ongoing as above

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
6.1	SP	M	reject water from the clarifier enters inlet stream investigate corrective actions to minimise reject water entering clarifier.	Nov-19	In progress	PE - need to install E1 pump station for reject water ME - trades to investigate leak 5/2/21 - initial investigation has begun 18/10/2021 - E1 pump still to be investigated - ongoing. OC to brief TO on project requirements
6.12	SWR	H	investigation required for SWR for CIP - Consider installation of new membrane cleaning tank	Nov-19	In progress	quotes received for new tank and bund and prep work on chemical storage area 10/2/21 - New neutralization tank installed - progressing with CIP connection to new tank 18/10/2021 - tank installed awaiting on design
7.01	KLM	H	Automated overflow cone valve testing program	Nov-20	In progress	10/2/2021 -This in in the budget for 21-22, completion by June 22 23/09/2021 - Phil (MC) - in progress, MC arranging with Engineering Trade's Team
7.02	ALL	H	Investigate installing of aqua-jetter/mixer on required Reservoirs (PH, FREDO, New Entrance, upgrade of BB from static and JL)	Nov-20	To be started	10/2/2021 -Needs investigation of scope of works and to be incorporated into future budgets 18/10/21 - Investigation yet to begin
7.05	ALL	L	When performing manual slug dosing of reservoirs/Clear Water Tanks the Team Leader or Senior Water Operator need to be informed beforehand to double check dose rate calculations	Nov-20	Standing Item	10/2/2021 - SOP to be developed and then Tool boxed to team also to be added to Water Outlook 25/10/21 - Slug dose amount column has been added to WaterOutlook - SOP still to be developed
7.06	ALL	VH	Investigate having the door alarms connected to each Water locations - can be either to security company ,SCADA or other security control also Back to base security alarm system required for all treatment facilities (old action number 2.42)	Nov-20	To be started	10/2/2021 - Investigate to confirm alarms on all Water Assets treatment plant main access doors and begin scope of works investigation for alarms on reservoir hatches 25/10/2021 - Action is to liaise with facility Management for alarming at water assets

Action No.	Supply System	Residual Risk	Outstanding Actions	Date Added	Status	Actions & Comments
7.07	ALL	VH	Investigate of cameras on key assets	Nov-20	Ongoing	10/2/2021 - Started to investigate sites and proposed money allocation been requested into the 22-23 budget for SWR and the SMD at this stage 23/09/2021 - Phil (MC) - ongoing, installed at Hat Head WTP in 2021. These will initially be stand-alone systems that record locally, with the cabinet key living with Manager Water & Sewer for security reasons. We will need to review when and how we access these systems remotely with the help of IT. 18/10/21 - Hat Head cameras completed, other plants yet to be done
7.08	ALL	M	Develop re-order sheets for each plant with identification at what minimal chemical levels should be carried	Nov-20	To be started	10/2/2021 - Develop SOP that covers all plants minimal Chemical levels and for it to be listed, this list then to be incorporated into SCADA as an alert alarm for when to re-order 25/10/2021 - yet to begin
7.09	ALL	H	review SCADA alarms at each plant (Hat Head STP is completed)	Nov-20	Ongoing	10/2/2021 -Ongoing review of all SCADA systems and Plant functional description across all water and sewer 23/09/2021 - Phil (MC) - ongoing as part of Council SCADA systems upgrade.
7.11	SP	L	Online monitoring to be installed at Stuart Point combined raw water at CCP1 AND CCP2 for automatic shutdown capabilities	Feb-21	To be started	18/2/2021 - To be investigated 23/09/2021 - Phil (MC) - as 18/2/2021 comment - to be investigated.