

COFFS HARBOUR LABORATORY

Environmental Analysis

Page 1 of 2



KEMPSEY SHIRE COUNCIL
BLAKE GIDDY
P.O. BOX 3078
WEST KEMPSEY NSW 2440

BATCHNUMBER: 25/0961
No. of SAMPLES: 5
DATE COLLECTED: 23/04/25
DATE RECEIVED: 23/04/25
TIME RECEIVED: 16:30
DATE TESTING COMMENCED:
23/04/25

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
25/0961/1	South Kempsey TP
25/0961/2	Crescent Head CW
25/0961/3	West Kempsey TP
25/0961/4	Hat Head C. Well
25/0961/5	South Kempsey STP Head Wall Day Pond

ANALYSIS	UNITS	25/0961/1	25/0961/2	25/0961/3	25/0961/4	METHOD NO
pH	pH unit	7.0	7.5	7.3	7.5	APHA 4500-H+ B
Conductivity	µS/cm	-	933	-	998	APHA 2510 B
Total Dissolved Solids	mg/L	-	-	-	638	EL7B
Turbidity	NTU	-	1.2	-	0.75	APHA 2130 B
Transmittance#	%	-	-	-	-	EL**32
Alkalinity	mg CaCO ₃ /L	-	-	-	135	APHA 2320 B
Total Suspended Solids	mg/L	2	5	19	2	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	<2	<2	6	<2	APHA 5210 B
Nitrate Nitrogen	mg/L	-	5.59	2.76	0.42	APHA 4500-NO3 I
Nitrite Nitrogen	mg/L	-	-	0.62	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	0.46	0.05	0.60	<0.02	APHA 4500-NH3 H
Total Nitrogen	mg/L	2.45	7.06	5.58	1.23	APHA 4500-P J
Total Phosphorus	mg/L	3.18	0.25	0.14	0.11	APHA 4500-P J
Potassium	mg/L	-	-	-	23	EL9A
Chloride	mg/L	-	-	-	131	EL10
Oil & Grease	mg/L	<2	<2	<2	<2	EL23A



Accredited for compliance with ISO/IEC 17025 - Testing
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	25/0961/1	25/0961/2	25/0961/3	25/0961/4	METHODNO
Chlorophyll-a	µg/L	-	-	62	-	APHA 10200 H
Thermotolerant Coliforms	cfu/100mL	240	0	80	2	ELM3

ANALYSIS	UNITS	25/0961/5				METHODNO
pH	pH unit	-				APHA 4500-H+ B
Conductivity	µS/cm	-				APHA 2510 B
Total Dissolved Solids	mg/L	-				EL7B
Turbidity	NTU	-				APHA 2130 B
Transmittance#	%	-				EL**32
Alkalinity	mg CaCO ₃ /L	-				APHA 2320 B
Total Suspended Solids	mg/L	-				APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	-				APHA 5210 B
Nitrate Nitrogen	mg/L	-				APHA 4500-NO3I
Nitrite Nitrogen	mg/L	-				APHA 4500-NO 2
Ammonia Nitrogen	mg/L	-				APHA 4500-NH3H
Total Nitrogen	mg/L	-				APHA 4500-P J
Total Phosphorus	mg/L	-				APHA 4500-P J
Potassium	mg/L	-				EL9A
Chloride	mg/L	-				EL10
Oil & Grease	mg/L	-				EL23A
Chlorophyll-a	µg/L	-				APHA 10200 H
Thermotolerant Coliforms	cfu/100mL	50				ELM3

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 24th Edition, 2023, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Measurement Uncertainty is available upon request.

Report Date: 5/05/25



Accredited for compliance with ISO/IEC 17025 - Testing
Accreditation Number: 12359

Approved:

Shane Ewart

Shane Ewart
Technical Supervisor
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.